

257.84 (b)(2)	<b>2020 REPORT OF ANNUAL INSPECTION OF CCR LANDFILL</b>	
	<b>CCR LANDFILL NAME:</b> Plant Bowen Private Industrial Solid Waste (Coal Combustion By-product) Disposal Facility (Active Cells 1 & 2, 3 & 4, 9 & 10). Permit # 008-018D(LI).	
	<b>OWNER OF CCR LANDFILL:</b> Georgia Power Company	
	<b>INSPECTION DATE:</b> 11/04/2020	
	<b>INSPECTING ENGINEER:</b> Gary H. McWhorter, P.E. GA Reg. #PE012687	
(i)	<b>ANY CHANGES IN GEOMETRY OF THE STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION?</b>	<b>NO</b> <sup>(1)</sup>
	(IF YES, DESCRIBE):	
(ii)	<b>APPROXIMATE VOLUME OF CCR CONTAINED IN THE UNIT AT THE TIME OF INSPECTION?</b>	<b>1,418,765 cy</b> <sup>(2)</sup>
(iii)	<b>ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT?</b>	<b>NO</b>
	<b>(IF YES, DESCRIBE):</b>	
(iv)	<b>ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION OF THE CCR UNIT SINCE THE PREVIOUS ANNUAL INSPECTION?</b>	<b>NO</b>
	<b>(IF YES, DESCRIBE):</b>	

- (1) The geometry of the structure (permitted footprint and final grades) has not changed since the last inspection, with the exception of the additional placement or marketing of CCR.
- (2) Approximate CCR volume: Cell 1 (by survey dated 12/14/2020) – 101,866 cy; Cell 2 – 0 cy; Cell 3&4 (by survey dated 12/15/2020; operated as one cell) – 1,316,899 cy (operated as one cell); Cell 9&10 – 0 cy.

