

## Coal Combustion Residuals (CCR) Annual Fugitive Dust Control Report

**PLANT NAME:** Plant McDonough

**OWNER/OPERATOR OF FACILITY:** Georgia Power

**REPORTING TIMEFRAME:** October 20, 2019 – October 19, 2020

**PURPOSE:** The purpose of this report is to demonstrate compliance with the requirements for the annual CCR fugitive dust control report in 40 CFR § 257.80 (c) of the Coal Combustion Residuals Final Rule. See 80 Fed. Reg. 21,302 (April 17, 2015). This report describes the actions taken by Plant McDonough to control CCR fugitive dust, a record of all citizen complaints and if any, a summary of corrective measures taken.

### **DESCRIBE THE ACTIONS TAKEN TO CONTROL FUGITIVE DUST.**

CCR Units:

Ash Pond 1 (AP-1): AP-1 has been substantially capped in place.

Ash Pond 2 (AP-2): CCR has been removed from AP-2 in accordance with the closure plan.

Ash Pond 3 (AP-3): Fugitive dust was controlled by water suppression, chemical dust suppressants, or synthetic liners, as needed.

Ash Pond 4 (AP-4): Fugitive dust was controlled by water suppression, chemical dust suppressants, or synthetic liners, as needed.

Roads, CCR management and material handling activities:

Water suppression was used as needed to control fugitive dust on facility roads used to transport CCR and other CCR management areas.

Speed limits were utilized to reduce the potential for fugitive dust.

Trucks used to transport ash were covered and/or filled at or under capacity to reduce the potential for material spillage.

CCR that was transported via truck on the plant site was conditioned to an appropriate moisture content to reduce the potential for fugitive dust.

HAS THE FACILITY RECEIVED ANY CCR FUGITIVE DUST CITIZEN COMPLAINTS WITHIN THE REPORTING TIMEFRAME?	Yes	No
--	-----	----

IF YES, INCLUDE A RECORD OF ALL CITIZEN COMPLAINTS

Date	Description of Complaint	Corrective Measures (If Any)