| 257.83 (b) (2) | REPORT OF ANNUAL INSPECTION C | F CCR SU | RFACE IM | POUI | NDMENT | | | |
|-------------------|---|--|-------------------------|--|---|--|--|--|
| | FACILITY NAME: Plant Scherer Ash Pond | | | | | | | |
| | OWNER/OPERATOR OF FACILITY: Georgia Power Company | | | | | | | |
| | INSPECTION DATE: December 10, 2021 | | | | | | | |
| | INSPECTING ENGINEER: Patrick B. Rhodes, P.E. | (Georgia P.I | E. License # | 24586 | | | | |
| (i) | ANY CHANGES IN GEOMETRY OF THE IMPOUN SINCE THE PREVIOUS ANNUAL INSPECTION? | DING STRU | CTURE | | No | | | |
| | (IF YES, DESCRIBE): | | | | | | | |
| (ii) | LOCATION AND TYPE OF EXISTING INSTRUMEN | NTATION | | See | Attached Plans | | | |
| (ii) | MAXIMUM RECORDED READING OF EACH INST | | INCE | See / | Attached Tables | | | |
| | APPROXIMATE MINIMUM, MAXIMUM AND PI | | | EVATI | ON OF THE | | | |
| | MIN. DEPTH: 0 ft ⁽¹⁾ | MAX. DEP | TH: 61.2 | PRES to 61 | ENT DEPTH: Up 1 ft | | | |
| | MIN. ELEVATION: 492.5 ft | MAX. ELE\ 494.2 ft | VATION: | PRES | ENT. ATION: 494.1 ft | | | |
| (iii) | APPROXIMATE MINIMUM, MAXIMUM AND PI | | TH AND EL | | | | | |
| | MIN. DEPTH: 1 ft | MAX. DEP | TH: 87 ft | PRES to 87 | ENT DEPTH: Up ' FT | | | |
| (iv) | MIN. ELEVATION: 420 ft | MAX. ELE ¹ 505 ft ⁽¹⁾ | VATION: | PRESENT ELEVATION: Up to 505 ft ⁽¹⁾ | | | | |
| (iv) | APPROXIMATE STORAGE CAPACITY OF IMPOU | INDING | 2 | 9,846, | 667 yd³ | | | |
| (v) | APPROXIMATE VOLUME OF IMPOUNDED WATCCR AT TIME OF INSPECTION | TER AND | WATER: 11,484,00 | 0 yd³ | CCR: Approx 15,300,000 yd ³ | | | |
| (vi) | ANY APPEARANCE OF AN ACTUAL OR POTENT WEAKNESS OF THE CCR UNIT, IN ADDITION TO CONDITIONS THAT ARE DISRUPTING OR HAVE DISRUPT THE OPERATION AND SAFETY OF THE APPURTENANT STRUCTURES? | ANY EXIST | ING NTIAL TO | | No | | | |
| | (IF YES, DESCRIBE): | | | _ | | | | |
| (vii) | ANY OTHER CHANGE(S) WHICH MAY HAVE AF STABILITY OR OPERATION SINCE THE PREVIOU INSPECTION? | | | | No | | | |
| | (IF YES, DESCRIBE): | | | | | | | |

(1) An ash delta is present along the south end of the ash pond. Highest ash elevation of 505 ft occurs along the south end of the ash pond but not at the maximum depth of the ash pond.

(2) Cubic yard estimates are derived by qualified personnel from available information.

No. 24586 PROFESSIONAL

PLANT SCHERER ASH POND MAXIMUM RECORDED READINGS OF INSTRUMENTATION

PIEZOMETERS AT STATION 21+50

| PIEZOMETER NUMBER | MAXIMUM RECORDED READING ⁽¹⁾ |
|-------------------|---|
| AP10 | EL 475 |
| AP11 | EL 477 |
| AP13 | EL 476 |
| AP14 | EL 477 |
| APA2 | EL 472 |
| APA2A | EL 472 |
| APA3 | EL 472 |
| APA3A | EL 474 |
| APA4A | EL 476 |
| APA5 | EL 475 |
| APA5A | EL 473 |
| AP12R (AP12) | EL 478 |
| AP12A | EL 466 |

⁽¹⁾ Maximum recorded reading since last annual inspection; rounded to the nearest foot.

PIEZOMETERS AT STATION 42+00

| PIEZOMETER NUMBER | MAXIMUM RECORDED READING ⁽¹⁾ |
|-------------------|---|
| AP1R | EL 439 |
| AP2 | EL 471 |
| AP3 | EL 437 |
| AP4 | EL 421 |
| AP5 | EL 422 |
| AP8R | EL 411 |
| AP9R | EL 413 |

⁽¹⁾ Maximum recorded reading since last annual inspection; rounded to the nearest foot.

PIEZOMETERS AT STATION 75+40

| PIEZOMETER NUMBER | MAXIMUM RECORDED READING ⁽¹⁾ | |
|-------------------|---|--|
| AP6 | EL 479 | |
| AP7 | EL 478 | |

⁽¹⁾ Maximum recorded reading since last annual inspection; rounded to the nearest foot.

TOE DRAIN SUMP FLOWS(1)

| PUMP NUMBER | MAXIMUM MEASURED FLOW | |
|-------------|-----------------------|--|
| PS-1 | 20 gpm | |
| PS-2 | 3 gpm | |
| PS-5 | 59 gpm | |
| PS-6 | 1.2 gpm | |

⁽¹⁾ Toe drain flows collected in a sump and pumped back into Ash Pond.



