



630 Colonial Park Drive
Suite 110
Roswell, GA 30075
(770) 594-5998
www.atlcc.net

GROUNDWATER EXCEEDANCE NOTIFICATION
40 C.F.R. PART 257.95(g)
PLANT WANSLEY AP
GEORGIA POWER COMPANY

Consistent with the previous semiannual monitoring event, the following Appendix IV constituent(s) were detected at statistically significant levels above groundwater protection standards established pursuant to the "Disposal of Coal Combustion Residuals from Electric Utilities" Final Rule, 40 C.F.R. 257.95(h) and Georgia EPD Rules for Solid Waste Management 391-3-4-.10(6)(a).


Federal CCR Rule

- Lithium

State of Georgia CCR Rule

- Lithium

Georgia Power will continue groundwater monitoring and reporting activities as required by 40 C.F.R. §257.95.


Richard T. Deason, P.E.
CEO

March 1, 2019
Date