257.83 (b) (2)	REPORT OF ANNUAL INSPECTION	ON OF CCR SU	JRFACE I	MPOL	JNDMENT	
	FACILITY NAME: Plant Wansley Ash Pond					
	OWNER/OPERATOR OF FACILITY: Georgia Power Company					
	INSPECTION DATE: December 4, 2023					
	INSPECTING ENGINEER: Patrick B. Rhodes, P.E. (Georgia P.E. License #24586)					
(i)	ANY CHANGES IN GEOMETRY OF THE IMPOUNDING STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION?			No		
	(IF YES, DESCRIBE):					
(ii)	LOCATION AND TYPE OF EXISTING INSTRUMENTATION.  See Attached Plan					
(ii)	MAXIMUM RECORDED READING OF EACH INSTRUMENT SINCE PREVIOUS ANNUAL INSPECTION.			See Attached Table		
	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF THE IMPOUNDED WATER SINCE PREVIOUS ANNUAL INSPECTION.					
	MIN. DEPTH:	MAX. DEPTH:	EPTH:		PRESENT DEPTH:	
	0 ft (ASH DELTA PRESENT) 50 ft			Up to 48 ft		
		MAX. ELEVATION: 785 ft		PRESENT. ELEVATION:		
	1			783 ft		
(iii)	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF CCR SINCE PREVIOUS ANNUAL INSPECTION.					
	MIN. DEPTH:	MAX. DEPTH:		PRESENT DEPTH:		
	0 ft 1	110 ft MAX. ELEVATION:		Up to 94 ft		
	MIN. ELEVATION:			PRESENT ELEVATION:		
	705 ft 8	815 ft		Up to 815 ft		
(iv)	APPROXIMATE STORAGE CAPACITY OF IMPOUNDING 29,615,000 yd <sup>3 (2)</sup>			000 yd <sup>3 (2)</sup>		
(v)	APPROXIMATE VOLUME OF IMPOUNDED	WATER AND	WATER:		CCR:	
	CCR AT TIME OF INSPECTION. 9,562,00		O yd³	15,700,000 yd <sup>3</sup>		
(vi)	ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT AND APPURTENANT STRUCTURES?					
	(IF YES, DESCRIBE):					
(vii)	ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION SINCE THE PREVIOUS ANNUAL INSPECTION?			No		
	(IF YES, DESCRIBE):					

(1) Cubic yard estimates are derived by qualified personnel from available information.

(2) Approximate storage capacity of impounding structure is estimated as the total storage volume of the pond up to the dam crest elevation of 805 feet.

## INSTRUMENTATION READINGS PLANT WANSLEY ASH POND

## PIEZOMETERS INSTALLED ON SEPARATOR DIKE BETWEEN ASH POND AND STORAGE POND

PIEZOMETER NUMBER	LOCATION	MAXIMUM RECORDED READING*
ВВ	N 33° 24.939′, W 85° 02.507′	EL 780
DD	N 33° 25.063′, W 85° 02.656′	EL 782

<sup>\*</sup>MAXIMUM RECORDED READING SINCE LAST ANNUAL INSPECTION; ROUNDED TO NEAREST FOOT

