

**INITIAL WRITTEN CLOSURE PLAN
40 C.F.R. PART 257.102
PLANT YATES ASH POND A (AP-A)
GEORGIA POWER COMPANY**

SITE INFORMATION

Site Name / Address

Eugene A. Yates Power Plant
708 Dyer Road
Newnan, GA 30263

Owner Name / Address

Georgia Power Company
241 Ralph McGill Blvd
Atlanta, GA 30308

CCR Unit

AP-A

Closure Method

Closure by Removal

CLOSURE PLAN DESCRIPTION

§ 257.102(b)(1)(i) – Narrative description of how the CCR unit will be closed.

All CCR from the Plant Yates AP-A has been removed. The CCR from AP-A was either placed in Landfill R6, a permitted dry ash landfill located within the boundary of Plant Yates, or used to construct grades to provide drainage on top of a portion of Pond AP-3 as part of the closure plan for Pond AP-3. The closure procedure included removing all visible ash, over excavating into the subgrade soils, and placement of topsoil and permanent vegetative cover to provide erosion control for the completed surfaces. Closure will also include confirmation that groundwater monitoring concentrations do not exceed the groundwater protection standard established for constituents in Appendix IV of the Rule.

§ 257.102(b)(1)(iv) – Estimate of the maximum inventory of CCR ever on-site over the active life of the CCR unit

Approximately 725,000 cubic yards of CCR was removed from AP-A.

§ 257.102(b)(1)(vi) – Closure Schedule

CCR removal at Yates AP-A began in October 2014, and was completed in June 2017.

Certification Statement 40 CFR §257.102(b)(4)

Initial Written Closure Plan

Site Name / Address

Eugene A. Yates Power Plant
708 Dyer Road
Newnan, GA 30263

Owner Name / Address

Georgia Power Company
241 Ralph McGill Blvd
Atlanta, GA 30308

CCR Unit

AP-A

Yates AP-A has undergone CCR removal in accordance with §257.102(c), no longer impounds free water nor receives CCR, and is in the process of obtaining a solid waste permit under the Georgia Rules for Solid Waste Management, 391-3-4-.10. As such, Yates AP-A no longer meets the definition of a CCR Surface Impoundment.

I hereby certify that the documentation above is accurate based on current available information.

James C. Pegues, P.E.
Licensed GA PE 17419

