257.83 (b) (2)	REPORT OF ANNU	JAL II	NSPECTION OF C	CR SUF	RFACI	E IMPOUI	NDMENT		
	FACILITY NAME: Plant Yates – Ash Pond 3								
	OWNER/OPERATOR OF FACILITY: Georgia Power Company								
	INSPECTION DATE: August 22, 2018								
	INSPECTING ENGINEER: Patrick B. Rhodes, PE (GA Reg. # PE024586)								
(i)	ANY CHANGES IN GEOMETRY OF THE IMPOUNDING STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION?					NO			
	(IF YES, DESCRIBE):								
(ii)	LOCATION AND TYPE OF I	EXIST	NG INSTRUMENTAT	TION		SEE ATTACHED TABLE			
(ii)	MAXIMUM RECORDED READING OF EACH INSTRUMENT SINCE					SFF ATT	ACHED TABLE		
	PREVIOUS ANNUAL INSPECTION								
(iii) 	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF THE								
	IMPOUNDED WATER SINCE PREVIOUS ANNUAL INSPECTION								
	MIN. DEPTH: 0 ft.	MAX. DEPTH: 0 ft. PRESENT DEPTH: 0 ft.							
4	MIN. ELEVATION: N/A MAX. ELEVATION: N/A PRESENT. ELEVATION: N/A								
(iii) 	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF CCR SINCE PREVIOUS ANNUAL INSPECTION.								
	MIN. DEPTH: 0 ft.	MAX. DEPTH: 18.8 ft. PRE		SENT DEPTH: 18.8 ft.					
	MIN. ELEVATION: N/A	MAX. ELEVATION: ft.	748.8 PRESENT ELEVATION: 748 ft.		TION: 748.8				
(iv)	APPROXIMATE STORAGE CAPACITY OF IMPOUNDING STRUCTURE AT TIME OF INSPECTION.			1,000,000 yd³					
(v)	APPROXIMATE VOLUME OF IMPOUNDED WATER			WATER: <20,000 yd ³ CCR:			CCR:		
	AND CCR AT TIME OF INSPECTION			See No	ote 1		750,200 yd ³		
(vi)	ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT AND APPURTENANT STRUCTURES?						NO		
	(IF YES, DESCRIBE):								
(vii)	ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION SINCE THE PREVIOUS ANNUAL INSPECTION?						NO		
	(IF YES, DESCRIBE):								

Note 1: An accurate estimate of the stored volume in AP3 at the present time cannot be made due to ongoing closure activities which includes CCR being relocated to AP-3 from other onsite ash pond closures. Any water within AP3 is temporary stormwater detained in separate detention ponds.

⁻ Cubic yard estimates are derived by qualified personnel from available information.

LOCATION AND TYPE OF EXISTING INSTRUMENTATION YATES ASH POND 3

Instrument No	Type of Instrument	Location of Instrument		Maximum Reading Since	
Instrument No.		Northing	Easting	Last Inspection	
EP-1	Piezometer	1256501.06	2074989.17	EL 747	
EP-2	Piezometer	1256505.95	2074993.04	EL 747	
EP-3	Piezometer	1256695.48	2075039.36	EL 744	
EP-4	Piezometer	1256704.31	2075043.75	EL 744	
EP-5	Piezometer	1256979.79	2075116.41	EL 745	
EP-6	Piezometer	1256985.02	2075118.90	EL 745	

