

257.83 (b) (2)	REPORT OF ANNUAL INSPECTION OF CCR SURFACE IMPOUNDMENT		
	FACILITY NAME: Plant Yates – Ash Pond B'		
	OWNER/OPERATOR OF FACILITY: Georgia Power Company		
	INSPECTION DATE: August 22, 2018		
	INSPECTING ENGINEER: Patrick B. Rhodes, PE (GA Reg. # PE024586)		
(i)	ANY CHANGES IN GEOMETRY OF THE IMPOUNDING STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION?		YES
	(IF YES, DESCRIBE): The impounding area is in the process of being filled with ash as a part of closure. It no longer impounds water, and the existing embankments now retain only compacted ash.		
(ii)	LOCATION AND TYPE OF EXISTING INSTRUMENTATION		NO INSTRUMENTATION
(ii)	MAXIMUM RECORDED READING OF EACH INSTRUMENT SINCE PREVIOUS ANNUAL INSPECTION		N/A
(iii)	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF THE IMPOUNDED WATER SINCE PREVIOUS ANNUAL INSPECTION		
	MIN. DEPTH: 0 ft.	MAX. DEPTH: 0 ft.	PRESENT DEPTH: 0 ft.
	MIN. ELEVATION: N/A	MAX. ELEVATION: N/A	PRESENT. ELEVATION: N/A
(iii)	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF CCR SINCE PREVIOUS ANNUAL INSPECTION.		
	MIN. DEPTH: 0 ft.	MAX. DEPTH: 27 ft.	PRESENT DEPTH: 27 ft.
	MIN. ELEVATION: N/A	MAX. ELEVATION: 772 ft.	PRESENT ELEVATION: 772 ft.
(iv) 1	APPROXIMATE STORAGE CAPACITY OF IMPOUNDING STRUCTURE AT TIME OF INSPECTION.		575,913 yd ³
(v)1	APPROXIMATE VOLUME OF IMPOUNDED WATER AND CCR AT TIME OF INSPECTION		WATER: 0 yd ³ See Note 1 CCR: 473,627 yd ³
(vi)	ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT AND APPURTENANT STRUCTURES?		NO
	(IF YES, DESCRIBE):		
(vii)	ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION SINCE THE PREVIOUS ANNUAL INSPECTION?		NO
	(IF YES, DESCRIBE): N/A		

Note 1: An accurate estimate of the stored volume in APB' at the present time cannot be made due to ongoing closure activities which includes CCR being relocated to the area from other onsite ash pond closures. Any water in APB' is temporary stormwater.

Note 2: All previous instrumentation has been removed as a part of the closure process.

- Cubic yard estimates are derived by qualified personnel from available information.

