



630 Colonial Park Drive
Suite 110
Roswell, GA 30075
(770) 594-5998
www.atlcc.net

GROUNDWATER EXCEEDANCE NOTIFICATION

40 C.F.R. PART 257.95(g)

PLANT YATES AP-3 and B/B'

GEORGIA POWER COMPANY

Consistent with the previous semiannual monitoring event, the following Appendix IV constituent(s) were detected at statistically significant levels above groundwater protection standards established pursuant to the "Disposal of Coal Combustion Residuals from Electric Utilities" Final Rule, 40 C.F.R. 257.95(h) and Georgia EPD Rules for Solid Waste Management 391-3-4-.10(6)(a).


Federal CCR Rule

- Beryllium

State of Georgia CCR Rule

- Beryllium

Georgia Power will continue groundwater monitoring and reporting activities as required by 40 C.F.R. §257.95.


Richard T. Deason, P.E.
CEO

March 1, 2019
Date