


257.84 (b)(2)	2022 REPORT OF ANNUAL INSPECTION OF CCR LANDFILL	
CCR LANDFILL NAME: Plant Hammond – Huffaker Road Private Industrial Solid Waste (Coal Combustion By-Product) Disposal Facility (Active Cells A & B, E). Permit 057-022D(LI).		
OWNER OF CCR LANDFILL: Georgia Power Company		
INSPECTION DATE: 11/9/2022		
INSPECTING ENGINEER: Gary H. McWhorter, P.E. GA Reg. #PE012687		
(i)	ANY CHANGES IN GEOMETRY OF THE STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION?	NO ⁽¹⁾
(IF YES, DESCRIBE):		
(ii)	APPROXIMATE VOLUME OF CCR CONTAINED IN THE UNIT AT THE TIME OF INSPECTION?	1,495,308 yd³ ⁽²⁾
(iii)	ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT?	NO
(IF YES, DESCRIBE):		
(iv)	ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION OF THE CCR UNIT SINCE THE PREVIOUS ANNUAL INSPECTION?	NO
(IF YES, DESCRIBE):		

- (1) The geometry of the structure (permitted footprint and CCR grades) has not changed since the last inspection, with the exception of the additional placement of CCR in Cells A & B.
- (2) CCR approximate volume: Cells A & B (by survey dated 12/13/2022; operated as one cell) – 756,895 yd³; Cell E (by survey dated 11/5/2019) – 738,413 yd³.



 Gary H. McWhorter, P.E.
 GA. Reg. #PE012687
 1/17/23