



**PERIODIC SAFETY FACTOR ASSESSMENT**  
**391-3-4-.10(4) AND 40 C.F.R. PART 257.73(e)**  
**PLANT MCDONOUGH ASH POND 3 (AP-3) AND ASH POND 4 (AP-4)**  
**GEORGIA POWER COMPANY**

The Federal CCR Rule and the Georgia CCR Rule (391-3-4-.10) require the owner or operator of a CCR surface impoundment to conduct initial and periodic safety factor assessments. See 40 C.F.R. § 257.73(e); Ga. Comp. R. & Regs. r. 391.3-4-.10(4)(b)<sup>1</sup>. A direct final rule revision to a partial vacatur of the Final Rule became effective on October 4, 2016. This revision eliminated the exemption for inactive CCR surface impoundments and required such units to meet the same requirements as existing CCR surface impoundments. The owner or operator of the CCR unit must conduct an assessment of the CCR unit and document whether the minimum safety factors outlined in 40 C.F.R. § 257.73(e)(1)(i) through (iv) for the critical cross section of the embankment are achieved. In addition, the Rules require a subsequent assessment be performed within 5 years of the previous assessment. See 40 C.F.R. § 257.73(f)(3); Ga. Comp. R. & Regs. r. 391.3-4-.10(4)(b) 1.

The CCR surface impoundments known as Ash Pond 3 (AP-3) and Ash Pond 4 (AP-4), owned, and operated by Georgia Power Company, are located at Plant McDonough-Atkinson (Plant McDonough) in Cobb County, Georgia. These units no longer receive CCR or other waste streams and no longer function as a CCR surface impoundment. At the time of this submittal, AP-3 and AP-4 are being consolidated and closed in place as combined unit AP-3/4 in accordance with §257.102(d) and are in the process of obtaining a solid waste permit under the Georgia Rules for Solid Waste Management, 391-3-4-.10.

The interim (November 2022) construction condition of AP-3 and AP-4 was analyzed for this periodic assessment. According to section § 257.73(e) of the rule, stability of earth structures must be assessed under four loading conditions:

- Maximum Pool Storage (40 C.F.R. § 257.73(e)(i))
- Maximum Pool Surcharge (40 C.F.R. § 257.73(e)(ii))
- Seismic Loading Conditions (40 C.F.R. § 257.73(e)(iii))
- Post-Seismic Liquefaction Conditions (when liquefaction susceptible materials are present; 40 C.F.R. § 257.73(e)(iv)) (not applicable for AP-3 and AP-4).

Engineering analysis of AP-3/4 in its current condition were evaluated for each loading condition. Stability safety factors were evaluated for each of the loading scenarios using the computer program SLIDE (2018). As required by the EPA rule, a general limit equilibrium (GLE) method (Morgenstern and Price) was used to calculate factors of safety, and the factors of safety were calculated by dividing the resisting forces by the driving forces along the calculated critical slip surface of a given slope.

Stability was evaluated along two cross-sections deemed the most critical for AP-3 and AP-4 as shown in Figure 1. Subsurface stratigraphy at each cross-section was developed from data collected during subsurface explorations from October 2015 to January 2016, and supplemental information collected through November 2022. Similarly, material properties were developed for the dam, foundation, and impounded materials from this

---

<sup>(1)</sup> In a typographical error, 391.3-4.10(4)(b) references the “structural integrity criteria in 40 CFR 247.73,” when the reference to such criteria should be 40 CFR 257.73.

data. The conditions modeled in stability analyses are reflective of the (November 2022) interim conditions for AP-3 and AP-4.

The 100-year 24-hour rain event was used for the maximum pool surcharge scenario.

For the surcharge pool scenario for this interim condition (November 2022), WSP considered the effects of the 100-year 24-hour rain event. For AP-3 and AP-4, the interim condition rain event will cause stormwater flow in a combination of lined channels and open working areas. Thus, the stability of AP-3 and AP-4 slopes were evaluated with applicable water levels to the calculated flow depths for the rain event. At the time of this demonstration, the majority of areas of AP-3 and AP-4 are covered with the ClosureTurf final cover system, and limited areas remains as open construction areas.

Factors of safety for stability under seismic loading conditions were calculated based on the earthquake hazard corresponding to a probability of exceedance of 2% in 50 years (2,475 year return period). The Bray and Travasarou displacement-based seismic slope stability screening method was used to evaluate the seismic stability. For this method, a pseudo-static coefficient corresponding to an allowable displacement of six inches (15 cm) is applied as a horizontal force in the static stability model. The pseudo-static coefficient for the above stated criteria was calculated to be 0.029g (g = standard gravity).

The CCR Rule specifies a required factor of safety of 1.2 against liquefaction for pond impoundment structures in 40 C.F.R. § 257.73(e)(iv). The dam and foundation soils at the location of the AP-3 and AP-4 analysis sections were evaluated for liquefaction susceptibility and were found to have calculated factors of safety against liquefaction above 1.2. Since no liquefaction susceptible materials are present, the post-liquefaction analysis is not applicable for AP-3/4. The table below summarizes the results of the slope stability analyses for the current conditions at AP-3 and AP-4, with figures displaying the stability analysis results attached to this demonstration.

For all cases analyzed, the calculated factors of safety are in excess of those required in Sections § 257.73(e)(i) to (iv) of the EPA Rule.

<b>Interim Condition Stability Analysis Results</b>				
<b>Analysis Case</b>	<b>Max. Storage Pool</b>	<b>Max. Surcharge Pool</b>	<b>Seismic</b>	<b>Post Liquefaction</b>
<b>Rule Section</b>	§ 257.73(e)(i)	§ 257.73(e)(ii)	§ 257.73(e)(iii)	§ 257.73(e)(iv)
<b>Target Factor of Safety</b>	1.5	1.4	1.0	1.2
<b>Cross-Sections</b>	<b>Factor of Safety</b>			
A-A' South-West	1.6	1.6	1.5	Not Applicable
A-A' East	2.1	2.1	1.3	
B-B' North	3.1	3.1	2.7	
B-B' South-East	1.8	1.8	1.6	



I certify that the safety factor assessment for AP-3 and AP-4 was conducted in accordance with 40 C.F.R. § 257.73(e).



---

Gregory L. Hebel, PhD, P.E.  
Georgia Licensed Professional Engineer No. 034749  
**WSP USA Inc.**

# Stability Analysis Figures for AP-3 and AP-4



**LEGEND**

	EXISTING CONTOURS (MARCH 2018)
	PROPERTY BOUNDARY MARKERS/LIMITS
	FINAL CLOSURE CONTOURS (SEE NOTE 2)
	CLOSURE CONTOURS OUTSIDE LIMITS OF CCR
	EXISTING OVERHEAD ELECTRIC LINES IN CCR POND 2, 3, & 4 AREA TO REMAIN & TO BE PROTECTED
	APPROXIMATE PRE-CLOSURE CCR LIMITS (SEE NOTE 4)
	EXISTING GAS LINE
	PROPOSED PERMIT BOUNDARY AP-2, AP-3/4
	FINAL LIMITS OF LINER
	POST-CLOSURE CCR LIMITS

**REFERENCES**


1. THE EXISTING TOPOGRAPHY AND CONTOUR ELEVATIONS WERE PROVIDED BY GEORGIA LAND DEPARTMENT AND METRO ENGINEERING AND SURVEYING CO. INC. THE DATE OF THE SURVEY PROVIDED AND SHOWN ON THIS SET OF PLANS IS 03-18-2018. REFER TO THE SURVEY DRAWING TITLED "TOPOGRAPHIC MAP PREPARED FOR GEORGIA POWER COMPANY PLANT MCDONOUGH - GEORGIA STATE PLANE WEST SURVEY FEET - DATE OF PHOTOGRAPHY 03-18-2018.

- NOTES**
1. FINAL CLOSURE CONTOURS (PURPLE) DELINEATE FINAL LIMITS OF CCR.
  2. CLOSURE CONTOURS OUTSIDE LIMITS OF CCR (GREEN) DELINEATE AREAS WHERE ANY EXISTING ASH IS TO BE COMPLETELY REMOVED.
  3. PERMANENT MARKERS FOR EACH CCR UNIT WERE INSTALLED AT PLANT MCDONOUGH ON JULY 31, 2015.
  4. CCR DELINEATION IS ONGOING THROUGHOUT CONSTRUCTION AND WILL CONTINUE UNTIL THE COMPLETION OF CLOSURE CERTIFICATION. ALL CCR WITHIN THE CLOSURE PERMIT BOUNDARY TO BE EITHER EXCAVATED OR PLACED WITHIN THE FINAL COVER LIMITS.

**FOR PERMITTING PURPOSES  
NOT FOR CONSTRUCTION**




CLIENT  
**GEORGIA POWER COMPANY**



PROJECT  
**PLANT MCDONOUGH - ATKINSON  
ASH POND 3 AND ASH POND 4 (AP-3/4) CLOSURE  
& ASH POND 2 (AP-2) CLOSURE**

TITLE  
**STABILITY ANALYSIS  
PERMIT BOUNDARY AP-2, & AP-3/4  
SITE PLAN**

CONSULTANT	YYYY-MMM	2023 - FEB
	DESIGNED	GLH
	PREPARED	CRP
	CHECKED	LS
	REVIEWED / APPROVED	GLH



PROJECT NO.  
1777449



REV.  
0

SHEET  
SA-1

Path: \\atlantia\cadd\Southern Company\1777449 Plant McDonough\Permitting\AP-3&4-AP-2&AP-3&4\Stability Analysis\2023\_0221\_1 File Name: 1777449-05-PROPOSED COMPLIANCE BNDY\_SA\_2023\_0227.dwg

IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM ANS/D

Path: \\atlantafacstaff\Southern Company\1777449\04-17 SITE SECTIONS\_SA-2023\_0221.dwg | File Name: 1777449-04-17 SITE SECTIONS\_SA-2023\_0221.dwg



**LEGEND**

	ASH TO REMAIN		PROPOSED ASH FILL
	EXISTING EMBANKMENT FILL		PROPOSED SOIL FILL
	CCR / SOIL TO BE REMOVED		

- NOTES**
- EXISTING CCR TO BE REMOVED FROM OVER AND AROUND EXISTING PIPE AND SOIL FILL TO BE PLACED BACK OVER PIPE.
  - MAINTAIN 50 FOOT BUFFER BETWEEN FINAL TOE OF CCR AND EXISTING EDGE OF CULVERT.
  - ESTIMATED BOTTOM OF CCR LIMITS ARE APPROXIMATE.

**REFERENCES**

- THE PRE-CLOSURE TOPOGRAPHY AND CONTOUR ELEVATIONS WERE PROVIDED BY GEORGIA LAND DEPARTMENT AND METRO ENGINEERING AND SURVEYING CO., INC. THE DATE OF THE SURVEY PROVIDED AND SHOWN ON THIS SET OF PLANS IS 10-16-2012. REFER TO THE SURVEY DRAWING TITLED "TOPOGRAPHIC MAP PREPARED FOR GEORGIA POWER COMPANY PLANT MCDONOUGH - GEORGIA STATE PLANE WEST SURVEY FEET - DATE OF PHOTOGRAPHY 10-26-12. PROJECT NO. 13225 - 01-13-2013."
- REVISED PRE-CLOSURE TOPOGRAPHY & CONTOUR ELEVATIONS WERE PROVIDED BY GEORGIA POWER LAND DEPARTMENT. THE DATA SHOWN IS AN UPDATE TO THE PLANS DONE ON 10-16-2012 & THE ONSITE CHANGES SINCE THAT 2012 SURVEY. THE REVISED SURVEY WAS DONE ON 1-12-2016 & MERGED WITH THE DATA ON 10-16-2012. GEORGIA POWER COMPANY PLANT MCDONOUGH ASH PONDS - GEORGIA STATE PLANE WEST SURVEY FEET - DATE OF SURVEY 1-12-2016.

**FOR PERMITTING PURPOSES  
NOT FOR CONSTRUCTION**

CLIENT  
GEORGIA POWER COMPANY



PROJECT  
PLANT MCDONOUGH - ATKINSON  
ASH POND 3 AND ASH POND 4 (AP-3/4) CLOSURE  
& ASH POND 2 (AP-2) CLOSURE

TITLE  
**STABILITY ANALYSIS  
PERMIT BOUNDARY AP-2, & AP-3/4 - SECTION A - A'**


CONSULTANT	YYYY-MMM	2023-FEB
	DESIGNED	GLH
	PREPARED	CRP
	CHECKED	LS
	REVIEWED / APPROVED	GLH

PROJECT NO.  
1777449

REV.  
0


SHEET  
SA-2

1 in IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM: ANSI D



**LEGEND**

- ASH TO REMAIN
- PROPOSED ASH FILL
- EXISTING EMBANKMENT FILL
- PROPOSED SOIL FILL
- CCR / SOIL TO BE REMOVED



**NOTES**

1. EXISTING CCR TO BE REMOVED FROM OVER AND AROUND EXISTING PIPE AND SOIL FILL TO BE PLACED BACK OVER PIPE.
2. MAINTAIN 50 FOOT BUFFER BETWEEN FINAL TOE OF CCR AND EXISTING EDGE OF CULVERT.
3. ESTIMATED BOTTOM OF CCR LIMITS ARE APPROXIMATE.

**REFERENCES**

1. THE PRE-CLOSURE TOPOGRAPHY AND CONTOUR ELEVATIONS WERE PROVIDED BY GEORGIA LAND DEPARTMENT AND METRO ENGINEERING AND SURVEYING CO., INC. THE DATE OF THE SURVEY PROVIDED AND SHOWN ON THIS SET OF PLANS IS 10-16-2012. REFER TO THE SURVEY DRAWING TITLED "TOPOGRAPHIC MAP PREPARED FOR GEORGIA POWER COMPANY PLANT MCDONOUGH - GEORGIA STATE PLANE WEST SURVEY FEET - DATE OF PHOTOGRAPHY 10-26-12. PROJECT NO. 13225 - 01-13-2013."
2. REVISED PRE-CLOSURE TOPOGRAPHY & CONTOUR ELEVATIONS WERE PROVIDED BY GEORGIA POWER LAND DEPARTMENT. THE DATA SHOWN IS AN UPDATE TO THE PLANS DONE ON 10-16-2012 & THE ONSITE CHANGES SINCE THAT 2012 SURVEY. THE REVISED SURVEY WAS DONE ON 1-12-2016 & MERGED WITH THE DATA ON 10-16-2012. GEORGIA POWER COMPANY PLANT MCDONOUGH ASH PONDS - GEORGIA STATE PLANE WEST SURVEY FEET - DATE OF SURVEY 1-12-2016.

**FOR PERMITTING PURPOSES  
NOT FOR CONSTRUCTION**

CLIENT  
**GEORGIA POWER COMPANY**





PROJECT  
**PLANT MCDONOUGH - ATKINSON  
ASH POND 3 AND ASH POND 4 (AP-3/4) CLOSURE  
& ASH POND 2 (AP-2) CLOSURE**

TITLE  
**STABILITY ANALYSIS  
PERMIT BOUNDARY AP-2, & AP-3/4 - SECTION B - B'**

CONSULTANT	YYYY-MMM	2023-FEB
	DESIGNED	GLH
	PREPARED	CRP
	CHECKED	LS
	REVIEWED / APPROVED	GLH

PROJECT NO. 1777449      REV. 0      SHEET SA-3



**LEGEND**

- EXISTING CONTOURS (MARCH 2018)
- PROPERTY BOUNDARY MARKERS/LIMITS
- 810 FINAL CLOSURE CONTOURS (SEE NOTE 2)
- 810 CLOSURE CONTOURS OUTSIDE LIMITS OF CCR
- EXISTING OVERHEAD ELECTRIC LINES IN CCR POND 2, 3, & 4 AREA TO REMAIN & TO BE PROTECTED
- APPROXIMATE PRE-CLOSURE CCR LIMITS (SEE NOTE 4)
- EXISTING GAS LINE
- PROPOSED PERMIT BOUNDARY AP-2, AP-3/4
- FINAL LIMITS OF LINER
- POST-CLOSURE CCR LIMITS

**REFERENCES**

1. THE EXISTING TOPOGRAPHY AND CONTOUR ELEVATIONS WERE PROVIDED BY GEORGIA LAND DEPARTMENT AND METRO ENGINEERING AND SURVEYING CO. INC. THE DATE OF THE SURVEY PROVIDED AND SHOWN ON THIS SET OF PLANS IS 03-18-2018. REFER TO THE SURVEY DRAWING TITLED "TOPOGRAPHIC MAP PREPARED FOR GEORGIA POWER COMPANY PLANT MCDONOUGH - GEORGIA STATE PLANE WEST SURVEY FEET - DATE OF PHOTOGRAPHY 03-18-2018.

**NOTES**

1. FINAL CLOSURE CONTOURS (PURPLE) DELINEATE FINAL LIMITS OF CCR.
2. CLOSURE CONTOURS OUTSIDE LIMITS OF CCR (GREEN) DELINEATE AREAS WHERE ANY EXISTING ASH IS TO BE COMPLETELY REMOVED.
3. PERMANENT MARKERS FOR EACH CCR UNIT WERE INSTALLED AT PLANT MCDONOUGH ON JULY 31, 2015.
4. CCR DELINEATION IS ONGOING THROUGHOUT CONSTRUCTION AND WILL CONTINUE UNTIL THE COMPLETION OF CLOSURE CERTIFICATION. ALL CCR WITHIN THE CLOSURE PERMIT BOUNDARY TO BE EITHER EXCAVATED OR PLACED WITHIN THE FINAL COVER LIMITS.

**FOR PERMITTING PURPOSES  
NOT FOR CONSTRUCTION**




CLIENT  
**GEORGIA POWER COMPANY**



PROJECT  
**PLANT MCDONOUGH - ATKINSON  
ASH POND 3 AND ASH POND 4 (AP-3/4) CLOSURE  
& ASH POND 2 (AP-2) CLOSURE**

TITLE  
**STABILITY ANALYSIS  
PERMIT BOUNDARY AP-2, & AP-3/4  
SITE PLAN**

CONSULTANT	YYYY-MMM	2023 - FEB
	DESIGNED	GLH
	PREPARED	CRP
	CHECKED	LS
	REVIEWED / APPROVED	GLH





Path: \\atlantia\cadd\Southern Company\1777449 Plant McDonough\Permitting\AP-3&4-AP-2\AP-3&4-Stability Analysis\2023\_02\21\_1 File Name: 1777449-05-PROPOSED COMPLIANCE BNDY\_SA\_2023\_0227.dwg


IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM ANS/D





Material Name	Color	Unit Weight (lbs/ft3)	Strength Type	Cohesion (psf)	Phi (deg)	Cohesion Type	Water Surface	Hu Type	Hu	Phi b (deg)	Air Entry (psf)
Stacked / Compacted CCR		110	Mohr-Coulomb	0	30		Water Surface	Custom	1	0	0
Saturated Sluiced Ash		90	Mohr-Coulomb	0	24		Water Surface	Custom	1	0	0
Fill		125	Mohr-Coulomb	100	30		Water Surface	Custom	1	0	0
Upper Residuuum		125	Mohr-Coulomb	50	30		Water Surface	Custom	1	0	0
Lower Residuuum		125	Mohr-Coulomb	100	30		Water Surface	Custom	1	0	0
PWR		140	Undrained	10000		Constant	Water Surface	Custom	0	0	0










	SCALE	AS SHOWN	PROJECT	<b>State CCR Permitting Services - MCD Pond 3&amp;4</b>				
	DATE	Mar 2023						
	MADE BY	HJ	TITLE	<b>Section A-A' South-West - Static</b>				
	CAD	-						
FILE	Stability Analysis		CHECK	GLH	CLIENT	<b>Georgia Power Company</b>	FIGURE	<b>1</b>
PROJECT No.	GL1777449-02	REV.	0	REVIEW				


Material Name	Color	Unit Weight (lbs/ft3)	Strength Type	Cohesion (psf)	Phi (deg)	Cohesion Type	Water Surface	Hu Type	Hu	Phi b (deg)	Air Entry (psf)
Stacked / Compacted CCR		110	Mohr-Coulomb	0	30		Water Surface	Custom	1	0	0
Saturated Sluiced Ash		90	Mohr-Coulomb	0	24		Water Surface	Custom	1	0	0
Fill		125	Mohr-Coulomb	100	30		Water Surface	Custom	1	0	0
Upper Residuuum		125	Mohr-Coulomb	50	30		Water Surface	Custom	1	0	0
Lower Residuuum		125	Mohr-Coulomb	100	30		Water Surface	Custom	1	0	0
PWR		140	Undrained	10000		Constant	Water Surface	Custom	0	0	0




	SCALE	AS SHOWN	PROJECT	<b>State CCR Permitting Services - MCD Pond 3&amp;4</b>					
	DATE	Mar 2023							
	MADE BY	HJ	TITLE	<b>Section A-A' South-West - Maximum Pool</b>					
	CAD	-							
FILE	Stability Analysis		CHECK	GLH	CLIENT	<b>Georgia Power Company</b>		FIGURE	<b>2</b>
PROJECT No.	GL1777449-02	REV.	0	REVIEW					


Material Name	Color	Unit Weight (lbs/ft3)	Strength Type	Cohesion (psf)	Cohesion Type	Shear Normal Function	Water Surface	Hu Type	Hu	Phi b (deg)	Air Entry (psf)
PWR		140	Undrained	10000	Constant		Water Surface	Custom	0	0	0
Stacked Ash Undrained		110	Shear Normal function			Compacted Ash	Water Surface	Custom	1	0	0
Sluiced Ash Undrained		90	Shear Normal function			Sluiced Ash	Water Surface	Custom	1	0	0
Dike Fill Soil Undrained		125	Shear Normal function			Fill	Water Surface	Custom	1	0	0
Lower Residuuum Soil Undrained		125	Shear Normal function			Lower Residuuum	Water Surface	Custom	1	0	0
Upper Residuuum Soil Undrained		125	Shear Normal function			Upper Residuuum	Water Surface	Custom	1	0	0




	SCALE	AS SHOWN	PROJECT	State CCR Permitting Services - MCD Pond 3&4		
	DATE	Mar 2023				
	MADE BY	HJ	TITLE	Section A-A' South-West - Seismic		
	CAD	-				
FILE	Stability Analysis		CLIENT	Georgia Power Company		FIGURE 3
PROJECT No.	GL1777449-02	REV.	0			
				REVIEW	GLH	


Material Name	Color	Unit Weight (lbs/ft3)	Strength Type	Cohesion (psf)	Phi (deg)	Cohesion Type	Water Surface	Hu Type	Hu	Phi b (deg)	Air Entry (psf)
Stacked / Compacted CCR	Light Gray	110	Mohr-Coulomb	0	30		Water Surface	Custom	1	0	0
Saturated Sluiced Ash	Dark Gray	90	Mohr-Coulomb	0	24		Water Surface	Custom	1	0	0
Fill	Yellow	125	Mohr-Coulomb	100	30		Water Surface	Custom	1	0	0
Upper Residuum	Orange	125	Mohr-Coulomb	50	30		Water Surface	Custom	1	0	0
Lower Residuum	Red	125	Mohr-Coulomb	100	30		Water Surface	Custom	1	0	0
PWR	Tan	140	Undrained	10000		Constant	Water Surface	Custom	0	0	0










	SCALE	AS SHOWN	PROJECT	<b>State CCR Permitting Services - MCD Pond 3&amp;4</b>			
	DATE	Mar 2023					
	MADE BY	HJ	TITLE	<b>Section A-A' East - Static</b>			
	CAD	-					
FILE	Stability Analysis		CLIENT	<b>Georgia Power Company</b>		FIGURE	<b>4</b>
PROJECT No.	GL1777449-02	REV.					


Material Name	Color	Unit Weight (lbs/ft3)	Strength Type	Cohesion (psf)	Phi (deg)	Cohesion Type	Water Surface	Hu Type	Hu	Phi b (deg)	Air Entry (psf)
Stacked / Compacted CCR		110	Mohr-Coulomb	0	30		Water Surface	Custom	1	0	0
Saturated Sluiced Ash		90	Mohr-Coulomb	0	24		Water Surface	Custom	1	0	0
Fill		125	Mohr-Coulomb	100	30		Water Surface	Custom	1	0	0
Upper Residuuum		125	Mohr-Coulomb	50	30		Water Surface	Custom	1	0	0
Lower Residuuum		125	Mohr-Coulomb	100	30		Water Surface	Custom	1	0	0
PWR		140	Undrained	10000		Constant	Water Surface	Custom	0	0	0








	SCALE	AS SHOWN	PROJECT	<b>State CCR Permitting Services - MCD Pond 3&amp;4</b>			
	DATE	Mar 2023					
	MADE BY	HJ	TITLE	<b>Section A-A' East - Maximum Pool</b>			
	CAD	-					
FILE	Stability Analysis		CLIENT	<b>Georgia Power Company</b>		FIGURE	<b>5</b>
PROJECT No.	GL1777449-02	REV.	0				


Material Name	Color	Unit Weight (lbs/ft <sup>3</sup> )	Strength Type	Cohesion (psf)	Cohesion Type	Shear Normal Function	Water Surface	Hu Type	Hu	Phi b (deg)	Air Entry (psf)
PWR		140	Undrained	10000	Constant		Water Surface	Custom	0	0	0
Stacked Ash Undrained		110	Shear Normal function			Compacted Ash	Water Surface	Custom	1	0	0
Sluiced Ash Undrained		90	Shear Normal function			Sluiced Ash	Water Surface	Custom	1	0	0
Dike Fill Soil Undrained		125	Shear Normal function			Fill	Water Surface	Custom	1	0	0
Lower Residuum Soil Undrained		125	Shear Normal function			Lower Residuum	Water Surface	Custom	1	0	0
Upper Residuum Soil Undrained		125	Shear Normal function			Upper Residuum	Water Surface	Custom	1	0	0








	SCALE	AS SHOWN	PROJECT	<b>State CCR Permitting Services - MCD Pond 3&amp;4</b>				
	DATE	Mar 2023						
	MADE BY	HJ	TITLE	<b>Section A-A' East - Seismic</b>				
	CAD	-						
FILE	Stability Analysis		CHECK	GLH	CLIENT	<b>Georgia Power Company</b>	FIGURE	<b>6</b>
PROJECT No.	GL1777449-02	REV.	0	REVIEW				


Material Name	Color	Unit Weight (lbs/ft <sup>3</sup> )	Strength Type	Cohesion (psf)	Phi (deg)	Cohesion Type	Water Surface	Hu Type	Hu
Stacked / Compacted CCR		110	Mohr-Coulomb	0	30		Water Surface	Custom	1
Fill		125	Mohr-Coulomb	100	30		Water Surface	Custom	1
Lower Residuuum		125	Mohr-Coulomb	100	30		Water Surface	Custom	1
PWR		140	Undrained	10000		Constant	Water Surface	Custom	0






	SCALE	AS SHOWN	PROJECT	<b>State CCR Permitting Services - MCD Pond 3&amp;4</b>			
	DATE	Mar 2023					
	MADE BY	HJ	TITLE	<b>Section B-B' North - Static</b>			
	CAD	-					
FILE	Stability Analysis		CLIENT	<b>Georgia Power Company</b>			
PROJECT No.	GL1777449-02	REV.				0	CHECK
				REVIEW	GLH	FIGURE	<b>7</b>


Material Name	Color	Unit Weight (lbs/ft <sup>3</sup> )	Strength Type	Cohesion (psf)	Phi (deg)	Cohesion Type	Water Surface	Hu Type	Hu
Stacked / Compacted CCR		110	Mohr-Coulomb	0	30		Water Surface	Custom	1
Fill		125	Mohr-Coulomb	100	30		Water Surface	Custom	1
Lower Residuuum		125	Mohr-Coulomb	100	30		Water Surface	Custom	1
PWR		140	Undrained	10000		Constant	Water Surface	Custom	0






	SCALE	AS SHOWN	PROJECT	<b>State CCR Permitting Services - MCD Pond 3&amp;4</b>			
	DATE	Mar 2023					
	MADE BY	HJ	TITLE	<b>Section B-B' North - Maximum Pool</b>			
	CAD	-					
FILE	Stability Analysis		CLIENT	<b>Georgia Power Company</b>		FIGURE	<b>8</b>
PROJECT No.	GL1777449-02	REV.	0				
				REVIEW	GLH		





Material Name	Color	Unit Weight (lbs/ft <sup>3</sup> )	Strength Type	Cohesion (psf)	Cohesion Type	Shear Normal Function	Water Surface	Hu Type	Hu
PWR		140	Undrained	10000	Constant		Water Surface	Custom	0
Dike Fill Soil Undrained		125	Shear Normal function			Fill	Water Surface	Custom	1
Lower Residuuum Soil Undrained		125	Shear Normal function			Lower Residuuum	Water Surface	Custom	1






	SCALE	AS SHOWN	PROJECT	State CCR Permitting Services - MCD Pond 3&4			
	DATE	Mar 2023					
	MADE BY	HJ	TITLE	Section B-B' North - Seismic			
	CAD	-					
FILE	Stability Analysis		CLIENT	Georgia Power Company			
PROJECT No.	GL1777449-02	REV.	0			CHECK	GLH
				REVIEW	GLH	FIGURE	9


Material Name	Color	Unit Weight (lbs/ft <sup>3</sup> )	Strength Type	Cohesion (psf)	Phi (deg)	Cohesion Type	Water Surface	Hu Type	Hu
Stacked / Compacted CCR		110	Mohr-Coulomb	0	30		Water Surface	Custom	1
			Mohr-				Water		






	SCALE	AS SHOWN	PROJECT	State CCR Permitting Services - MCD Pond 3&4		
	DATE	Mar 2023		TITLE	Section B-B' South-East - Static	
	MADE BY	HJ	CLIENT		Georgia Power Company	
	CAD	-				
FILE	Stability Analysis		CHECK	GLH		
PROJECT No.	GL1777449-02	REV.	0	REVIEW	GLH	


Material Name	Color	Unit Weight (lbs/ft <sup>3</sup> )	Strength Type	Cohesion (psf)	Phi (deg)	Cohesion Type	Water Surface	Hu Type	Hu
Stacked / Compacted CCR		110	Mohr-Coulomb	0	30		Water Surface	Custom	1
			Mohr-				Water		



	SCALE	AS SHOWN	PROJECT	State CCR Permitting Services - MCD Pond 3&4			
	DATE	Mar 2023					
	MADE BY	HJ	TITLE	Section B-B' South-East - Maximum Pool			
	CAD	-					
FILE	Stability Analysis		CLIENT	Georgia Power Company			
PROJECT No.	GL1777449-02	REV.	0			CHECK	GLH
				REVIEW	GLH	FIGURE	11

Material Name	Color	Unit Weight (lbs/ft <sup>3</sup> )	Strength Type	Cohesion (psf)	Cohesion Type	Shear Normal Function	Water Surface	Hu Type	Hu
PWR		140	Undrained	10000	Constant		Water Surface	Custom	0
Dike Fill Soil		125	Shear Normal			Fill	Water	Custom	1



	SCALE	AS SHOWN	PROJECT	State CCR Permitting Services - MCD Pond 3&4			
	DATE	Mar 2023					
	MADE BY	HJ	TITLE	Section B-B' South-East - Seismic			
	CAD	-					
FILE	Stability Analysis		CLIENT	Georgia Power Company			
PROJECT No.	GL1777449-02	REV.				0	CHECK
				REVIEW	GLH	FIGURE	12