



1150 Northmeadow Pkwy.
Suite 100
Roswell, GA 30076
(770) 594-5998
www.atlcc.net

GROUNDWATER EXCEEDANCE NOTIFICATION
40 C.F.R. PART 257.95(g)
PLANT MCINTOSH ASH POND (AP-1)
GEORGIA POWER COMPANY

Consistent with the previous semiannual monitoring event, the following Appendix IV constituent(s) were detected at statistically significant levels above groundwater protection standards established pursuant to the “Disposal of Coal Combustion Residuals from Electric Utilities” Final Rule, 40 C.F.R. 257.95(h) and Georgia EPD Rules for Solid Waste Management 391-3-4-.10(6)(a).


Federal CCR Rule

- Cobalt
- Lithium

State of Georgia CCR Rule

- Cobalt
- Lithium

Per 40 C.F.R. 257.95 (g)(3)(ii) an alternate source demonstration was prepared to address the statistically significant level of lithium. Georgia Power will continue groundwater monitoring and reporting activities as required by 40 C.F.R. 257.95.



Evan B. Perry, P.G.
Senior Project Manager

August 7, 2020

Date