


| | | | |
|---------------------------|---|--------------------------------|------------------------------|
| 257.83 (b) (2) | REPORT OF ANNUAL INSPECTION OF CCR SURFACE IMPOUNDMENT | | |
| | FACILITY NAME: Plant McIntosh AP-1, Cell A | | |
| | OWNER/OPERATOR OF FACILITY: Georgia Power Company | | |
| | INSPECTION DATE: December 9, 2021 | | |
| | INSPECTING ENGINEER: Patrick B. Rhodes, P.E. (Georgia P.E. License #24586) | | |
| (i) | ANY CHANGES IN GEOMETRY OF THE IMPOUNDING STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION? | No | |
| | (IF YES, DESCRIBE): | | |
| (ii) | LOCATION AND TYPE OF EXISTING INSTRUMENTATION | See Attached Table | |
| (ii) | MAXIMUM RECORDED READING OF EACH INSTRUMENT SINCE PREVIOUS ANNUAL INSPECTION. | See Attached Table | |
| (iii) | APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF THE IMPOUNDED WATER SINCE PREVIOUS ANNUAL INSPECTION (ft) | | |
| | MIN. DEPTH: 0 | MAX. DEPTH: 0 | PRESENT DEPTH: 0 |
| | MIN. ELEVATION: NA | MAX. ELEVATION: NA | PRESENT. ELEVATION: NA |
| (iii) | APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF CCR SINCE PREVIOUS ANNUAL INSPECTION. (ft) | | |
| | MIN. DEPTH: 0 | MAX. DEPTH: 0 | PRESENT DEPTH: 0 |
| | MIN. ELEVATION: NA | MAX. ELEVATION: NA | PRESENT ELEVATION: NA |
| (iv) | APPROXIMATE STORAGE CAPACITY OF IMPOUNDING STRUCTURE AT TIME OF INSPECTION. (cy) | <185,500 ^(1,3) | |
| (v) | APPROXIMATE VOLUME OF IMPOUNDED WATER AND CCR AT TIME OF INSPECTION. (cy) | WATER: 0 ⁽²⁾ | CCR: 0 ⁽²⁾ |
| (vi) | ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT AND APPURTENANT STRUCTURES? | No | |
| | (IF YES, DESCRIBE): | | |
| (vii) | ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION SINCE THE PREVIOUS ANNUAL INSPECTION? | No | |
| | (IF YES, DESCRIBE): | | |

(1) Cubic yard estimates are derived by qualified personnel from available generating data, maintenance records and other available information.

(2) The ash pond is in the process of closure construction. Cell A has been dewatered and ash has been removed.

(3) Plant McIntosh no longer burns coal, thus no longer generates nor disposes of CCR in this area. Impounding embankments are being lowered/removed as part of closure construction and actual storage volume is less than the original operational condition.




| | | | |
|---------------------------|---|---------------------------------------|------------------------------|
| 257.83 (b) (2) | REPORT OF ANNUAL INSPECTION OF CCR SURFACE IMPOUNDMENT | | |
| | FACILITY NAME: Plant McIntosh AP-1, Cell B | | |
| | OWNER/OPERATOR OF FACILITY: Georgia Power Company | | |
| | INSPECTION DATE: December 9, 2021 | | |
| | INSPECTING ENGINEER: Patrick B. Rhodes, P.E. (Georgia P.E. License #24586) | | |
| (i) | ANY CHANGES IN GEOMETRY OF THE IMPOUNDING STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION? | No | |
| | (IF YES, DESCRIBE): | | |
| (ii) | LOCATION AND TYPE OF EXISTING INSTRUMENTATION | See Attached Table | |
| (ii) | MAXIMUM RECORDED READING OF EACH INSTRUMENT SINCE PREVIOUS ANNUAL INSPECTION. | See Attached Table | |
| (iii) | APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF THE IMPOUNDED WATER SINCE PREVIOUS ANNUAL INSPECTION (ft) | | |
| | MIN. DEPTH: 0 | MAX. DEPTH: 0 | PRESENT DEPTH: 0 |
| | MIN. ELEVATION: NA | MAX. ELEVATION: NA | PRESENT. ELEVATION: NA |
| (iii) | APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF CCR SINCE PREVIOUS ANNUAL INSPECTION. (ft) | | |
| | MIN. DEPTH: Varies ⁽²⁾ | MAX. DEPTH: Varies ⁽²⁾ | PRESENT DEPTH: 0 |
| | MIN. ELEVATION: Varies ⁽²⁾ | MAX. ELEVATION: Varies ⁽²⁾ | PRESENT ELEVATION: NA |
| (iv) | APPROXIMATE STORAGE CAPACITY OF IMPOUNDING STRUCTURE AT TIME OF INSPECTION. (cy) | <174,200 ^(1,3) | |
| (v) | APPROXIMATE VOLUME OF IMPOUNDED WATER AND CCR AT TIME OF INSPECTION (cy) | WATER: 0 ⁽²⁾ | CCR: 0 ⁽²⁾ |
| (vi) | ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT AND APPURTENANT STRUCTURES? | No | |
| | (IF YES, DESCRIBE): | | |
| (vii) | ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION SINCE THE PREVIOUS ANNUAL INSPECTION? | No | |
| | (IF YES, DESCRIBE): | | |

(1) Cubic yard estimates are derived by qualified personnel from available generating data, maintenance records and other available information.

(2) The ash pond is in the process of closure construction. Cell B has been dewatered and all ash has been removed as of the date of the inspection. Cell B was previously used as a temporary staging area during final phases of closure construction to spread and dry ash being excavated from Cell D.

(3) Plant McIntosh no longer burns coal, thus no longer generates nor disposes of CCR_in this area Impounding embankments are being lowered/removed as part of closure_construction and actual storage volume is less than the original operational condition.




| | | | |
|---------------------------|---|--------------------------------|---------------------------------|
| 257.83 (b) (2) | REPORT OF ANNUAL INSPECTION OF CCR SURFACE IMPOUNDMENT | | |
| | FACILITY NAME: Plant McIntosh AP-1, Cell C | | |
| | OWNER/OPERATOR OF FACILITY: Georgia Power Company | | |
| | INSPECTION DATE: December 9, 2021 | | |
| | INSPECTING ENGINEER: Patrick B. Rhodes, P.E. (Georgia P.E. License #24586) | | |
| (i) | ANY CHANGES IN GEOMETRY OF THE IMPOUNDING STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION? | No | |
| | (IF YES, DESCRIBE): | | |
| (ii) | LOCATION AND TYPE OF EXISTING INSTRUMENTATION | See Attached Table | |
| (ii) | MAXIMUM RECORDED READING OF EACH INSTRUMENT SINCE PREVIOUS ANNUAL INSPECTION | See Attached Table | |
| (iii) | APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF THE IMPOUNDED WATER SINCE PREVIOUS ANNUAL INSPECTION (ft) | | |
| | MIN. DEPTH: 0 | MAX. DEPTH: 6 | PRESENT DEPTH: 0 |
| | MIN. ELEVATION: NA | MAX. ELEVATION: 45.5 | PRESENT. ELEVATION: NA |
| (iii) | APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF CCR SINCE PREVIOUS ANNUAL INSPECTION. (ft) | | |
| | MIN. DEPTH: 0 ⁽²⁾ | MAX. DEPTH: 0 ⁽²⁾ | PRESENT DEPTH: 0 ⁽²⁾ |
| | MIN. ELEVATION: N/A | MAX. ELEVATION: N/A | PRESENT ELEVATION: N/A |
| (iv) | APPROXIMATE STORAGE CAPACITY OF IMPOUNDING STRUCTURE AT TIME OF INSPECTION. (cy) | <158,100 ^(1,3) | |
| (v) | APPROXIMATE VOLUME OF IMPOUNDED WATER AND CCR AT TIME OF INSPECTION (cy) | WATER: 0 ⁽²⁾ | CCR: 0 ⁽²⁾ |
| (vi) | ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT AND APPURTENANT STRUCTURES? | No | |
| | (IF YES, DESCRIBE): | | |
| (vii) | ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION SINCE THE PREVIOUS ANNUAL INSPECTION? | No | |
| | (IF YES, DESCRIBE): | | |

(1) Cubic yard estimates are derived by qualified personnel from available generating data, maintenance records and other available information.

(2) The ash pond is in the process of closure construction. Cell C has been dewatered and ash has been removed.

(3) Plant McIntosh no longer burns coal, thus no longer generates nor disposes of CCR in this area. Impounding embankments are being lowered/removed as part of closure construction and actual storage volume is less than the original operational condition.




| | | | |
|---------------------------|---|--------------------------------|------------------------------|
| 257.83 (b) (2) | REPORT OF ANNUAL INSPECTION OF CCR SURFACE IMPOUNDMENT | | |
| | FACILITY NAME: Plant McIntosh AP-1, Cell D | | |
| | OWNER/OPERATOR OF FACILITY: Georgia Power Company | | |
| | INSPECTION DATE: December 9, 2021 | | |
| | INSPECTING ENGINEER: Patrick B. Rhodes, P.E. (Georgia P.E. License #24586) | | |
| (i) | ANY CHANGES IN GEOMETRY OF THE IMPOUNDING STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION? | No | |
| | (IF YES, DESCRIBE): | | |
| (ii) | LOCATION AND TYPE OF EXISTING INSTRUMENTATION | See Attached Table | |
| (ii) | MAXIMUM RECORDED READING OF EACH INSTRUMENT SINCE PREVIOUS ANNUAL INSPECTION. | See Attached Table | |
| (iii) | APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF THE IMPOUNDED WATER SINCE PREVIOUS ANNUAL INSPECTION. (ft) | | |
| | MIN. DEPTH: 0 | MAX. DEPTH: 1 | PRESENT DEPTH: 0 |
| | MIN. ELEVATION: NA | MAX. ELEVATION: 40 | PRESENT. ELEVATION: NA |
| (iii) | APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF CCR SINCE PREVIOUS ANNUAL INSPECTION. (ft) | | |
| | MIN. DEPTH: 9.5 | MAX. DEPTH: 10.5 | PRESENT DEPTH: up to 10.5 |
| | MIN. ELEVATION: 39 | MAX. ELEVATION: 40 | PRESENT ELEVATION: up to 40 |
| (iv) | APPROXIMATE STORAGE CAPACITY OF IMPOUNDING STRUCTURE AT TIME OF INSPECTION. (cy) | <31,924 ^(1,3) | |
| (v) | APPROXIMATE VOLUME OF IMPOUNDED WATER AND CCR AT TIME OF INSPECTION. (cy) | WATER: 0 ⁽²⁾ | CCR: 0 ⁽²⁾ |
| (vi) | ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT AND APPURTENANT STRUCTURES? | No | |
| | (IF YES, DESCRIBE): | | |
| (vii) | ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION SINCE THE PREVIOUS ANNUAL INSPECTION? | No | |
| | (IF YES, DESCRIBE): | | |

(1) Cubic yard estimates are derived by qualified personnel from available generating data, maintenance records and other available information.

(2) The ash pond is in the process of closure construction. Cell D has been dewatered and ash has been removed.

(3) Plant McIntosh no longer burns coal, thus no longer generates nor disposes of CCR in this area. Impounding embankments are being lowered/removed as part of closure construction and actual storage volume is less than the original operational condition.



**MAXIMUM RECORDED READINGS OF INSTRUMENTATION
PLANT MCINTOSH ASH POND**

PIEZOMETERS⁽¹⁾

| PIEZOMETER NUMBER | MAXIMUM RECORDED READING⁽¹⁾ | LOCATION⁽²⁾ |
|--------------------------|---|------------------------------------|
| M1 | Abandoned | 32° 21' 07.92" N, 81° 10' 07.13" W |
| M2 | Abandoned | 32° 21' 08.19" N, 81° 10' 17.72" W |
| M6 | Abandoned | 32° 21' 04.36" N, 81° 10' 10.90" W |
| M7 | Abandoned | 32° 21' 03.54" N, 81° 10' 10.34" W |

(1) Piezometers abandoned on December 1 & 2, 2020 as a part of closure construction and prior to 2020 inspection. No further readings were recorded since 2020 inspection.

(2) Locations estimated from aerial imaging.

TOE DRAIN SUMP FLOWS⁽¹⁾

| PUMP NUMBER | MAXIMUM MEASURED FLOW⁽¹⁾ | LOCATION⁽²⁾ |
|--------------------|--|------------------------------------|
| A SUMP | 1.2 gpm | 32° 21' 12.35" N, 81° 10' 11.75" W |
| C SUMP NORTH | <1 gpm | 32° 21' 03.42" N, 81° 10' 10.49" W |
| C SUMP SOUTH | <1 gpm | 32° 21' 00.63" N, 81° 10' 12.74" W |

(1) Toe drain flows collected in sumps and pumped back into ash pond.

(2) Readings elevated when taken after heavy rainfall. Sump A abandoned on February 25, 2021, and Sump C North & Sump C South abandoned on May 6, 2021 as a part of closure construction.

(3) Locations estimated from aerial imaging.