

**GROUNDWATER EXCEEDANCE NOTIFICATION 40 C.F.R. PART  
257.95(g) and GEORGIA EPD RULES FOR SOLID WASTE  
MANAGEMENT 391-3-4-.10(6)(a)**

**PLANT MCINTOSH ASH POND  
(AP-1)  
GEORGIA POWER COMPANY**

**Federal and State of Georgia CCR Rule**

The following Appendix IV constituent(s) were detected at statistically significant levels above the groundwater protection standards established pursuant to the "Disposal of Coal Combustion Residuals from Electric Utilities" Final Rule, 40 C.F.R. 257.95(h) and Georgia Environmental Protection Division Rules for Solid Waste Management 391-3-4-.10(6)(a).

- **Cobalt**
- **Lithium**

Per 40 C.F.R. 257.95 (g)(3)(ii) an alternate source demonstration was prepared to address the statistically significant levels of cobalt and lithium. Georgia Power will continue groundwater monitoring and reporting activities required by 40 C.F.R. 257.95.



July 31, 2023

Chad Hall, PhD, P.E.  
Georgia Professional Engineer