


257.84 (b)(2)	2023 REPORT OF ANNUAL INSPECTION OF CCR LANDFILL	
	CCR LANDFILL NAME: Plant McIntosh CCR Landfill 4 (Cells 1, 2A). Permit # 051-010D(CCR).	
	OWNER OF CCR LANDFILL: Georgia Power Company	
	INSPECTION DATE: November 14, 2023	
	INSPECTING ENGINEER: Gary H. McWhorter, P.E. GA Reg. #PE012687	
(i)	ANY CHANGES IN GEOMETRY OF THE STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION?	NO ⁽¹⁾
	(IF YES, DESCRIBE):	
(ii)	APPROXIMATE VOLUME OF CCR CONTAINED IN THE UNIT AT THE TIME OF INSPECTION?	558,973 yd³ ⁽²⁾
(iii)	ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT?	NO
	(IF YES, DESCRIBE):	
(iv)	ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION OF THE CCR UNIT SINCE THE PREVIOUS ANNUAL INSPECTION?	NO
	(IF YES, DESCRIBE):	

- (1) The geometry of the structure (permitted footprint and CCR grades) has not changed since the last inspection.
- (2) Approximate CCR volume: - Cell 1 – 361,231 yd³ (by Final Survey dated 2016); Cell 2A (by Final survey dated – October 19, 2021) – 197,742 yd³.



 Gary H. McWhorter, P.E.
 GA Reg. #PE012687
Gary H. McWhorter
 1/12/24