

**NOTIFICATION OF INTENT TO INITIATE CLOSURE
PLANT MCMANUS INACTIVE CCR SURFACE IMPOUNDMENT
GEORGIA POWER COMPANY
BRUNSWICK, GEORGIA**

Georgia Power Company (GPC) intends to close the inactive CCR surface impoundment known as AP-1 located at Plant McManus in Brunswick, Georgia under the requirements of 40 C.F.R. §257.100(b). The Plant McManus surface impoundment is an inactive CCR Surface Impoundment, as defined in 40 C.F.R. §257.53.

Closure of the surface impoundment will be conducted under 40 C.F.R. §257.100(b)(5), *Closure through removal of CCR*. The closure will be completed by removing all CCR and CCR laden soils in the inactive CCR Surface Impoundment. CCR removal activities will take place immediate to, and inside the current permitted impoundment boundary, with the exception of the transportation of the CCR to an off-site permitted landfill. Vegetation growing within the CCR will be cut and disposed with the CCR. Free liquids within the surface impoundment will be removed and treated if necessary to meet the facility's National Pollution Discharge Elimination System (NPDES) Permit requirements.

Tentative schedule for closure is as follows:

- | | |
|--|---------|
| • Award of Closure Construction Contract | Q4 2015 |
| • Contractor Mobilization | Q1 2016 |
| • Commence Removal of Free Liquids | Q1 2016 |
| • Commence CCR Removal | Q1 2016 |
| • Complete CCR Removal | Q1 2018 |
| • Certification of Closure | Q2 2018 |

By signature below, certification is made that:

- The closure of the Plant McManus surface impoundment will be completed by removal of all CCR, and CCR laden soils in the surface impoundment, in accordance with the requirements of 40 C.F.R. §257.100(b)(5) , and
- It is technically feasible to complete closure of the surface impoundment in accordance with 40 C.F.R. §257.100(b)(5), *Closure through removal of CCR*, by April 17, 2018.



Richard K. Lowe, P.E.,
Georgia Licensed Professional Engineer No. 040110



Date

