

**LOCATION RESTRICTION DEMONSTRATION
WETLANDS
(40 CFR 257.61)
PLANT MCMANUS ASH POND 1 (AP-1)
GEORGIA POWER COMPANY**

Plant McManus AP-1 is subject to the timelines announced in 81 Fed. Reg. 51802 (Aug. 5, 2016). EPA's "Disposal of Coal Combustion Residuals from Electric Utilities Final Rule" (40 CFR 257.61), requires that existing CCR surface impoundments must not be located in wetlands, as defined by 40 CFR 232.2, without special considerations and permitting.

A wetlands survey was conducted to evaluate the area of and in proximity to AP-1 for the presence of jurisdictional wetlands, open waters and streams. No jurisdictional wetlands or waters of the state were identified within the footprint of AP-1 as part of the wetland survey completed in October 2019. Therefore, Georgia Power's Plant McManus AP-1 is not located in a wetland as defined by 40 CFR Part 232.2. AP-1 is utilized as part of Plant McManus' National Pollutant Discharge Elimination System ("NPDES") wastewater treatment system.

I hereby certify that for Georgia Power's Plant McManus AP-1, the wetlands location restriction demonstration meets the requirement of 40 CFR 257.61(a).

11/26/19

J. Robin Blanton, P.E.

Date

Licensed State of Georgia, P.E. No. 19978

