257.83 (b) (2)	REPORT OF ANNU	JAL	INSPECTION OF C	CR SU	RFACI	E IMPOUI	NDMENT		
-	FACILITY NAME: Plant Yates – Ash Pond 3								
	OWNER/OPERATOR OF FACILITY: Georgia Power Company								
	INSPECTION DATE: November 16, 2016 INSPECTING ENGINEER: Patrick B. Rhodes, PE (GA 024586)								
(i)	ANY CHANGES IN GEOMETRY OF THE IMPOUNDING STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION?						NO		
	(IF YES, DESCRIBE):								
(ii)	LOCATION AND TYPE OF 1	EXIS	TING INSTRUMENTAT	TION SEE ATTACHED TABLE and PLAN					
(ii)	MAXIMUM RECORDED RI PREVIOUS ANNUAL INSPI		ADING OF EACH INSTRUMENT SINCE SEE ATTACHED TABLE						
(iii)	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF THE IMPOUNDED WATER SINCE PREVIOUS ANNUAL INSPECTION								
					NT DE	DEPTH: Up to 5 ft			
	MIN. ELEVATION: N/A	ı	AX. ELEVATION: 0.4	PRESENT. ELEVATION: 750.4 ft.					
(iii)	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF CCR SINCE PREVIOUS ANNUAL INSPECTION.								
	MIN. DEPTH: 0 ft MAX. DEPTH: 18.8 ft			PRESENT DEPTH: 18.8 ft.					
	MIN. ELEVATION: N/A		MAX. ELEVATION: 74	8.8 ft PRES		ENT ELEVATION: 748.8 ft.			
(iv)	APPROXIMATE STORAGE IMPOUNDING STRUCTUR INSPECTION.			1,000,000 yd <sup>3</sup>					
(v)	APPROXIMATE VOLUME AND CCR AT TIME OF INS			WATER: <20,000 yd <sup>3</sup> CCR: See Note 1 750,2		CCR: 750,200 yd <sup>3</sup>			
(vi)	ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT AND APPURTENANT STRUCTURES?								
	(IF YES, DESCRIBE):					<u> </u>			
(vii)	STABILITY OR OPERATION INSPECTION?	ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION SINCE THE PREVIOUS ANNUAL NSPECTION?							
	(IF YES, DESCRIBE):								
	(IF YES, DESCRIBE):								

Note 1: An accurate estimate of the stored volume in AP3 at the present time cannot be made due to ongoing closure activities. The impoundment no longer receives process water flows, and CCR is being relocated to AP-3 from other onsite ash pour closures.

<sup>-</sup> Cubic yard estimates are derived by qualified personnel from available information.

## LOCATION AND TYPE OF EXISTING INSTRUMENTATION YATES ASH POND 3

Instrument No.	Type of Instrument	Location of	Instrument	Maximum Reading Since
Instrument No.		Northing	Easting	Last Inspection
EP-1	Piezometer	1256501.06	2074989.17	EL 748
EP-2	Piezometer	1256505.95	2074993.04	EL 747
EP-3	Piezometer	1256695.48	2075039.36	EL 745
EP-4	Piezometer	1256704.31	2075043.75	EL 745
EP-5	Piezometer	1256979.79	2075116.41	EL 746
EP-6	Piezometer	1256985.02	2075118.90	EL 746