

<b>257.83 (b) (2)</b>	<b>REPORT OF ANNUAL INSPECTION OF CCR SURFACE IMPOUNDMENT</b>		
	FACILITY NAME: Plant Yates – Ash Pond B'		
	OWNER/OPERATOR OF FACILITY: Georgia Power Company		
	INSPECTION DATE: September 27, 2017		
	INSPECTING ENGINEER: Patrick B. Rhodes, PE (GA Reg. # PE024586)		
<b>(i)</b>	<b>ANY CHANGES IN GEOMETRY OF THE IMPOUNDING STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION?</b>		<b>NO</b>
	(IF YES, DESCRIBE): N/A		
<b>(ii)</b>	<b>LOCATION AND TYPE OF EXISTING INSTRUMENTATION</b>		<b>SEE ATTACHED TABLE</b>
<b>(ii)</b>	<b>MAXIMUM RECORDED READING OF EACH INSTRUMENT SINCE PREVIOUS ANNUAL INSPECTION</b>		<b>SEE ATTACHED TABLE</b>
<b>(iii)</b>	<b>APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF THE IMPOUNDED WATER SINCE PREVIOUS ANNUAL INSPECTION</b>		
	MIN. DEPTH: 0 ft.	MAX. DEPTH: 0 ft.	PRESENT DEPTH: 0 ft.
	MIN. ELEVATION: N/A	MAX. ELEVATION: N/A	PRESENT. ELEVATION: N/A
<b>(iii)</b>	<b>APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF CCR SINCE PREVIOUS ANNUAL INSPECTION.</b>		
	MIN. DEPTH: 0 ft.	MAX. DEPTH: 27 ft.	PRESENT DEPTH: 27 ft.
	MIN. ELEVATION: N/A	MAX. ELEVATION: 772 ft.	PRESENT ELEVATION: 772 ft.
<b>(iv) 1</b>	<b>APPROXIMATE STORAGE CAPACITY OF IMPOUNDING STRUCTURE AT TIME OF INSPECTION.</b>		<b>575,913 yd<sup>3</sup></b>
<b>(v)1</b>	<b>APPROXIMATE VOLUME OF IMPOUNDED WATER AND CCR AT TIME OF INSPECTION</b>		<b>WATER: 0 yd<sup>3</sup>      CCR: 473,627 yd<sup>3</sup></b>
<b>(vi)</b>	<b>ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT AND APPURTENANT STRUCTURES?</b>		<b>NO</b>
	(IF YES, DESCRIBE):		
<b>(vii)</b>	<b>ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION SINCE THE PREVIOUS ANNUAL INSPECTION?</b>		<b>NO</b>
	(IF YES, DESCRIBE): N/A		

Note 1: An accurate estimate of the stored volume in APB' at the present time cannot be made due to ongoing closure preparation activities which includes CCR being relocated to the area from other onsite ash pond closures.

- Cubic yard estimates are derived by qualified personnel from available information.



**LOCATION AND TYPE OF INSTRUMENTATION  
YATES ASH POND B'**

Instrument No.	Type of Instrument	Location of Instrument		Maximum Reading Since Last Inspection
		Northing	Easting	
APB'-1	Piezometer	1258084.69	2075198.99	EL 755*
APB'-2	Piezometer	1258197.65	2075279.82	EL 761*
APB'-3	Piezometer	1258228.41	2075224.66	EL 751

\* Abandoned on April 27, 2017