

GROUNDWATER EXCEEDANCE NOTIFICATION
40 C.F.R. PART 257.95(g)
PLANT BOWEN ASH POND 1 (AP-1)
GEORGIA POWER COMPANY

Consistent with the previous semiannual monitoring event, the following Appendix IV constituent(s) were detected at statistically significant levels above groundwater protection standards established pursuant to the “Disposal of Coal Combustion Residuals from Electric Utilities” Final Rule, 40 C.F.R. 257.95(h) and Georgia EPD Rules for Solid Waste Management 391-3-4-.10(6)(a).

Federal CCR Rule

- Arsenic
- Cobalt

State of Georgia CCR Rule

- Arsenic
- Cobalt
- Molybdenum

Per 40 C.F.R. 257.95 (g)(3)(ii) an alternate source demonstration was prepared to address the statistically significant levels of arsenic. Georgia Power will continue groundwater monitoring and reporting activities required by 40 C.F.R. 257.95.



Whitney B. Law, PE
Project Manager

8/31/2020
Date