

**WRITTEN CLOSURE PLAN REVISION 1
40 C.F.R. PART 257.102
PLANT MCDONOUGH ASH POND 2 (AP-2)
GEORGIA POWER COMPANY**

SITE INFORMATION

Site Name / Address

Plant McDonough-Atkinson
5551 South Cobb Drive
Atlanta, GA 30339

Owner Name / Address

Georgia Power Company
241 Ralph McGill Blvd
Atlanta, GA 30308

CCR Unit

AP-2

Closure Method

Closure by Removal

CLOSURE PLAN DESCRIPTION

§ 257.102(b)(1)(i) – Narrative description of how the CCR unit will be closed.

All CCR from the Plant McDonough AP-2 has been removed. A majority of the CCR from AP-2 was placed in McDonough AP-1 to provide drainage to facilitate closure in place of AP-1. Minor amounts of CCR from AP-2 were also dry stacked within the closure footprint of AP-3/4 or disposed of at permitted offsite waste management facilities. The closure procedures for AP-2 included dewatering as needed, clearing and grubbing of vegetative intermediate cover materials (disposed of off-site), excavating all visible ash, over excavating into the subgrade soils, and placement of topsoil and seeding for vegetative cover to provide erosion control for the completed surfaces. Closure will also include confirmation that groundwater monitoring concentrations do not exceed the groundwater protection standard established for constituents in Appendix IV of the CCR Rule.

§ 257.102(b)(1)(iv) – Estimate of the maximum inventory of CCR ever on-site over the active life of the CCR unit

Approximately 260,000 cubic yards of CCR was removed from AP-2.

WRITTEN CLOSURE PLAN REVISION 1
40 C.F.R. PART 257.102
PLANT MCDONOUGH ASH POND 2 (AP-2)
GEORGIA POWER COMPANY

§ 257.102(b)(1)(vi) – Closure Schedule

CCR removal activities for AP-2 began in March 2016 and were substantially completed in September 2016. Subsequent removal of a limited amount of CCR material was completed in September 2019. Milestone dates for closure activities are as follows.

Notification of Intent to Initiate Closure	December 7, 2015
Begin Dewatering Activities	Q1 2016
End of CCR Removal Activities	Q3 2019
Earthen Fill Placement in AP-2 (Future Development)	Q4 2022

**WRITTEN CLOSURE PLAN REVISION 1
40 C.F.R. PART 257.102
PLANT MCDONOUGH ASH POND 2 (AP-2)
GEORGIA POWER COMPANY**

Certification Statement 40 CFR §257.102(b)(4)

Written Closure Plan Revision 1

Site Name / Address

Plant McDonough-Atkinson
5551 South Cobb Drive
Atlanta, GA 30339


Owner Name / Address

Georgia Power Company
241 Ralph McGill Blvd
Atlanta, GA 30308

CCR Unit

AP-2

I hereby certify that the written closure plan was prepared in accordance with the requirements of 40 CFR § 257.102.


James C. Pegues, PE
Licensed GA PE 17419