

**LOCATION RESTRICTION DEMONSTRATION
PROXIMITY TO WETLANDS (40 C.F.R. PART 257.61)
PLANT MCDONOUGH-ATKINSON ASH POND 1 (AP-1)
GEORGIA POWER COMPANY**

Plant McDonough AP-1 is subject to the timelines announced in 81 Fed. Reg. 51802 (Aug. 5, 2016). Provision §257.61 of the United States Environmental Protection Agency's "Disposal of Coal Combustion Residuals from Electric Utilities Final Rule" (40 C.F.R. Part 257) requires that a CCR surface impoundment must not be located in wetlands, as defined by the U.S. Army Corps of Engineers, without special considerations and permitting.

No wetlands were identified within the limits of AP-1 based on a wetlands survey dated September 25, 2019. Based on current information, AP-1 meets the location restriction requirement of §257.61 for proximity to wetlands.

I hereby certify that for Georgia Power's Plant McDonough AP-1, the wetlands location restriction demonstration meets the requirement of 40 C.F.R. Part 257.61(a).



Gregory L. Hebeler, PhD, P.E.

Georgia Licensed Professional Engineer No. 034749

April 16, 2020

Golder Associates Inc.