

## Coal Combustion Residuals (CCR) Annual Fugitive Dust Control Report

**PLANT NAME:** Plant McManus

**OWNER/OPERATOR OF FACILITY:** Georgia Power

**REPORTING TIMEFRAME:** October 20, 2018 – October 19, 2019

**PURPOSE:** The purpose of this report is to demonstrate compliance with the requirements for the annual CCR fugitive dust control report in 40 CFR § 257.80 (c) of the Coal Combustion Residuals Final Rule. See 80 Fed. Reg. 21,302 (April 17, 2015). This report describes the actions taken by Plant McManus to control CCR fugitive dust, a record of all citizen complaints and if any, a summary of corrective measures taken.

### **DESCRIBE THE ACTIONS TAKEN TO CONTROL FUGITIVE DUST.**

CCR Units:

Ash Pond 1 (AP-1): Fugitive dust was controlled by water suppression or chemical dust suppressants, as needed.

Roads, CCR management and material handling activities:

Water suppression was used as needed to control fugitive dust on facility roads used to transport CCR and other CCR management areas.

Speed limits were utilized to reduce the potential for fugitive dust.

Trucks used to transport CCR were filled at or under capacity to reduce the potential for material spillage.

Trucks used to transport CCR off site were covered and the material was conditioned to an appropriate moisture content to reduce the potential for fugitive dust.

HAS THE FACILITY RECEIVED ANY CCR FUGITIVE DUST CITIZEN COMPLAINTS WITHIN THE REPORTING TIMEFRAME?	Yes	No
--	-----	----

IF YES, INCLUDE A RECORD OF ALL CITIZEN COMPLAINTS

Date	Description of Complaint	Corrective Measures (If Any)