



Plant McManus

Prepared by:



Monthly Dewatering Results¹

April 2021

Parameter	Units	Effluent Concentration			Permit Limits		
		Daily Min ²	Daily Avg ²	Daily Max ²	Daily Min	Daily Avg	Daily Max
Flow	MGD	0.00	0.60	0.67	***	***	***
pH	SU	7.8	***	8.4	6.0	***	9.0
Total Suspended Solids	mg/L	6.0	6.0	6.0	***	30.0	100.0
Oil and Grease	mg/L	ND ³	ND	ND	***	15.0	20.0

Parameter	Units	Effluent Concentration					Daily Average
		Week 1	Week 2	Week 3	Week 4	Week 5	
		Sampled in March	4/7/2021	No discharge	No discharge	No discharge	
Turbidity ⁴	NTU		2.5				2.5
Total Residual Chlorine	mg/L		***				***
Total Dissolved Solids	mg/L		1420				1420
Ammonia	mg/L		ND				ND
Total Kjeldahl Nitrogen	mg/L		1.60				1.60
Nitrate-Nitrite	mg/L		ND				ND
Organic Nitrogen	mg/L		1.50				1.50
Phosphorus	mg/L		ND				ND
Ortho-Phosphorus	mg/L		ND				ND
Biological Oxygen Demand	mg/L		ND				ND
Hardness	mg/L		329				329

Parameter	Units	Effluent Concentration ⁵					Calculated Receiving Water Concentration ⁵						Water Quality Criteria ⁶	
		Week 1 Sampled in March	Week 2 4/7/2021	Week 3 No discharge	Week 4 No discharge	Week 5 No discharge	Week 1 Sampled in March	Week 2 4/7/2021	Week 3 No discharge	Week 4 No discharge	Week 5 No discharge	Average	Acute ⁷	Chronic ⁷
Arsenic	µg/L		ND				***					***	69	36
Cadmium	µg/L		ND				***					***	33	7.9
Chromium ⁸	µg/L		ND				***					***	1,100	50
Copper	µg/L		ND				***					***	4.8	3.1
Lead	µg/L		ND				***					***	210	8.1
Nickel	µg/L		ND				***					***	74	8.2
Selenium	µg/L		ND				***					***	290	71
Zinc	µg/L		ND				***					***	90	81
Mercury	ng/L		ND				***					***	1,800	25

¹ Tetra Tech verifies the correct laboratory analysis methods were used, any applicable permit limits have been met and other results are protective of Georgia EPD's water quality standards.

² Daily Min and Daily Max are the lowest and highest values for any day in the month. Daily Avg is the arithmetic average of all daily values during the entire month.

³ ND = Not Detected. ND = Not Detected (below the lab's reporting limit).

⁴ Turbidity is monitored continuously. The value reported is the weekly maximum and the daily average is the average of the weekly maximum values reported.

⁵ Calculated Receiving Water Concentration shows the effluent concentration at the discharge once it has fully mixed in the receiving waterbody. This value is calculated as a dissolved concentration for an appropriate comparison to the numeric water quality criteria, which are also in the dissolved form. Consistent with Georgia EPD, non-detectable effluent concentrations are not translated into Calculated Receiving Water Concentrations.

⁶ Numeric Water Quality Criteria is the maximum concentration of a parameter (calculated at a default hardness of 50 mg/L as calcium carbonate) established for the receiving waterbody that will be protective of the designated use per Georgia EPD's rules and regulations. Calculated Receiving Water Concentrations less than these criteria are protective of the waterbody.

⁷ Acute (short-term) water quality criterion to be compared with the weekly calculated receiving water concentration; Chronic (long-term) water quality criterion to be compared with the average calculated receiving water concentration.

⁸ Numeric water quality criterion shown is for Hexavalent Chromium.

*** = Not Applicable

mg/L = milligrams per liter = parts per million; µg/L = micrograms per liter = parts per billion; ng/L = nanograms per liter = parts per trillion; SU = Standard Units; MGD = Million Gallons Day



Plant McManus

Prepared by:



Monthly Instream Results¹

April 2021

Parameter ³	Units	Burnett Creek ²			
		4/14/2021	4/14/2021	4/21/2021	4/21/2021
		Upstream	Downstream	Upstream	Downstream
pH	SU	7.3	7.3	7.3	7.5
TSS	mg/L	40.0	33.0	16.0	15.0
O&G	mg/L	ND	ND	ND	ND
TRC	mg/L	***	***	***	***
Turbidity	NTU	7.0	6.3	5.7	6.1
TDS	mg/L	16000	13800	18100	15000
BOD	mg/L	9.9	12.6	ND	ND
Arsenic	µg/L	ND	ND	ND	ND
Cadmium	µg/L	ND	ND	ND	ND
Chromium	µg/L	ND	ND	ND	ND
Copper	µg/L	ND	ND	ND	ND
Lead	µg/L	ND	ND	ND	ND
Mercury	ng/L	5.5	4.8	6.2	5.8
Nickel	µg/L	ND	ND	ND	ND
Selenium	µg/L	ND	ND	ND	ND
Zinc	µg/L	ND	ND	ND	ND
Ammonia	mg/L	0.18	ND	ND	ND
TKN	mg/L	0.65	0.59	0.72	0.71
Nitrate-Nitrite	mg/L	ND	0.05	ND	0.05
Organic Nitrogen	mg/L	ND	0.54	0.69	0.68
Phosphorus	mg/L	0.10	0.08	0.09	0.08
Ortho-phosphorus	mg/L	ND	0.03	ND	ND
Hardness	mg/L	2480	3070	2770	3000

1 Tetra Tech verifies the correct laboratory analysis methods were used.

2 Burnett Creek measured 1000ft upstream and 1000ft downstream of Final Outfall 002.

3 Metals results are total recoverable.

4 ND = Non-detect

*** = Not Applicable

mg/L = milligrams per liter = parts per million; µg/L = micrograms per liter = parts per billion; ng/L = nanograms per liter = parts per trillion; SU = Standard Units; MGD = Million Gallons Day