

257.84 (b)(2)	2021 REPORT OF ANNUAL INSPECTION OF CCR LANDFILL	
	CCR LANDFILL NAME: Plant Wansley Private Industrial Solid Waste (Coal Combustion By-Product) Disposal Facility (Active Cell 1, and Cells 2, & 3). Permit # 074-005D(LI).	
	OWNER OF CCR LANDFILL: Georgia Power Company	
	INSPECTION DATE: 12/13/2021	
	INSPECTING ENGINEER: Gary H. McWhorter, P.E. GA Reg. #PE012687	
(i)	ANY CHANGES IN GEOMETRY OF THE STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION? (IF YES, DESCRIBE):	NO ⁽¹⁾
(ii)	APPROXIMATE VOLUME OF CCR CONTAINED IN THE UNIT AT THE TIME OF INSPECTION?	523,384 ⁽²⁾
(iii)	ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT? (IF YES, DESCRIBE):	NO
(iv)	ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION OF THE CCR UNIT SINCE THE PREVIOUS ANNUAL INSPECTION? (IF YES, DESCRIBE):	NO

- (1) The geometry of the structure (permitted footprint and final grades) has not changed since the last inspection, with the exception of the additional placement or marketing of CCR.
- (2) Approximate CCR volume (by survey dated 12/01/2021): Cell 1 – 443,399 cy; Cell 2 – 33,422 cy; Cell 3 – 46,563 cy.

