

**PERIODIC HAZARD POTENTIAL CLASSIFICATION ASSESSMENT**  
**391-3-4-.10(4) and 40 C.F.R. PART 257.73**  
**PLANT YATES ASH POND B (AP-B)**  
**GEORGIA POWER COMPANY**


The Federal CCR Rule, and, for Existing Surface Impoundments where applicable, the Georgia CCR Rule (391-3-4-.10) require the owner or operator of a CCR surface impoundment to conduct initial and periodic hazard potential classification assessments. *See* 40 C.F.R. § 257.73(a)(2); Ga. Comp. R. & Regs. r. 391.3-4-.10(4)(b)<sup>1</sup>. The owner or operator must classify the hazard potential of each CCR surface impoundment as either a high hazard potential CCR surface impoundment, a significant hazard potential CCR surface impoundment, or a low hazard potential CCR surface impoundment and document the basis of the classification. In addition, the Rules require a subsequent assessment be performed within 5 years of the previous assessment. *See* 40 C.F.R. § 257.73(f)(3); Ga. Comp. R. & Regs. r. 391.3-4-.10(4)(b)<sup>1</sup>.

The CCR surface impoundment known as Plant Yates AP-B is located northwest of Newnan, Georgia, on Plant Yates property. AP-B was originally formed by an engineered cross-valley embankment located on the west side of the impoundment. The Notification of Intent to Initiate Closure was placed in the Operating Record on 04/20/2018 and closure has been designed to have no negative impacts on the classification. The impoundment is currently undergoing closure and all CCR has been removed from its original footprint. Furthermore, the unit is incapable of impounding water as the embankments have been breached in several locations.

Based on the potential impacts in the unlikely event of an embankment failure, a hazard potential classification of Low Hazard Potential was initially assigned to AP-B in 2016. Structural failure or mis-operation of the unit would result in no probable loss of human life and low economic and/or environmental losses; any losses would be limited to the Owner's property. A review of current conditions in and around AP-B indicates that a Low Hazard Potential classification is still the appropriate designation.

<sup>[1]</sup> In a typographical error, 391.3-4.10(4)(b) references the "structural integrity criteria in 40 CFR 247.73," when the reference to such criteria should be 40 CFR 257.73.

I hereby certify that the hazard potential classification was conducted in accordance with 40 C.F.R. Part 257.73 (a)(2).

  
James C. Rogers, P.E.  
Licensed State of GA, PE No. 17419  
5/15/2021