

**GROUNDWATER EXCEEDANCE NOTIFICATION**  
**40 C.F.R. PART 257.95(g)**  
**PLANT YATES AP-3, A, B, B' and R6 CCR LANDFILL**  
**GEORGIA POWER COMPANY**

**Federal CCR Rule**

The following Appendix IV constituent(s) were detected at statistically significant levels above the federal groundwater protection standards established pursuant to the "Disposal of Coal Combustion Residuals from Electric Utilities" Final Rule, 40 C.F.R. 257.95(h).


- **Beryllium**
- **Selenium**

**State of Georgia CCR Rule**

USEPA revised the Federal CCR Rule on July 30, 2018, updating groundwater protection standards for Cobalt, Lead, Lithium, and Molybdenum (See 40 CFR 257.95(h)(2)). While these updated federal groundwater protection standards are expected to govern, the following Appendix IV constituent(s) were detected at statistically significant levels above the current state groundwater protection standards. See Georgia EPD Rules for Solid Waste Management 391-3-4-.10(6)(a).

- **Beryllium**
- **Selenium**
- **Lithium**

Georgia Power will continue groundwater monitoring and reporting activities required by 40 C.F.R. 257.95.



\_\_\_\_\_  
Geoffrey Gay, P.E.  
Technical Expert (Eng)

January 31, 2022  
Date