


257.84 (b)(2)	2023 REPORT OF ANNUAL INSPECTION OF CCR LANDFILL	
CCR LANDFILL NAME: Plant Bowen CCR Landfill (Active Cells 1 & 2, 3 & 4, 9 & 10). Permit 008-018D(CCR)		
OWNER OF CCR LANDFILL: Georgia Power Company		
INSPECTION DATE: November 17, 2023		
INSPECTING ENGINEER: Gary H. McWhorter, P.E. GA Reg. #PE012687		
(i)	ANY CHANGES IN GEOMETRY OF THE STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION?	NO ⁽¹⁾
(IF YES, DESCRIBE):		
(ii)	APPROXIMATE VOLUME OF CCR CONTAINED IN THE UNIT AT THE TIME OF INSPECTION?	1,664,818 yd³ ⁽²⁾
(iii)	ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT?	NO
(IF YES, DESCRIBE):		
(iv)	ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION OF THE CCR UNIT SINCE THE PREVIOUS ANNUAL INSPECTION?	NO
(IF YES, DESCRIBE):		

- (1) The geometry of the structure (permitted footprint and CCR grades) has not changed since the last inspection, with the exception of the additional placement and marketing of CCR.
- (2) Approximate CCR volume: Cell 1 (by survey dated 12/06/2023) – 61,059 yd³; Cell 2 – 0 yd³; Cell 3&4 (by survey dated 10/04/2022; operated as one cell) – 1,507,000 yd³; Cell 9&10 (by survey dated 12/06/2023; operated as one cell) – 96,759 yd³.



 Gary H. McWhorter, P.E.
 GA. Reg. #PE012687
 GARY H. McWHORTER