

Coal Combustion Residuals (CCR) Annual Fugitive Dust Control Report

PLANT NAME: Plant McIntosh

OWNER/OPERATOR OF FACILITY: Georgia Power

REPORTING TIMEFRAME: October 20, 2022 – October 19, 2023

PURPOSE: The purpose of this report is to demonstrate compliance with the requirements for the annual CCR fugitive dust control report in accordance with Georgia Rules for Solid Waste Management 391-3-4-.10(5) [40 CFR § 257.80 (c)]. This report describes the actions taken by Plant McIntosh to control CCR fugitive dust, a record of all citizen complaints and if any, a summary of corrective measures taken.

DESCRIBE THE ACTIONS TAKEN TO CONTROL FUGITIVE DUST.

CCR Units:

Ash Pond 1 (AP-1): CCR has been removed from AP-1 in accordance with the closure plan.

Landfill 4, Cell 1 (LF 4 Cell 1): Fugitive dust was controlled by water suppression, chemical dust suppressants, material compaction, or by using vegetative or synthetic cover, as needed.

Landfill 4, Cell 2 (LF 4 Cell 2): Fugitive dust was controlled by water suppression, chemical dust suppressants, material compaction, or by using vegetative or synthetic cover, as needed.

Roads, CCR management and material handling activities: No CCR is transported or handled on site.

HAS THE FACILITY RECEIVED ANY CCR FUGITIVE DUST CITIZEN COMPLAINTS WITHIN THE REPORTING TIMEFRAME?	Yes	<input checked="" type="radio"/> No
--	-----	-------------------------------------

IF YES, INCLUDE A RECORD OF ALL CITIZEN COMPLAINTS

Date	Description of Complaint	Corrective Measures (If Any)