

<b>257.83 (b) (2)</b>	<b>REPORT OF ANNUAL INSPECTION OF CCR SURFACE IMPOUNDMENT</b>		
	<b>FACILITY NAME:</b> Plant McManus Ash Pond 1 (AP-1)		
	<b>OWNER/OPERATOR OF FACILITY:</b> Georgia Power Company		
	<b>INSPECTION DATE:</b> June 11, 2021		
	<b>INSPECTING ENGINEER:</b> Patrick B. Rhodes, P.E. (Georgia P.E. License # 24586) Southern Company Services Fossil Dam Safety		
	Based on the results of the inspection and review of the data provided by a qualified Professional Engineer, it is my professional opinion that the report has been completed in accordance with 40 CFR 257.83(b).		
<b>(i)</b>	<b>ANY CHANGES IN GEOMETRY OF THE IMPOUNDING STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION (YES OR NO)?</b>	No	
	(IF YES, DESCRIBE): N/A		
<b>(ii)</b>	<b>LOCATION AND TYPE OF EXISTING INSTRUMENTATION</b>	N/A (No Instrumentation)	
<b>(ii)</b>	<b>MAXIMUM RECORDED READING OF EACH INSTRUMENT SINCE PREVIOUS ANNUAL INSPECTION</b>	N/A (No Instrumentation)	
<b>(iii)</b>	<b>APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF THE IMPOUNDED WATER SINCE PREVIOUS ANNUAL INSPECTION*</b>		
	MIN. DEPTH: 0 ft	MAX. DEPTH: 22.8 ft	PRESENT DEPTH: Varies 0 - 21.2 ft
	MIN. ELEVATION: 1.2 ft-msl	MAX. ELEVATION: 2.8 ft-msl	PRESENT ELEVATION: 1.2 ft-msl
<b>(iii)</b>	<b>APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF CCR SINCE PREVIOUS ANNUAL INSPECTION.</b>		
	MIN. DEPTH: 0 ft*	MAX. DEPTH: 0 ft*	PRESENT DEPTH: 0 ft*
	MIN. ELEVATION: N/A*	MAX. ELEVATION: N/A*	PRESENT ELEVATION: N/A*
<b>(iv)</b>	<b>APPROXIMATE STORAGE CAPACITY OF IMPOUNDING STRUCTURE AT TIME OF INSPECTION.</b>	0 yd <sup>3</sup> *	
<b>(v)</b>	<b>APPROXIMATE VOLUME OF IMPOUNDED WATER AND CCR AT TIME OF INSPECTION</b>	WATER: 498,000 yd <sup>3</sup> *	CCR: 0 yd <sup>3</sup> *
<b>(vi)</b>	<b>ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT AND APPURTENANT STRUCTURES (YES OR NO)?</b>	No	
	(IF YES, DESCRIBE):		
<b>(vii)</b>	<b>ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION SINCE THE PREVIOUS ANNUAL INSPECTION (YES OR NO)?</b>	No	
	(IF YES, DESCRIBE):		

\* All CCR has been removed from AP-1 as part of closure by removal. The pond retains water only.

