

**LOCATION RESTRICTION DEMONSTRATION
FAULT AREAS (40 C.F.R. PART 257.62)
PLANT YATES ASH POND A (AP-A)
GEORGIA POWER COMPANY**

Plant Yates AP-A is subject to the timelines announced in 81 Fed. Reg. 51802 (Aug. 5, 2016). EPA's "Disposal of Coal Combustion Residuals from Electric Utilities Final Rule" (40 C.F.R. Part 257.62) requires that a CCR surface impoundment must not be located within 60 meters, or 200 feet, of the outermost damage zone of a fault that has had a displacement in Holocene time (within the last approximately 12,000 years).

Based on a review of the United States Geological Survey (USGS) Geologic Hazards Service Center Interactive Map, AP-A is not located within 200 feet of a fault that has had displacement in Holocene time. Additionally, there are no active Holocene faults identified by the USGS within Coweta County, Georgia.

I hereby certify that for Georgia Power's Plant Yates AP-A, the fault areas location restriction demonstration meets the requirements of 40 C.F.R. § 257.62(a).



Richard T Deason, P.E.
Atlantic Coast Consulting, Inc.

