

**LOCATION RESTRICTION DEMONSTRATION
FAULT AREAS (40 C.F.R. PART 257.62)
PLANT BOWEN ASH POND 1 (AP-1)
GEORGIA POWER COMPANY**

EPA's "Disposal of Coal Combustion Residuals from Electric Utilities Final Rule" (40 C.F.R. Part 257.62), requires that existing CCR surface impoundments must not be located within 200 ft of the outermost damage zone of a fault that has had displacement in Holocene time (within the last approximately 12,000 years). Based on review of available publications from the United States Geological Survey, there are no known faults present at the site and faults present in this region are not known to have had movement since Late Paleozoic times (approximately 250 million years before the present). Therefore, Plant Bowen AP-1 is not within 200 feet of the outermost damage zone of a fault that has had displacement in Holocene time.

I hereby certify that for Georgia Power's Plant Bowen AP-1, the fault areas location restriction demonstration meets the requirements of 40 C.F.R. Part 257.62(a).



Cuneyt Gokmen, P.E.

Licensed State of GA, PE No. 28504

10/17/2018

