

Georgia Power Plant Bowen
NPDES Permit No. GA0001449
Ash Pond Dewatering Plan

Revised October 2019

Reporting and Notification

Effluent and Instream monitoring results will be submitted to EPD via e-mail by the 15th day of the month following the sampling period. Results shall be submitted in an excel spreadsheet to both the EPD Compliance Office and the Industrial Permitting Unit. Laboratory analysis and data sheets shall be retained on site. The first report will be submitted the month following system startup. In addition, quarterly updates of the TSS vs. Turbidity correlation curve and other updates based on an exceedance of the EQS for TSS, will also be submitted to EPD via e-mail by the 15th of the month following the end of the quarter or the month after the EQS exceedance.

Immediate (within 24 hours) notification to both the EPD Compliance Office and Industrial Permitting Unit will occur if any of the EQSs for pH, total residual chlorine, or turbidity are not achieved, and the automatic recirculation system fails.