



Plant Bowen

Prepared by: TETRA TECH

Monthly Dewatering Results¹ January 2018

| Parameter | Units | Effluent Concentration | | Permit Limits | |
|------------------------|-------|------------------------|---------|---------------|-----------|
| | | Minimum | Maximum | Daily Avg | Daily Max |
| Flow | MGD | 0.0 | 0.95 | *** | *** |
| pH | SU | 6.3 | 7.0 | 6.0 - 9.0 | |
| Total Suspended Solids | mg/L | 14.5 | 20.0 | 30.0 | 100.0 |
| Oil and Grease | mg/L | ND ² | 14.8 | 15.0 | 20.0 |

| Parameter | Units | Measured Effluent Concentration | | |
|-------------------------|-------|---------------------------------|-----------|-----------|
| | | 1/12/2018 | 1/22/2018 | 1/29/2018 |
| Turbidity | NTU | 7.2 | 7.0 | 4.0 |
| Total Dissolved Solids | mg/L | 3,660 | 3,710 | 3,660 |
| Ammonia | mg/L | 0.9 | 1.4 | 1.2 |
| Total Kjeldahl Nitrogen | mg/L | 2.05 | 1.8 | 1.6 |
| Nitrate-Nitrite | mg/L | 4.0 | 4.4 | 4.6 |
| Organic Nitrogen | mg/L | 1.1 | 0.4 | 0.4 |
| Phosphorus | mg/L | ND | ND | ND |
| Ortho-Phosphorus | mg/L | ND | ND | ND |
| Hardness | mg/L | 2,750 | 2,820 | 2,710 |

| Parameter | Units | Effluent Concentration ³ | | | Calculated River Value ³ | | | Water Quality Standard ⁴ |
|-----------------------|-------|-------------------------------------|-----------|-----------|-------------------------------------|-----------|-----------|-------------------------------------|
| | | 1/12/2018 | 1/22/2018 | 1/29/2018 | 1/12/2018 | 1/22/2018 | 1/29/2018 | |
| Arsenic | µg/L | ND | 5.6 | ND | *** | 0.024 | *** | 340 |
| Cadmium | µg/L | 9.2 | 16.2 | 18.3 | 0.0075 | 0.0128 | 0.0145 | 1 |
| Chromium ⁵ | µg/L | ND | ND | ND | *** | *** | *** | 16 |
| Copper | µg/L | ND | 7.1 | ND | *** | 0.024 | *** | 7 |
| Lead | µg/L | ND | ND | ND | *** | *** | *** | 30 |
| Nickel | µg/L | 60.2 | 76.3 | 80.6 | 0.265 | 0.343 | 0.363 | 260 |
| Selenium ⁶ | µg/L | 20.4 | 18.4 | 16.3 | 0.107 | 0.096 | 0.085 | 5 |
| Zinc | µg/L | 70.3 | 223 | 191 | 0.224 | 0.737 | 0.631 | 65 |
| Mercury | ng/L | 11.6 | 18.8 | 19.3 | 0.012 | 0.019 | 0.020 | 1400 |

- 1 Tetra Tech verifies the correct laboratory analysis methods were used, any applicable permit limits have been met and other results are protective of Georgia EPD's water quality standards.
 - 2 ND = Not Detected.
 - 3 Calculated River Value shows what the total effluent concentration looks like once it has fully mixed in the receiving waterbody. This value is calculated as a dissolved concentration for an appropriate comparison to the numeric water quality criteria, which are also in the dissolved form. Consistent with Georgia EPD, non-detectable effluent concentrations are not translated into calculated river values.
 - 4 Numeric Water Quality Criteria is the maximum concentration of a parameter (calculated at a default hardness of 50 mg/L as calcium carbonate) established for the receiving waterbody that will be protective of the designated use per Georgia EPD's rules and regulations. Calculated River Values less than these criteria are protective of the waterbody.
 - 5 Numeric water quality criterion shown is for Hexavalent Chromium.
 - 6 The numeric water quality criterion shown is the chronic (long-term) water quality criterion for selenium since this parameter does not have an acute (short-term) water quality criterion.
- *** = Not Applicable