

GROUNDWATER EXCEEDANCE NOTIFICATION
40 C.F.R. PART 257.95(g)
PLANT HAMMOND ASH POND 1 (AP-1)
GEORGIA POWER COMPANY

Consistent with the previous semiannual monitoring event, the following Appendix IV constituent(s) were detected at statistically significant levels above groundwater protection standards established pursuant to the “Disposal of Coal Combustion Residuals from Electric Utilities” Final Rule, 40 C.F.R. 257.95(h) and Georgia EPD Rules for Solid Waste Management 391-3-4-.10(6)(a).


Federal CCR Rule

- Arsenic
- Molybdenum

State of Georgia CCR Rule

- Arsenic
- Molybdenum

Georgia Power will continue groundwater monitoring and reporting activities required by 40 CFR §257.95.


Whitney B. Law, PE
Project Manager

March 1, 2019
Date