



## GROUNDWATER EXCEEDANCE NOTIFICATION 40 C.F.R. PART 257.95(g) and GEORGIA EPD RULES FOR SOLID WASTE MANAGEMENT 391-3-4-.10(6)(a)

## PLANT HAMMOND ASH POND 2 (AP-2) GEORGIA POWER COMPANY

## Federal and State of Georgia CCR Rule

The following Appendix IV constituent(s) were detected at statistically significant levels above the groundwater protection standards established pursuant to the "Disposal of Coal Combustion Residuals from Electric Utilities" Final Rule, 40 C.F.R. 257.95(h) and Georgia Environmental Protection Division Rules for Solid Waste Management 391-3-4-.10(6)(a).

## - Cobalt

Georgia Power will continue groundwater monitoring and reporting activities required by 40 C.F.R. 257.95.



1/31/2023

Whitney B. Law, PE Project Director

Date