

POST-CLOSURE CARE PLAN

**PLANT KRAFT
INACTIVE CCR LANDFILL
GRUMMAN ROAD ASH LANDFILL
CHATHAM COUNTY, GEORGIA
FOR**



**Georgia
Power**

NOVEMBER 2018



Atlantic Coast Consulting, Inc.
630 Colonial Park, Suite 110, Roswell, GA,
p. 770-594-5998, f. 770-594-5967

TABLE OF CONTENTS

1. GENERAL1

2. POST-CLOSURE USE OF THE PROPERTY1

3. GROUNDWATER MONITORING2

4. ROUTINE INSPECTION OF VEGETATIVE / FINAL COVER / DRAINAGE SYSTEM.....2

5. SEDIMENT POND MAINTENANCE / CLEAN-OUT2

6. LIMITED ACCESS.....3

7. POST-CLOSURE SUPERVISION3

8. SITE EQUIPMENT.....3

9. REMOVAL OF CCR3

10. POST-CLOSURE CARE COST AND FINANCIAL INSURANCE3

11. NOTIFICATION OF MONITORING STANDARDS EXCEEDED3

12. NOTIFICATION AND CERTIFICATION.....4

13. RECORDKEEPING/NOTIFICATION REQUIREMENTS4

APPENDIX5

 A. POST-CLOSURE CARE COSTS6

1. GENERAL

The Grumman Road Ash Landfill post-closure care plan is prepared to meet the requirements of Rule 391-3-4-.10(7), which requires the owner or operator of an existing CCR landfill that is closed in place to provide for post-closure care of the landfill for a period of at least 30 years. Post-closure care includes maintaining the integrity of the final cover system, the liner, as well as continuing groundwater monitoring in accordance with Rule 391-3-4-.10(6).

Georgia Power will amend the initial and subsequent written post-closure care plans whenever:

- There is a change in the facility's operation of the landfill that substantially affects the written post-closure care plan in effect; or
- If after post-closure activities have commenced, unanticipated events necessitate a revision of the written post-closure care plan.

Georgia Power will amend the written post-closure care plan at least 60 days prior to a planned change in the operation of the CCR landfill affecting post-closure care, or no later than 60 days after an unanticipated event requires the need to revise the existing written post-closure care plan. If the written post-closure care plan is revised after post-closure care activities have commenced, Georgia Power will amend the written post-closure care plan no later than 30 days following an unanticipated event that necessitates a revision of the written post-closure care plan.

All amendments to the approved post-closure care plan will include a certification from a professional engineer licensed to practice in the State of Georgia, that the amended post-closure plan meets the requirements of Rule 391-3-4-.10(7).

The release from the post-closure requirements in this plan must be approved by the Director of the Georgia Environmental Protection Division (EPD).

2. POST-CLOSURE USE OF THE PROPERTY

Georgia Power shall conduct post closure for the CCR unit which shall consist of at least:

- A. Maintaining the integrity and effectiveness of the final cover system, including making repairs to the final cover as necessary to correct the effects of settlement, subsidence, erosion, or other events, and preventing run-on and run-off from eroding or otherwise damaging the final cover
- B. Maintaining the groundwater monitoring system and monitoring the groundwater in accordance with Groundwater Monitoring Plan included in this application.

At the end of the 30-year post-closure care period, if the site is in detection monitoring, Georgia Power may request a release from the post-closure care requirements in this plan. The release must be approved by the Director of Georgia EPD. However, if the site is operating under assessment monitoring, Georgia Power will continue to conduct post-closure care and

monitoring until the site returns to detection monitoring.

There is no planned use of this property during the Post-Closure Care Period at this time. Prior to any future use, EPD approval is required.

3. GROUNDWATER MONITORING

Groundwater monitoring shall continue throughout the Post-Closure Care Period as described in the Groundwater Monitoring Plan. Following each semi-annual sampling event, results will be provided to EPD for review. The groundwater monitoring wells shall be maintained throughout this period. If at any time the monitoring results indicate exceeding of established standards or indicate a threat to human health or the environment, Georgia Power will notify the Environmental Protection Division and comply with all requirements of Georgia Rule 391-3-4-.10(6). If at the end of the post-closure care period the facility is operating under assessment monitoring in accordance with Rule 391-3-4-.10(6), Georgia Power will continue to conduct post-closure care until the facility returns to detection monitoring in accordance with Rule 391-3-4-.10(6).

4. ROUTINE INSPECTION OF VEGETATIVE / FINAL COVER / DRAINAGE SYSTEM

Throughout the Post-Closure Care Period, the site shall be inspected on a quarterly basis to ensure that all CCR disposed of in the facility remains properly covered with the approved final closure system for the facility. Any repair work on the soil cover or synthetic cap liner shall meet or exceed the original construction requirements. Any areas noted to have less than the required cover from the effects of erosion, vehicular traffic, etc., shall be immediately repaired. All areas lacking proper vegetation shall be grassed and maintained according to the vegetation and fertilization plans in this Closure Plan. Down drain systems shall be maintained in proper working condition in accordance with the Permit Application. The contact person for post-closure care of the facility is provided below:

General Manager
Environmental Affairs
Georgia Power Company
241 Ralph McGill Blvd.
Atlanta, GA 30308
(404) 506-6505

5. SEDIMENT POND MAINTENANCE / CLEAN-OUT

Throughout the Post-Closure Care Period, all ditches, diversion berms, culverts, rip-rap, and other drainage structures shall be maintained in accordance with the permit application to prevent run-on and run-off from eroding or otherwise damaging the final cover. Erosion control structures shall be maintained so as to prevent damage to the final cover. Inspections of ditches, diversion berms, culverts, rip-rap, and other drainage structures will be performed by a qualified person and maintenance of these structures will be addressed as soon as practical.

6. LIMITED ACCESS

Access to the site shall be controlled by fencing, gates, buffers, etc. Access shall be limited to those time periods when the site is undergoing maintenance activities.

7. POST-CLOSURE SUPERVISION

Post-Closure Care of the site shall be under the supervision of a qualified professional.

General Manager
Environmental Affairs
Georgia Power Company
241 Ralph McGill Blvd.
Atlanta, GA 30308
(404) 506-6505


8. SITE EQUIPMENT

Georgia Power shall make adequate equipment available to ensure that Post-Closure Care requirements are executed correctly and efficiently. Rental equipment shall be utilized in the event that equipment dedicated to the CCR landfill should break down during Post-Closure Care procedures.

9. REMOVAL OF CCR

If Georgia Power wishes to remove CCR or CCR residue Georgia Power shall request and receive written approval from EPD prior to conducting any such activity.

10. POST-CLOSURE CARE COST AND FINANCIAL INSURANCE



11. NOTIFICATION OF MONITORING STANDARDS EXCEEDED

Georgia Power shall be responsible for conducting all monitoring activities. If at any time the monitoring results indicate exceeding of established standards or indicate a threat to human health or the environment, the Georgia Power shall notify the Environmental Protection Division and comply with all requirements of Georgia Rule 391-3-4-.10(6).

12. NOTIFICATION AND CERTIFICATION

No later than 60 days following the completion of the post-closure care period, Georgia Power will prepare a notification verifying that post-closure care has been completed. The notification will include the certification by a qualified professional engineer verifying that post-closure care has been completed in accordance with this plan. Georgia Power has completed the notification when it has been placed in the facility's operating record as required by Rule 391-3-4-.10(7) and provided to the Director of Georgia EPD. The release of the CCR unit of post-closure care must be approved by the Georgia EPD.

13. RECORDKEEPING/NOTIFICATION REQUIREMENTS

Georgia Power will comply with all applicable recordkeeping requirements and maintain the facility's operating record at all times.

APPENDIX

Age Group	Gender	Percentage Vaccinated
18-24	Male	~5%
25-34	Male	~15%
35-44	Male	~25%
45-54	Male	~35%
55-64	Male	~85%
65-74	Male	~95%
75-84	Male	~98%
85+	Male	~95%
18-24	Female	~10%
25-34	Female	~20%
35-44	Female	~30%
45-54	Female	~40%
55-64	Female	~80%
65-74	Female	~90%
75-84	Female	~95%
85+	Female	~90%