



# Safety Factor Assessment

*Plant McDonough-Atkinson*

*Ash Pond 3 (AP-3) and Ash Pond 4 (AP-4)*

Prepared for:

**Georgia Power Company**


Prepared by:

**Golder Associates Inc.**

3730 Chamblee Tucker Road

Atlanta, Georgia, USA 30341

+1 770 496-1893



---

# Table of Contents

<b>1.0</b>	<b>CERTIFICATION.....</b>	<b>1</b>
<b>2.0</b>	<b>INTRODUCTION.....</b>	<b>2</b>
<b>3.0</b>	<b>SLOPE STABILITY ASSESSMENT METHODOLOGY .....</b>	<b>2</b>
3.1	Maximum Pool Storage.....	2
3.2	Maximum Pool Surcharge.....	2
3.3	Seismic Loading Conditions.....	2
3.4	Liquefaction Assessment .....	3
<b>4.0</b>	<b>SLOPE STABILITY ASSESSMENT RESULTS.....</b>	<b>3</b>
<b>5.0</b>	<b>CONCLUSION .....</b>	<b>3</b>
<b>6.0</b>	<b>REFERENCES.....</b>	<b>3</b>

## APPENDICES

### APPENDIX A

Stability Analysis Figures for AP-3 and AP-4

---

## 1.0 CERTIFICATION

This Safety Factor Assessment for Georgia Power Company (Georgia Power)'s Ash Pond 3 (AP-3) and Ash Pond 4 (AP-4), located at Plant McDonough-Atkinson (Plant McDonough) in Cobb County, Georgia was prepared by Golder Associates Inc. (Golder).

I certify that this Safety Factor Assessment for AP-3 and AP-4 was prepared in accordance with §257.73(e) of the United States Environmental Protection Agency's "Standards for the Disposal of Coal Combustion Residuals in Landfills and Surface Impoundments" (40 CFR 257).



---

Gregory L. Hebeler, PhD, P.E.

Georgia Licensed Professional Engineer No. 034749

**Golder Associates Inc.**

---

## 2.0 INTRODUCTION

The United States Environmental Protection Agency (EPA)'s "Disposal of Coal Combustion Residuals from Electric Utilities" Final Rule (40 C.F.R. Part 257, the "CCR Rule") §257.73(e) requires the owner or operator of a CCR surface impoundment to conduct initial and periodic safety factor assessments. The owner or operator of the CCR unit must conduct an assessment and document whether the minimum safety factors outlined in §257.73(e)(1)(i) through (iv) for the critical cross section of the embankment are achieved. The interim (October 2017) construction condition of AP-3 and AP-4 was analyzed. In the interim condition, AP-3 and AP-4 are being consolidated and closed in-place as combined unit AP-3/4. According to section § 257.73(e) of the rule, stability of earth structures must be assessed under four loading conditions:

- Maximum Pool Storage (§ 257.73(e)(i))
- Maximum Pool Surcharge (§ 257.73(e)(ii))
- Seismic Loading Conditions (§ 257.73(e)(iii))
- Post-Seismic Liquefaction Conditions (when liquefaction susceptible materials are present; § 257.73(e)(iv)).

## 3.0 SLOPE STABILITY ASSESSMENT METHODOLOGY

Embankment stability safety factors were evaluated for each of the loading scenarios using the computer program SLIDE 7.0 Version 7.031 (2018). As required by the CCR Rule, a general limit equilibrium (GLE) method (Morgenstern and Price) was used to calculate factors of safety, and the factor of safety is calculated by dividing the resisting forces by the driving forces along the calculated critical slip surface.

Stability was evaluated along two cross-sections deemed the most critical for AP-3 and AP-4 as shown in Figure 1 of Appendix A. Subsurface stratigraphy at each cross-section was developed from data collected during subsurface explorations from October 2015 to January 2016. Similarly, material properties were developed for the dike, foundation, and impounded materials from this data. The conditions modeled in stability analyses are reflective of the (October 2017) interim conditions for AP-3 and AP-4.

### 3.1 Maximum Pool Storage

The safety factor analyses represent the pool storage conditions for the interim condition (October 2017). At the time of this demonstration, some areas of AP-3 and AP-4 are covered with liner and others remain as open construction areas. The interim pool storage condition calculated in the Inflow Design Flood Control calculations was used for the maximum pool storage stability calculations.

### 3.2 Maximum Pool Surcharge

The 100-year 24-hour rain event was used for the maximum pool surcharge scenario.

For AP-3 and AP-4, the interim condition rain event will cause stormwater flow in a combination of lined channels and open working areas. Thus, the stability of AP-3 and AP-4 slopes were evaluated with applicable water levels to the calculated flow depths for the rain event.

### 3.3 Seismic Loading Conditions

Factors of safety for stability under seismic loading conditions were calculated based on the earthquake hazard corresponding to a probability of exceedance of 2% in 50 years (2,475 year return period). The Bray and

Travasariou displacement-based seismic slope stability screening method was used to evaluate the seismic stability. For this method, a pseudo-static coefficient corresponding to an allowable displacement of six inches (15 cm) is applied as a horizontal force in the static stability model. The pseudo-static coefficient for the above stated criteria was calculated to be 0.029g (g = standard gravity).

### 3.4 Liquefaction Assessment

The CCR Rule specifies a required factor of safety of 1.2 against liquefaction for pond impoundment structures in section § 257.73(e)(iv). The dikes and foundation soils at the location of the AP-3 and AP-4 analysis sections were evaluated for liquefaction susceptibility and were found to have calculated factors of safety against liquefaction above 1.2.

## 4.0 SLOPE STABILITY ASSESSMENT RESULTS

The table below presents the results of the slope stability analyses for the AP-3 and AP-4 dikes. For all cases analyzed, the calculated factors of safety are in excess of those required in Sections § 257.73(e)(i) to (iii) of the CCR Rule. The detailed stability result figures are presented in Figures 2a-2c and 3a-3c of Appendix A.

Interim Condition Stability Analysis Results				
Analysis Case	Max. Storage Pool	Max. Surcharge Pool	Seismic	Post Liquefaction
Rule Section	§ 257.73(e)(i)	§ 257.73(e)(ii)	§ 257.73(e)(iii)	§ 257.73(e)(iv)
Target Factor of Safety	1.5	1.4	1.0	1.2
Cross-Sections	Factor of Safety			
AP-4 North	1.7	1.7	1.6	Not Applicable
AP-4 East	1.6	1.6	1.5	

## 5.0 CONCLUSION

Golder evaluated the stability of the dikes surrounding AP-3 and AP-4 in the four loading conditions in accordance with section § 257.73(e) of the CCR Rule:

- Maximum Pool Storage (§ 257.73(e)(i))
- Maximum Pool Surcharge (§ 257.73(e)(ii))
- Seismic Loading Conditions (§ 257.73(e)(iii))
- Post-Seismic Liquefaction Conditions (when liquefaction susceptible materials are present; § 257.73(e)(iv))

For each loading case, the dikes were calculated to meet the target factor of safety presented in the CCR Rule.

## 6.0 REFERENCES

Bray, J. D., and Travasarou, T. 2007. Simplified Procedure for Estimating Earthquake-Induced Deviatoric Slope Displacements. Journal of Geotechnical and Geoenvironmental Engineering, Vol. 133, No. 4, pp. 381-392.

---

Bray, J.D., and Travasarou, T. 2009. Pseudostatic Coefficient for Use in Simplified Seismic Slope Stability Evaluation. *Journal of Geotechnical and Geoenvironmental Engineering*, Vol. 135, No. 9: pp. 1336-1340.

Rocscience (2016), SLIDE Version 7.017.

USEPA (2015), Hazardous and Solid Waste Management System; Disposal of Coal Combustion Residuals from Electric Utilities, § 40 CFR Parts 257 and 261.

---


APPENDIX A

Stability Analysis Figures  
for AP-3 and AP-4





LEGEND  
2 FOOT CONTOURS, OCTOBER 2017 CONDITIONS



CLIENT  
GEORGIA POWER COMPANY

PROJECT  
PLANT MCDONOUGH  
AP-3 AND AP-4


TITLE  
**STABILITY SECTION PLAN  
10-2017 INTERIM CONDITIONS**


CONSULTANT	YYYY-MM-DD	2018-03-23
	PREPARED	JDG
	DESIGN	---
	REVIEW	LS
	APPROVED	GLH





PROJECT No. 1777449	CONTROL	Rev. 0	FIGURE <b>1</b>
------------------------	---------	-----------	--------------------







			SCALE	AS SHOWN	PROJECT			McDonough AP-3 and AP-4				
			DATE	Apr 2018		TITLE						
			MADE BY	LJ								
			CAD	-								
FILE			STABILITY		CHECK	JGM		CLIENT			FIGURE	
PROJECT No.		1777449	REV.	0	REVIEW	GLH						
								Georgia Power Company			2(a)	





 <b>GOLDER</b>	SCALE	AS SHOWN	PROJECT			<b>McDonough AP-3 and AP-4</b>				
	DATE	Apr 2018	TITLE				<b>Section AP-4 (North) Maximum Surcharge Pool</b>			
	MADE BY	LJ								
	CAD	-								
FILE	STABILITY		CHECK	JGM	CLIENT		<b>Georgia Power Company</b>		FIGURE <b>2(b)</b>	
PROJECT No.	1777449	REV.	0	REVIEW						





 <b>GOLDER</b>	SCALE	AS SHOWN	PROJECT			McDonough AP-3 and AP-4		
	DATE	Apr 2018	TITLE				Section AP-4 (North) Seismic Screening	
	MADE BY	LJ						
	CAD	-						
FILE	STABILITY	CHECK	JGM	CLIENT			FIGURE	
PROJECT No.	1777449	REVIEW	GLH					







	SCALE	AS SHOWN	PROJECT			McDonough AP-3 and AP-4		
	DATE	Apr 2018	TITLE					
	MADE BY	LJ						
	CAD	-						
FILE	STABILITY		CHECK	JGM	CLIENT		FIGURE	
PROJECT No.	1777449	REV.	0	REVIEW	GLH	Georgia Power Company		3(a)



	SCALE	AS SHOWN	PROJECT		McDonough AP-3 and AP-4	
	DATE	Apr 2018	TITLE		Section AP-4 (South) Maximum Surge Pool	
	MADE BY	LJ				
	CAD	-				
FILE	STABILITY	CHECK	JGM	CLIENT		FIGURE
PROJECT No.	1777449	REVIEW	GLH			
	REV.	0		Georgia Power Company		3(b)



 <b>GOLDER</b>	SCALE	AS SHOWN	PROJECT			<b>McDonough AP-3 and AP-4</b>		
	DATE	Apr 2018	TITLE				<b>Section AP-4 (South) Seismic Screening</b>	
	MADE BY	LJ						
	CAD	-						
FILE	STABILITY	CHECK	JGM	CLIENT			FIGURE	
PROJECT No.	1777449	REVIEW	GLH					