


LOCATION RESTRICTION DEMONSTRATION
WETLANDS
40 CFR PART 257.61
PLANT MCINTOSH ASH POND 1 (AP-1)
GEORGIA POWER COMPANY

In accordance with 40 CFR 257.61, the existing Ash Pond 1 (AP-1) is required to comply with the location restrictions related to wetlands.

Based on review of site location, land use data, site geology, hydrogeology, and available subsurface information, the existing AP-1 meets the location requirement for not being located in wetlands. AP-1 is also utilized as part of the plant's National Pollutant Discharge Elimination Systems (NDPES) wastewater treatment system. No jurisdictional wetlands were identified within the limits of AP-1.

This location restriction demonstration for the existing AP-1 was prepared under my direct supervision, direction, and control, in accordance with the Rules of Professional Conduct Chapter 180-6; and that, to the best of my knowledge, all information contained in this document is correct.



John Mathew Trast, P.E.
Registered Professional Engineer No. PE041928
Senior Consultant
GEI Consultants, Inc.

