

DRAFT  
ATTORNEY CLIENT PRIVILEGED WORK PRODUCT

<b>257.83 (b) (2)</b>	<b>REPORT OF ANNUAL INSPECTION OF CCR SURFACE IMPOUNDMENT</b>		
	FACILITY NAME: Plant Wansley Ash Pond		
	OWNER/OPERATOR OF FACILITY: Georgia Power Company		
	INSPECTION DATE: October 30, 2018		
	INSPECTING ENGINEER: Patrick B. Rhodes, PE (GA Reg. # PE024586)		
(i)	ANY CHANGES IN GEOMETRY OF THE IMPOUNDING STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION? (IF YES, DESCRIBE):		NO
(ii)	LOCATION AND TYPE OF EXISTING INSTRUMENTATION		SEE ATTACHED PLAN
(ii)	MAXIMUM RECORDED READING OF EACH INSTRUMENT SINCE PREVIOUS ANNUAL INSPECTION		SEE ATTACHED TABLE
	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF THE IMPOUNDED WATER SINCE PREVIOUS ANNUAL INSPECTION		
	MIN. DEPTH: 0 FT (ASH DELTA PRESENT)	MAX. DEPTH: 98 FT	PRESENT DEPTH: Up to 89 FT
	MIN. ELEVATION: 787 FT	MAX. ELEVATION: 798 FT	PRESENT ELEVATION: 787 FT
(iii)	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF CCR SINCE PREVIOUS ANNUAL INSPECTION.		
	MIN. DEPTH: 1 FT	MAX. DEPTH: 98 FT	PRESENT DEPTH: Up to 98 FT
	MIN. ELEVATION: 730 FT	MAX. ELEVATION: 798 FT	PRESENT ELEVATION: 796 FT
(iv)	APPROXIMATE STORAGE CAPACITY OF IMPOUNDING STRUCTURE AT TIME OF INSPECTION.	24,603,333 yd <sup>3</sup>	
(v)	APPROXIMATE VOLUME OF IMPOUNDED WATER AND CCR AT TIME OF INSPECTION	WATER: 5,155,800 yd <sup>3</sup>	CCR: 14,566,600 yd <sup>3</sup>
(vi)	ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT AND APPURTENANT STRUCTURES? (IF YES, DESCRIBE):		NO
(vii)	ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION SINCE THE PREVIOUS ANNUAL INSPECTION? (IF YES, DESCRIBE):		NO

- Cubic yard estimates are derived by qualified personnel from available information.



DRAFT  
ATTORNEY CLIENT PRIVILEGED WORK PRODUCT

INSTRUMENTATION READINGS  
PLANT WANSLEY ASH POND

PIEZOMETERS INSTALLED ON SEPARATOR DIKE BETWEEN ASH POND AND STORAGE POND

PIEZOMETER NUMBER	LOCATION	MAXIMUM RECORDED READING*
BB	N 33° 24.939', W 85° 02.507'	EL 785
DD	N 33° 25.063', W 85° 02.656'	EL 788

\*MAXIMUM RECORDED READING SINCE LAST ANNUAL INSPECTION; ROUNDED TO NEAREST FOOT



DRAFT  
ATTORNEY CLIENT PRIVILEGED WORK PRODUCT

