

**LOCATION RESTRICTION DEMONSTRATION
WETLANDS (40 C.F.R. PART 257.61)
PLANT WANSLEY ASH POND 1 (AP-1)
GEORGIA POWER COMPANY**

EPA's "Disposal of Coal Combustion Residuals from Electric Utilities Final Rule" (40 C.F.R. Part 257.61), requires that existing CCR surface impoundments must not be located in wetlands, as defined by the U.S. Army Corps of Engineers, without special considerations and permitting. A review of the U.S. Fish and Wildlife Service National Wetlands Inventory database (2018) identified no jurisdictional wetlands within the footprint or directly adjacent to AP-1 as part of this review, and therefore, Georgia Power's Plant Wansley AP-1 is not located in a wetland as defined by 40 C.F.R. Part 232.2. AP-1 is utilized as a part of Plant Wansley's National Pollutant Discharge Elimination System ("NPDES") wastewater treatment system.

I hereby certify that for Georgia Power's Plant Wansley AP-1, the wetlands location restriction demonstration meets the requirements of 40 C.F.R. Part 257.61(a).



Cuneyt Gokmen, P.E.

Licensed State of GA, PE No. 28504

10/17/2018