

INITIAL SAFETY FACTOR ASSESSMENT
40 C.F.R. PART 257.73
PLANT YATES ASH POND B' (AP-B')
GEORGIA POWER COMPANY

EPA's "Disposal of Coal Combustion Residuals from Electric Utilities" Final Rule (40 C.F.R. Part 257 and Part 261), §257.73(e), requires the owner or operator of an existing CCR surface impoundment to conduct initial and periodic safety factor assessments. The owner or operator of the CCR unit must conduct an assessment and document whether the minimum safety factors outlined in §257.73(e)(1)(i) through (iv) for the critical cross section of the embankment are achieved.

The CCR surface impoundment known as Plant Yates AP-B' is located on Plant Yates property, northwest of Newnan, Georgia. AP-B' is formed by an engineered cross-valley embankment. The critical section of AP-B' has been determined to be at the midpoint of the cross-valley embankment.

The analyses used to determine the minimum safety factor for the critical section resulted in the following minimum safety factors:

Loading Condition	Minimum Calculated Safety Factor	Minimum Required Safety Factor
Long-term Maximum Storage Pool (Static)	2.7	1.5
Maximum Surcharge Pool (Static)	2.7	1.4
Seismic	2.3	1.0

The embankments of AP-B' are constructed of compacted clayey sands that are not susceptible to liquefaction. Therefore, a minimum liquefaction safety factor determination was not required. This assessment is supported by appropriate engineering calculations which are attached.

I hereby certify that the safety factor assessment was conducted in accordance with 40 C.F.R. Part 257.73 (e)(1).

James C. Pegues, P.E.

Licensed State of Georgia, PE No. 17419





Engineering and Construction Services Calculation

Calculation Number:
TV-YT-GPC603884-003

Project/Plant: Plant Yates Ash Pond B'	Unit(s): Units 6-7	Discipline/Area: ESFS
Title/Subject: Slope Stability Analyses of Ash Pond B' Dam		
Purpose/Objective: Analyze slope stability of the Ash Pond B' Dam		
System or Equipment Tag Numbers: NA	Originator: Stacey H. Simpson, P.E.	

Contents

Topic	Page	Attachments (Computer Printouts, Tech. Papers, Sketches, Correspondence)	# of Pages
Purpose of Calculation	2	Attachment A - Boring Location Plan	1
Methodology	2	Attachment B - Boring and Piezometer Logs	14
Criteria and Assumptions	2	Attachment C - Laboratory Analyses	42
Input Data	3	Attachment D - Critical Section Profile Used in Analysis	1
Summary of Conclusions	4		
Design Inputs/References	4		
Body of Calculation	6		
Total # of pages including cover sheet & attachments:	72		

Revision Record

Rev. No.	Description	Originator Initial / Date	Reviewer Initial / Date	Approver Initial / Date
0	Issued for Information	SHS 10/05/16	JAL 10/10/16	JCP 10/10/16

Notes:

Purpose of Calculation

The Eugene A. Yates Power Plant (Plant Yates) was once a seven unit, coal fired, power generation facility. Currently Plant Yates Units 1-5 are in the process of demolition and Plant Yates Units 6 and 7 have been converted to natural gas. AP-B' was designed to receive and store coal combustion residuals produced during the electric power generating process at Plant Yates. In 1977, the southern portion of AP-B' began to be used as an ash dewatering facility for coal combustion residuals dredged from Ash Pond 2. In 2015, B' ceased operation as a dewatering facility and ash was removed for placement in the dry ash landfill. No ash has been removed since October 2015, and the pond is dormant.

The purpose of this calculation is to provide a slope stability assessment of the Plant Yates Ash Pond B' dam under conditions prescribed by the EPA CCR rule.

Methodology

The calculation was performed using the following methods and software:

GeoStudio 2012 (Version 8.15.5.11777), August 2015 Release, Copyright 1991-2016, GEO-SLOPE International, Ltd.

Strata (Version alpha, Revision 0.2.0), Geotechnical Engineering Center, Department of Civil, Architectural, and Environmental Engineering, University of Texas.

The Morgenstern-Price analytical method with an entry-exit slip surface was used for slope stability calculation.

Criteria and Assumptions

The slope stability models were run using the following assumptions and design criteria:

- Seismic site response was determined using a one-dimensional equivalent linear site response analysis. The analysis was performed using Strata and utilizing random vibration theory. The input motion consisted of the USGS published 2008 Uniform Hazard Response Spectrum (UHRS) for Site Class B/C at a 2% Probability of Exceedance in 50 years. The UHRS was converted to a Fourier Amplitude Spectrum, and propagated through a representative one dimensional soil column using linear wave propagation with strain-dependent dynamic soil properties. The input soil properties and layer thickness were randomized based on defined statistical distributions to perform Monte Carlo simulations for 100 realizations, which were used to generate a median estimate of the surface ground motions.
- The median surface ground motions were then used to calculate a pseudostatic seismic coefficient for utilization in the stability analysis using the approach suggested by Bray and Tavaslarou (2009). The procedure calculates the seismic coefficient for an allowable seismic displacement and a probability exceedance of the displacement. For this analysis, an allowable displacement of 0.5 ft, and a probability of exceedance of 16% were conservatively selected, providing a seismic coefficient of 0.043g for use as a horizontal acceleration in the stability analysis.

- During March 2010, two borings were performed at the top of the dike, and one was performed at the downstream bench.
- The soil properties used for the analysis (unit weight, phi angle, and cohesion) were obtained from triaxial shear testing performed on undisturbed Shelby tube samples of the dam fill and foundation soils obtained during drilling. Soil testing was performed according to applicable ASTM standards.
- The ash properties used for the analysis (unit weight, phi angle, and cohesion) were based on laboratory testing performed on undisturbed and remolded samples of ash from various plants and on engineering judgment.
- Piezometer readings were used to obtain water elevations within the dike and the foundation soils.
- The Corps of Engineers (COE) EM 1110-2-1902 standard, October 2003, allows the use of the phreatic surface established for the maximum storage condition (normal pool) in the analysis for the maximum surcharge loading condition. This is based on the short term duration of the surcharge loading relative to the permeability of the embankment and the foundation materials. This method is used in the analysis for the impoundments at this facility with surcharge loading.
- The current required minimum criteria (factors of safety) were taken from the Structural Integrity Criteria for Existing CCR Surface Impoundments, 40 CFR 257.73, published April 17, 2015.
- The critical section was selected at location having the apparent maximum dam height. The cross-section of the Ash Pond B' dam was modeled using the following sources:
 - 1) A 2010 level profile survey extending from the pond surface on the upstream face of the dam to the river surface on the downstream face of the dam performed by Southern Company Services (SCS).

Input Data

- Soil Properties: Three consolidated, undrained triaxial tests were performed on Shelby tube samples recovered from borings performed at Ash Pond B' to provide total and effective shear strength values of embankment and foundation soils. Soil classification testing, and unit weight and moisture content determination were also performed on the

samples. The results of the laboratory analyses are included in attachments to this calculation. A compacted ash sample obtained from the B' dike for triaxial testing was judged too disturbed to provide accurate test results. Ash properties were instead based on laboratory testing performed on remolded samples of ash from various plants and on past experience. The following effective stress values were used in the analyses.

Soil Description	Unit Weight, pcf	Effective Stress Parameters	
		Cohesion, psf	Phi Angle, degrees
Compacted Ash	105	0	28
Clayey Sand Fill	125	115	33
Residuum	127	72	35
Ash	98	0	28

- Phreatic Surface: Piezometers were installed at the following locations:
 - Dike Crest – Two piezometers were installed in the borings performed at the top of the dike.
 - Lower Bench – One piezometer was installed at the lower downstream bench in foundation soils.

Summary of Conclusions

The following table summarizes the factors of safety resulting from the slope stability analyses. The results indicate the safety factors of the Ash Pond B' dam meet or exceed the minimum criteria set forth in the structural integrity criteria for existing CCR surface impoundments, 40 CFR 257.73.

Factor of Safety Summary Table


Loading Condition	Minimum Calculated Safety Factor	Minimum Required Safety Factor
Long-term Maximum Storage Pool (Static)	2.7	1.5
Maximum Surcharge Pool (Static)	2.7	1.4
Seismic	2.3	1.0

Design Inputs/References

- Bray, J. D. and Travasarou, T., Pseudostatic Coefficient for Use in Simplified Seismic Slope Stability Evaluation, Journal of Geotechnical and Environmental Engineering, American Society of Civil Engineers, September 2009
- Atlanta Testing & Engineering Report, *Subsurface Exploration Modifications to B' Dike and Pond*, April 19, 1977

- SCS Drawing ES1836S1A - Pond and Cross-section Layouts
- SCS Drawing ES1836S1B – Plant Yates Ash Pond Dike Cross-Sections
- SCS ES1836S2 Piezometer and Boring Layout
- SCS 2010 Boring and Piezometer Logs
- 2010 Laboratory Analyses


Body of Calculation



PLANT YATES

ASH POND B'

Maximum Surcharge Pool




Name: Compacted Ash
Unit Weight: 105 pcf
Cohesion': 0 psf
Phi': 28 °

Name: Clayey Sand Fill
Unit Weight: 125 pcf
Cohesion': 115 psf
Phi': 33 °

Name: Bedrock

Name: Residuum
Unit Weight: 127 pcf
Cohesion': 72 psf
Phi': 35 °

Name: Ash
Unit Weight: 98 pcf
Cohesion': 0 psf
Phi': 28 °



ASH POND B'

Seismic

Horizontal Seismic Coefficient.: 0.043




Name: Compacted Ash
Unit Weight: 105 pcf
Cohesion': 0 psf
Phi': 28 °

Name: Clayey Sand Fill
Unit Weight: 125 pcf
Cohesion': 115 psf
Phi': 33 °

Name: Bedrock

Name: Residuum
Unit Weight: 127 pcf
Cohesion': 72 psf
Phi': 35 °



Name: Ash
Unit Weight: 98 pcf
Cohesion': 0 psf
Phi': 28 °



ATTACHMENTS

Attachment A - Boring Location Plan

F
E
D
C
B
A



- LEGEND:**
- BORING
 - PIEZOMETER

Southern Company Services, Inc. ©Copyright 2010, Southern Company Services, Inc. All Rights Reserved. <small>This document contains proprietary, confidential, and/or trade secret information of the subsidiaries of The Southern Company or of third parties. It is intended for use only by employees of, or authorized contractors of, the subsidiaries of The Southern Company. Unauthorized possession, use, distribution, copying, dissemination, or disclosure of any portion hereof is prohibited.</small>				
Southern Company Generation Engineering and Construction Services FOR				
Georgia Power Company				
PLANT YATES PIEZOMETER & BORING LOCATIONS				
SCALE	PROJ. I.D.	DRAWING NUMBER	SHEET	CONT'D
AS SHOWN		ES1836S2	2	FINAL

Attachment B - Boring and Piezometer Logs



LOG OF TEST BORING

BORING APB'-1
PAGE 1 OF 3

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Yates Ash Pond Dikes

LOCATION Plant Yates

DATE STARTED 3/16/2010 COMPLETED 3/16/2010 SURF. ELEV. 789.2 COORDINATES: N 1,258,084.49 E 2,075,198.96

CONTRACTOR SCS Field Services EQUIPMENT CME 55 METHOD Hollow Stem Auger

DRILLED BY T. Milam LOGGED BY R. Mudd CHECKED BY _____ ANGLE _____ BEARING _____

BORING DEPTH 66 ft. GROUND WATER DEPTH: DURING _____ COMP. _____ DELAYED 32.7 ft. after 48 hrs.

NOTES Top of Ash Pond B' Dike, South Side Well installed. Refer to well data sheet.

GEOTECH ENGINEERING LOGS - ES&E DATABASE.GDT - 5/4/10 14:57 - T:\ES&E MAJOR PROJECTS\PROJECTS\YATES\YATES 2010\EPA ASH POND INSPECTIONS\BORING INFORMATION\YATES ASH POND DIKES.GPJ

DEPTH (ft)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	SAMPLE TYPE NUMBER	SAMPLE DEPTH (ft.)	BLOW COUNTS (N VALUE)	RECOVERY % (RQD)	COMMENTS
		ML - gray, moist, soft, low plasticity, ASH						
5				SS -1	4.5-6.0	WH-1-1 (2)		
10				SS -2	9.5-11.0	2-2-1 (3)		(MC = 27.9%; PL=NP; FC = 77.8%; Gravel = 0.2%)
15				SS -3	14.5-16.0	2-1-1 (2)		
20		SM - red and medium and dark gray, moist, low plasticity, fine to medium grain, probable fill material	769.7	SS -4	19.5-21.0	2-3-3 (6)		(MC = 17.6%; LL = 46; PI=17; FC = 42.8%; Gravel = 2.4%)
25							100	

(Continued Next Page)



LOG OF TEST BORING

BORING APB'-1
PAGE 2 OF 3

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Yates Ash Pond Dikes

LOCATION Plant Yates

DEPTH (ft)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	SAMPLE TYPE NUMBER	SAMPLE DEPTH (ft.)	BLOW COUNTS (N VALUE)	RECOVERY % (RQD)	COMMENTS
		SM - red and medium and dark gray, moist, low plasticity, fine to medium grain, probable fill material (<i>Con't</i>)		UD -1	24.5- 26.5		100	
30								(MC = 20.9%; FC = 41%)
				SS -5	29.5- 31.0	3-3-3 (6)		
35								
				SS -6	34.5- 36.0	3-4-8 (12)		
40								
				SS -7	39.5- 41.0	4-4-4 (8)		
45								More clay, slightly darker in color, more grays and black, silver mica. (MC = 28.3%; FC = 55.4%; Gravel = 0.2%)
				SS -8	44.5- 46.0	2-4-4 (8)		
50			739.7					Beginning of residuum material. (MC = 54.7%; FC = 32.4%; Gravel = 0.9%)
		SM - light orange and gray presenting in layers, moist, medium dense, fine to medium grain, residuum		SS -9	49.5- 51.0	4-5-9 (14)		
55		SM - light gray and medium orange and white,						Possible water table.

(Continued Next Page)



LOG OF TEST BORING

BORING APB'-1
PAGE 3 OF 3

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Yates Ash Pond Dikes

LOCATION Plant Yates

DEPTH (ft)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	SAMPLE TYPE NUMBER	SAMPLE DEPTH (ft.)	BLOW COUNTS (N VALUE)	RECOVERY % (RQD)	COMMENTS
60		wet, dense, fine grain, weathered in place parent rock structure evident, white section less weathered than rest of sample, several medium angular pebbles in sample, especially in white portion, probable water table SM - light orange and gray presenting in layers, moist, medium dense, fine to medium grain, residuum (<i>Con't</i>)		SS -10	54.5- 56.0	4-9-17 (26)		(MC = 13.3%; FC = 31%)
		SM - very dense, very fine grain, no pebbles, predominantly gray and dark tan, with some white		SS -11	59.5- 60.9	18-30-50/5" (100+)	50	
65		SM - light orange and white, moist, very dense, very fine grain, parent rock structure evident		SS -12	64.5- 64.8	50/4" (100+)		
			723.2					
		Bottom of borehole at 66.0 feet.						
70								
75								
80								
85								

GEOTECH ENGINEERING LOGS - ESEE DATABASE.GDT - 5/4/10 14:57 - T:\ESEE MAJOR PROJECTS\PROJECTS\YATES\YATES 2010\EPA ASH POND INSPECTIONS\BORING INFORMATION\YATES ASH POND DIKES.GPJ



LOG OF TEST BORING

BORING APB'-2
PAGE 1 OF 2

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Yates Ash Pond Dikes

LOCATION Plant Yates

DATE STARTED 3/16/2010 COMPLETED 3/16/2010 SURF. ELEV. 789.0 COORDINATES: N 1,258,197.60 E 2,075,279.61

CONTRACTOR SCS Field Services EQUIPMENT CME 55 METHOD Hollow Stem Auger

DRILLED BY T. Milam LOGGED BY R. Mudd CHECKED BY _____ ANGLE _____ BEARING _____

BORING DEPTH 46 ft. GROUND WATER DEPTH: DURING _____ COMP. _____ DELAYED 25.1 ft. after 48 hrs.

NOTES Top of Ash Pond B', North Side Well installed. Refer to well data sheet.

GEOTECH ENGINEERING LOGS - ESEE DATABASE.GDT - 5/4/10 14:57 - T:\ESEE MAJOR PROJECTS\PROJECTS\YATES\YATES 2010\EPA ASH POND INSPECTIONS\BORING INFORMATION\YATES ASH POND DIKES.GPJ

DEPTH (ft)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	SAMPLE TYPE NUMBER	SAMPLE DEPTH (ft.)	BLOW COUNTS (N VALUE)	RECOVERY % (RQD)	COMMENTS
5		ML - dark gray, moist, no plasticity, <i>fill</i> , ASH		SS -1	4.5-6.0	3-2-2 (4)		(MC = 20.6%; PL=NP; FC = 56.2%; Gravel = 4.8%)
10				UD -1	7.5-9.5		100	
				SS -2	9.5-11.0	2-1-1 (2)		(MC = 25.7%; PL=NP; FC = 56.4%; Gravel = 3.9%)
15				UD -2	12.5-14.5		100	
			774.0	SS -3	14.5-16.0	1-1-3 (4)		
20		SC - orange and yellow and tan, moist, fine to medium grain, <i>fill</i>		SS -4	19.5-21.0	1-3-3 (6)		
		SC - light tan, gray and red, <i>fill</i> , isolated layers of sandy CLAY (CL) that is stiff		UD -3	22.5-24.5		100	
25		SC - gray with some tan and mottled black						

(Continued Next Page)



LOG OF TEST BORING

BORING APB'-2
PAGE 2 OF 2

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Yates Ash Pond Dikes

LOCATION Plant Yates

DEPTH (ft.)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	SAMPLE TYPE NUMBER	SAMPLE DEPTH (ft.)	BLOW COUNTS (N VALUE)	RECOVERY % (RQD)	COMMENTS
		throughout, moist, fine grain, <i>fill</i> , less clay, isolated layers of (SP-SC) SC - orange and yellow and tan, moist, fine to medium grain, <i>fill</i> (<i>Con't</i>)		SS -5	24.5- 26.0	3-5-5 (10)		
30		SC - orange and tannish gray, moist, fine to medium grain, <i>fill</i> , micaceous, very clayey		SS -6	29.5- 31.0	4-5-5 (10)		(MC = 16.6%; LL = 50; PI=23; FC = 45.5%; Gravel = 0.2%)
35		SC - <i>fill</i> , slightly less clayey		SS -7	34.5- 36.0	3-3-4 (7)		
40				SS -8	39.5- 41.0	1-3-3 (6)		(MC = 26%; LL = 55; PI=25; FC = 47.2%)
45			743.0	SS -9	44.5- 46.0	2-3-5 (8)		
		Bottom of borehole at 46.0 feet.						
50								
55								

GEOTECH ENGINEERING LOGS - ESEE DATABASE.GDT - 5/4/10 14:57 - T:\ESEE MAJOR PROJECTS\PROJECTS\YATES\YATES 2010\IEPA ASH POND INSPECTIONS\BORING INFORMATION\YATES ASH POND DIKES.GPJ



LOG OF TEST BORING

BORING APB'-3
PAGE 1 OF 2

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Yates Ash Pond Dikes

LOCATION Plant Yates

DATE STARTED 3/16/2010 COMPLETED 3/17/2010 SURF. ELEV. 768.6 COORDINATES: N 1,258,228.40 E 2,075,224.62

CONTRACTOR SCS Field Services EQUIPMENT CME 55 METHOD Hollow Stem Auger

DRILLED BY T. Milam LOGGED BY R. Mudd CHECKED BY _____ ANGLE _____ BEARING _____

BORING DEPTH 51 ft. GROUND WATER DEPTH: DURING _____ COMP. _____ DELAYED 13.2 ft. after 24 hrs.

NOTES Toe of Ash Pond B' Well installed. Refer to well data sheet.

GEOTECH ENGINEERING LOGS - ESEE DATABASE.GDT - 5/4/10 14:57 - T:\ESEE MAJOR PROJECTS\PROJECTS\YATES\YATES 2010\IEPA ASH POND INSPECTIONS\BORING INFORMATION\YATES ASH POND DIKES.GPJ

DEPTH (ft)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	SAMPLE TYPE NUMBER	SAMPLE DEPTH (ft.)	BLOW COUNTS (N VALUE)	RECOVERY % (RQD)	COMMENTS
5		ML - dark gray, moist, no plasticity, ASH		SS -1	4.5-6.0	1-1-2 (3)		
10		ML - very wet, very soft, ASH		SS -2	9.5-11.0	WH-WH-WH (0)		(MC = 35.1%; PL=NP; FC = 89%; Gravel = 0.2%)
15		SC - red, orange and gray, wet, medium grain, Probable fill	754.1	SS -3	14.5-16.0	2-2-2 (4)		(MC = 24.1%; LL = 54; PI=23; FC = 34.8%; Gravel = 0.4%)
20		SC - tan, red and gray, very wet, loose, medium to fine grain, Possible residuum, layers of CH in sample		UD -1	17.5-19.5		100	
				SS -4	19.5-21.0	WH-2-2 (4)		
25		SC - red, yellow, and orange mottled, moist,						

(Continued Next Page)



LOG OF TEST BORING

BORING APB'-3
PAGE 2 OF 2

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Yates Ash Pond Dikes

LOCATION Plant Yates

DEPTH (ft)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	SAMPLE TYPE NUMBER	SAMPLE DEPTH (ft.)	BLOW COUNTS (N VALUE)	RECOVERY % (RQD)	COMMENTS
25		medium dense, fine grain, very high clay content, plastic fines		SS -5	24.5-26.0	1-4-5 (9)		
30		SC - red, orange and gray, wet, medium grain, Probable fill (Con't)						
35		SC - gray, wet, loose, medium to high plasticity, fine to medium grain, high clay content, fines have medium to high plasticity		SS -6	29.5-31.0	1-2-4 (6)		(MC = 20.3%; LL = 45; PI=24; FC = 39.7%; Gravel = 6.2%)
40		SP - light tan and white with dark brown veins, moist, medium dense, fine to medium grain, parent rock structure evident	734.1	SS -7	34.5-36.0	8-9-5 (14)		
45		SP - predominately white with dark brown veins		SS -8	39.5-41.0	3-6-8 (14)		(MC = 29.3%; FC = 27.2%)
50		SP - dense, one orange-red clayey sand seam running vertically through sample		SS -9	44.5-46.0	7-16-14 (30)		
55		SP - tan and medium brown, very dense	717.6	SS -10	49.5-51.0	8-18-27 (45)		Boring Terminated.
		Bottom of borehole at 51.0 feet.						

GEOTECH ENGINEERING LOGS - ESEE DATABASE.GDT - 5/4/10 14:57 - T:\ESEE MAJOR PROJECTS\PROJECTS\YATES\YATES 2010\IEPA ASH POND INSPECTIONS\BORING INFORMATION\YATES ASH POND DIKES.GPJ



LOG OF TEST BORING AND WELL

BORING APB'-1
PAGE 1 OF 3

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Yates Ash Pond Dikes

LOCATION Plant Yates

DATE STARTED 3/16/2010 COMPLETED 3/16/2010 SURF. ELEV. 789.2 COORDINATES: N 1,258,084.49 E 2,075,198.96

CONTRACTOR SCS Field Services EQUIPMENT CME 55 METHOD Hollow Stem Auger

DRILLED BY T. Milam LOGGED BY R. Mudd CHECKED BY _____ ANGLE _____ BEARING _____

BORING DEPTH 66 ft. GROUND WATER DEPTH: DURING _____ COMP. _____ DELAYED 32.7 ft. after 48 hrs.

NOTES Top of Ash Pond B' Dike, South Side Well installed. Refer to well data sheet.

GEOTECH WITH WELL LOG - ESEE DATABASE.GDT - 5/4/10 16:28 - T:\ESEE MAJOR PROJECTS\PROJECTS\YATES\2010\EPA ASH POND INSPECTIONS\BORING INFORMATION\YATES ASH POND DIKES.GPJ

DEPTH (ft)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	GROUNDWATER OBSERVATIONS	WELL DATA
					-Riser only, no protector -Single piezometer -Top of Casing Elev.=792.74
5		ML - gray, moist, soft, low plasticity, ASH			
10					
15					
20		SM - red and medium and dark gray, moist, low plasticity, fine to medium grain, probable fill material			
25					← Bentonite chips

(Continued Next Page)



LOG OF TEST BORING AND WELL

BORING APB'-1
PAGE 2 OF 3

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Yates Ash Pond Dikes

LOCATION Plant Yates

DEPTH (ft)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	GROUNDWATER OBSERVATIONS	WELL DATA
					-Riser only, no protector -Single piezometer -Top of Casing Elev.=792.74 (CONTINUED)
30		SM - red and medium and dark gray, moist, low plasticity, fine to medium grain, probable fill material (Con't)			
35				3/18/2010●	
40					2" ID PVC Riser (SCH 40)
45					
50		SM - light orange and gray presenting in layers, moist, medium dense, fine to medium grain, residuum			
55		SM - light gray and medium orange and white, wet, dense, fine grain,			

(Continued Next Page)



LOG OF TEST BORING AND WELL

BORING APB'-1
PAGE 3 OF 3

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Yates Ash Pond Dikes

LOCATION Plant Yates

DEPTH (ft)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	GROUNDWATER OBSERVATIONS	WELL DATA
					-Riser only, no protector -Single piezometer -Top of Casing Elev.=792.74
					(CONTINUED)
		weathered in place parent rock structure evident, white section less weathered than rest of sample, several medium angular pebbles in sample, especially in white portion, probable water table SM - light orange and gray presenting in layers, moist, medium dense, fine to medium grain, residuum (<i>Cont</i>)			Silica sand filter
60		SM - very dense, very fine grain, no pebbles, predominantly gray and dark tan, with some white			2" ID PVC Screen (SCH 40)
65		SM - light orange and white, moist, very dense, very fine grain, parent rock structure evident			
Bottom of borehole at 66.0 feet.					
70					
75					
80					
85					

GEOTECH WITH WELL LOG - ESEE DATABASE.GDT - 5/4/10 16:28 - T:\ESEE MAJOR PROJECTS\PROJECTS\YATES\2010\EPA ASH POND INSPECTIONS\BORING INFORMATION\YATES ASH POND DIKES.GPJ



LOG OF TEST BORING AND WELL

BORING APB'-2
PAGE 1 OF 2

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Yates Ash Pond Dikes

LOCATION Plant Yates

DATE STARTED 3/16/2010 COMPLETED 3/16/2010 SURF. ELEV. 789.0 COORDINATES: N 1,258,197.60 E 2,075,279.61

CONTRACTOR SCS Field Services EQUIPMENT CME 55 METHOD Hollow Stem Auger

DRILLED BY T. Milam LOGGED BY R. Mudd CHECKED BY _____ ANGLE _____ BEARING _____

BORING DEPTH 46 ft. GROUND WATER DEPTH: DURING _____ COMP. _____ DELAYED 25.1 ft. after 48 hrs.

NOTES Top of Ash Pond B', North Side Well installed. Refer to well data sheet.

GEOTECH WITH WELL LOG - ESEE DATABASE.GDT - 5/4/10 16:28 - T:\ESEE MAJOR PROJECTS\PROJECTS\YATES\2010\EPA ASH POND INSPECTIONS\BORING INFORMATION\YATES ASH POND DIKES.GPJ

DEPTH (ft)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	GROUNDWATER OBSERVATIONS	WELL DATA
					-Riser only, no protector -Single piezometer -Top of Casing Elev.=793.21
5		ML - dark gray, moist, no plasticity, <i>fill</i> , ASH			
10					
15					
		SC - orange and yellow and tan, moist, fine to medium grain, <i>fill</i>			← Bentonite chips ← 2" ID PVC Riser (SCH 40)
20		SC - light tan, gray and red, <i>fill</i> , isolated layers of sandy CLAY (CL) that is stiff			
25		SC - gray with some tan and mottled black throughout, moist, fine			

(Continued Next Page)



LOG OF TEST BORING AND WELL

BORING APB'-2
PAGE 2 OF 2

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Yates Ash Pond Dikes
LOCATION Plant Yates

DEPTH (ft)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	GROUNDWATER OBSERVATIONS	WELL DATA
					-Riser only, no protector -Single piezometer -Top of Casing Elev.=793.21 (CONTINUED)
		grain, <i>fill</i> , less clay, isolated layers of (SP-SC) SC - orange and yellow and tan, moist, fine to medium grain, <i>fill</i> (<i>Con't</i>)		3/16/2010	
30		SC - orange and tannish gray, moist, fine to medium grain, <i>fill</i> , micaceous, very clayey			
35		SC - <i>fill</i> , slightly less clayey			9 bags silica sand filter
40					2" ID PVC Screen (SCH 40)
45					
		Bottom of borehole at 46.0 feet.			
50					
55					

GEOTECH WITH WELL LOG - ESEE DATABASE.GDT - 5/4/10 16:28 - T:\ESEE MAJOR PROJECTS\PROJECTS\YATES 2010\EPA ASH POND INSPECTIONS\BORING INFORMATION\YATES ASH POND DIKES.GPJ



LOG OF TEST BORING AND WELL

BORING APB'-3
PAGE 1 OF 2

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Yates Ash Pond Dikes

LOCATION Plant Yates

DATE STARTED 3/16/2010 COMPLETED 3/17/2010 SURF. ELEV. 768.6 COORDINATES: N 1,258,228.40 E 2,075,224.62

CONTRACTOR SCS Field Services EQUIPMENT CME 55 METHOD Hollow Stem Auger

DRILLED BY T. Milam LOGGED BY R. Mudd CHECKED BY _____ ANGLE _____ BEARING _____

BORING DEPTH 51 ft. GROUND WATER DEPTH: DURING _____ COMP. _____ DELAYED 13.2 ft. after 24 hrs.

NOTES Toe of Ash Pond B' Well installed. Refer to well data sheet.

GEOTECH WITH WELL LOG - ESEE DATABASE.GDT - 5/4/10 16:28 - T:\ESEE MAJOR PROJECTS\PROJECTS\YATES 2010\EPA ASH POND INSPECTIONS\BORING INFORMATION\YATES ASH POND DIKES.GPJ

DEPTH (ft)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	GROUNDWATER OBSERVATIONS	WELL DATA
					-Riser only, no protector -Single piezometer -Top of Casing Elev.=770.73
5		ML - dark gray, moist, no plasticity, ASH			
10		ML - very wet, very soft, ASH			
15		SC - red, orange and gray, wet, medium grain, Probable fill		3/18/2010●	← Bentonite chips
20		SC - tan, red and gray, very wet, loose, medium to fine grain, Possible residuum, layers of CH in sample			← 2" ID PVC Riser (SCH 40)
25		SC - red, yellow, and orange mottled, moist, medium dense, fine grain,			

(Continued Next Page)



LOG OF TEST BORING AND WELL

BORING APB'-3
PAGE 2 OF 2

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Yates Ash Pond Dikes

LOCATION Plant Yates

DEPTH (ft)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	GROUNDWATER OBSERVATIONS	WELL DATA
					-Riser only, no protector -Single piezometer -Top of Casing Elev.=770.73 (CONTINUED)
30		very high clay content, plastic fines SC - red, orange and gray, wet, medium grain, Probable fill (Cont)			
35		SC - gray, wet, loose, medium to high plasticity, fine to medium grain, high clay content, fines have medium to high plasticity			
40		SP - light tan and white with dark brown veins, moist, medium dense, fine to medium grain, parent rock structure evident			
45		SP - predominately white with dark brown veins			← Silica sand filter
50		SP - dense, one orange-red clayey sand seam running vertically through sample			← 2" ID ABS Screen (SCH 40)
55		SP - tan and medium brown, very dense			
		Bottom of borehole at 51.0 feet.			

Attachment C - Laboratory Analyses


Project: Plant Yates Ash Pond
 Project Number 6189-10-9008
 Date Performed 4/2/2010
 Date Sampled

Moisture Content Calculation: (WetWt-DryWt)/(DryWt-can wt)

Boring Number	APA-2	APA-2	APA-2	APA-2	APB-1	APB-1	APB-1	APB-1	APB-1	APB-1
Sample Number	4	5	6	8	2	4	5	8	9	11
Depth	19.5-21	24.5-26	29.5-31	39.5-41	9.5-11	19.5-21	29.5-31	44.5-46	49.5-51	59.5-61
Can Number										
Can Weight	55.6	54.57	55.68	54.94	50.18	54.38	54.75	52.08	54.86	54.72
Wet wt w/ Can	165.36	218.03	223.21	228.36	171.67	208.71	197.61	170.79	197.96	166.95
Dry wt. W/ Can	140.95	171.67	179.27	191.37	145.14	185.56	172.91	144.58	174.33	153.78
Percent Moisture	28.6%	39.6%	35.6%	27.1%	27.9%	17.6%	20.9%	28.3%	54.7%	13.3%

Boring Number	APB-2	APB-2	APB-2	APB-2	APB-3	APB-3	APB-3	APB-3		
Sample Number	1	2	6	8	2	3	6	8		
Depth	4.5-6	9.5-11	29.5-31	39.5-41	9.5-11	14.5-16	29.5-31	39.5-41		
Can Number										
Can Weight	50.78	49.08	51.91	50.67	56.07	54.6	57.02	52.67		
Wet wt w/ Can	158.56	168.62	168.74	166.87	114.61	192.13	201.87	145.59		
Dry wt. W/ Can	140.15	144.2	152.15	142.89	99.41	165.42	177.47	124.54		
Percent Moisture	20.6%	25.7%	16.6%	26.0%	35.1%	24.1%	20.3%	29.3%		

Grain Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.2	1.2	3.9	16.9	77.8	

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3"	100.0		
2"	100.0		
1.5"	100.0		
1"	100.0		
3/4"	100.0		
1/2"	100.0		
3/8"	100.0		
#4	99.8		
#10	98.6		
#20	96.9		
#40	94.7		
#60	92.0		
#100	87.8		
#200	77.8		

Material Description

Dark Gray Fly Ash

Atterberg Limits (ASTM D 4318)

PL= NP

LL= NP

PI= NP

Classification

USCS (D 2487)= ML

AASHTO (M 145)= A-4(0)

Coefficients

D₉₀= 0.1887

D₈₅= 0.1204

D₆₀=

D₅₀=

D₃₀=

D₁₅=

D₁₀=

C_u=

C_c=

Remarks

Date Received: 4-2-10

Date Tested: 4-8-10

Tested By: MC

Checked By:

Title:

* (no specification provided)

Source of Sample: Boring No.: APB-1
Sample Number: 2

Depth: 9.5'-11.0'

Date Sampled:

**MACTEC ENGINEERING.
AND CONSULTING, INC.**


Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report

PERCENT FINER



GRAIN SIZE - mm.

% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	2.4	3.4	23.6	27.8	42.8	

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3"	100.0		
2"	100.0		
1.5"	100.0		
1"	100.0		
3/4"	100.0		
1/2"	100.0		
3/8"	100.0		
#4	97.6		
#10	94.2		
#20	85.7		
#40	70.6		
#60	59.2		
#100	50.7		
#200	42.8		

Material Description

Light Reddish Brown Medium to Fine SAND with Silt

Atterberg Limits (ASTM D 4318)

PL= 29 LL= 46 PI= 17

Classification

USCS (D 2487)= SM AASHTO (M 145)= A-7-6(4)

Coefficients

D₉₀= 1.1532 D₈₅= 0.8159 D₆₀= 0.2608
D₅₀= 0.1425 D₃₀= C_u= D₁₅=
D₁₀= C_c=

Remarks

Date Received: 4-2-10

Date Tested: 4-8-10

Tested By: MC

Checked By:

Title:

* (no specification provided)

Source of Sample: Boring No.: APB-1
Sample Number: 4

Depth: 19.5'-21.0'

Date Sampled:

**MACTEC ENGINEERING.
AND CONSULTING, INC.**


Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report

PERCENT FINER



GRAIN SIZE - mm.

% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.0	1.7	24.5	32.8	41.0	

Test Results (ASTM D 422 & ASTM D 1140)

Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3"	100.0		
2"	100.0		
1.5"	100.0		
1"	100.0		
3/4"	100.0		
1/2"	100.0		
3/8"	100.0		
#4	100.0		
#10	98.3		
#20	89.3		
#40	73.8		
#60	61.2		
#100	50.4		
#200	41.0		

* (no specification provided)

Material Description

Light Reddish Brown Medium to Fine SAND with Silt

Atterberg Limits (ASTM D 4318)

PL= LL= PI=

Classification

USCS (D 2487)= SM AASHTO (M 145)=

Coefficients

D₉₀= 0.8835 D₈₅= 0.6829 D₆₀= 0.2378
D₅₀= 0.1465 D₃₀= C_u= D₁₅=
D₁₀= C_c=

Remarks

Date Received: 4-2-10

Date Tested: 4-8-10

Tested By: MC

Checked By:

Title:

Source of Sample: Boring No.: APB-1
Sample Number: 5

Depth: 29.5'-31.0'

Date Sampled:


**MACTEC ENGINEERING.
AND CONSULTING, INC.**

Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.2	1.2	17.4	25.8	55.4	

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3"	100.0		
2"	100.0		
1.5"	100.0		
1"	100.0		
3/4"	100.0		
1/2"	100.0		
3/8"	100.0		
#4	99.8		
#10	98.6		
#20	94.4		
#40	81.2		
#60	70.8		
#100	63.4		
#200	55.4		

* (no specification provided)

Material Description Light Reddish Brown SILT with Medium to Fine SAND		
Atterberg Limits (ASTM D 4318) PL= LL= PI=		
Classification USCS (D 2487)= ML AASHTO (M 145)=		
Coefficients D ₉₀ = 0.6484 D ₈₅ = 0.5070 D ₆₀ = 0.1132 D ₅₀ = D ₃₀ = D ₁₅ = D ₁₀ = C _u = C _c =		
Remarks		
Date Received: 4-2-10		Date Tested: 4-8-10
Tested By: MC		
Checked By:		
Title:		

Source of Sample: Boring No.: APB-1
Sample Number: 8

Depth: 44.5'-46.0'

Date Sampled:


**MACTEC ENGINEERING.
AND CONSULTING, INC.**

Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.9	1.1	15.6	50.0	32.4	

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3"	100.0		
2"	100.0		
1.5"	100.0		
1"	100.0		
3/4"	100.0		
1/2"	100.0		
3/8"	100.0		
#4	99.1		
#10	98.0		
#20	94.1		
#40	82.4		
#60	67.0		
#100	50.8		
#200	32.4		

* (no specification provided)

Material Description Light Reddish Brown Medium to Fine SAND with Silt		
Atterberg Limits (ASTM D 4318) PL= LL= PI=		
Classification USCS (D 2487)= SM AASHTO (M 145)=		
Coefficients D ₉₀ = 0.6186 D ₈₅ = 0.4753 D ₆₀ = 0.2014 D ₅₀ = 0.1460 D ₃₀ = D ₁₅ = D ₁₀ = C _u = C _c =		
Remarks		
Date Received: 4-2-10		Date Tested: 4-8-10
Tested By: MC		
Checked By:		
Title:		

Source of Sample: Boring No.: APB-1
Sample Number: 9

Depth: 49.5'-51.0'

Date Sampled:


**MACTEC ENGINEERING.
AND CONSULTING, INC.**

Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.0	0.5	15.2	53.3	31.0	

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3"	100.0		
2"	100.0		
1.5"	100.0		
1"	100.0		
3/4"	100.0		
1/2"	100.0		
3/8"	100.0		
#4	100.0		
#10	99.5		
#20	96.2		
#40	84.3		
#60	70.8		
#100	53.9		
#200	31.0		

* (no specification provided)

Material Description Light Brown medium to fine SAND with silt		
Atterberg Limits (ASTM D 4318) PL= LL= PI=		
Classification USCS (D 2487)= SM AASHTO (M 145)=		
Coefficients D ₉₀ = 0.5615 D ₈₅ = 0.4394 D ₆₀ = 0.1791 D ₅₀ = 0.1335 D ₃₀ = D ₁₅ = D ₁₀ = C _u = C _c =		
Remarks		
Date Received: 4-2-10		Date Tested: 4-8-10
Tested By: MC		
Checked By:		
Title:		

Source of Sample: Boring No.: APB-1
Sample Number: 11

Depth: 59.5'-61.0'

Date Sampled:


**MACTEC ENGINEERING.
AND CONSULTING, INC.**

Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	4.8	3.2	9.0	26.8	56.2	

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3"	100.0		
2"	100.0		
1.5"	100.0		
1"	100.0		
3/4"	100.0		
1/2"	100.0		
3/8"	97.8		
#4	95.2		
#10	92.0		
#20	87.6		
#40	83.0		
#60	78.1		
#100	70.2		
#200	56.2		

* (no specification provided)

Material Description	
Dark Gray Fly Ash	
Atterberg Limits (ASTM D 4318)	
PL= NP	LL= NP PI= NP
Classification	
USCS (D 2487)= ML	AASHTO (M 145)= A-4(0)
Coefficients	
D ₉₀ = 1.3231	D ₈₅ = 0.5602 D ₆₀ = 0.0899
D ₅₀ =	D ₃₀ = D ₁₅ =
D ₁₀ =	C _u = C _c =
Remarks	
Date Received: 4-2-10 Date Tested: 4-8-10	
Tested By: MC	
Checked By:	
Title:	

Source of Sample: Boring No.: APB-2
Sample Number: 1

Depth: 4.5'-6.0'

Date Sampled:

**MACTEC ENGINEERING.
AND CONSULTING, INC.**


Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report

PERCENT FINER



GRAIN SIZE - mm.

% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	3.9	4.8	11.5	23.4	56.4	

Test Results (ASTM D 422 & ASTM D 1140)

Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3"	100.0		
2"	100.0		
1.5"	100.0		
1"	100.0		
3/4"	100.0		
1/2"	100.0		
3/8"	100.0		
#4	96.1		
#10	91.3		
#20	85.3		
#40	79.8		
#60	75.4		
#100	69.6		
#200	56.4		

* (no specification provided)

Material Description

Dark Gray Fly Ash

Atterberg Limits (ASTM D 4318)

PL= NP LL= NP PI= NP

Classification

USCS (D 2487)= ML AASHTO (M 145)= A-4(0)

Coefficients

D₉₀= 1.6176 D₈₅= 0.8210 D₆₀= 0.0889
D₅₀= D₃₀= D₁₅=
D₁₀= C_u= C_c=

Remarks

Date Received: 4-2-10

Date Tested: 4-8-10

Tested By: MC

Checked By: _____

Title: _____

Source of Sample: Boring No.: APB-2
Sample Number: 2

Depth: 9.5'-11.0'

Date Sampled:


**MACTEC ENGINEERING.
AND CONSULTING, INC.**

Client: Southern Company
Project: Plant Yates Ash Pond


Project No: 6189109008

Jax FL.

Grain Size Distribution Report



Grain Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.0	2.8	21.4	28.6	47.2	

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3"	100.0		
2"	100.0		
1.5"	100.0		
1"	100.0		
3/4"	100.0		
1/2"	100.0		
3/8"	100.0		
#4	100.0		
#10	97.2		
#20	89.3		
#40	75.8		
#60	65.0		
#100	56.1		
#200	47.2		

* (no specification provided)

Material Description Orange Brown Medium to Fine SAND with Silt	
Atterberg Limits (ASTM D 4318) PL= 30 LL= 55 PI= 25	
Classification USCS (D 2487)= SM AASHTO (M 145)= A-7-5(8)	
Coefficients D ₉₀ = 0.8905 D ₈₅ = 0.6634 D ₆₀ = 0.1906 D ₅₀ = 0.0950 D ₃₀ = D ₁₅ = D ₁₀ = C _u = C _c =	
Remarks	
Date Received: 4-2-10 Date Tested: 4-8-10 Tested By: MC Checked By: _____ Title: _____	

Source of Sample: Boring No.: APB-2
Sample Number: 8

Date Sampled:


**MACTEC ENGINEERING.
AND CONSULTING, INC.**

Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.2	0.2	0.5	10.1	76.4	12.6

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3/8"	100.0		
#4	99.8		
#10	99.6		
#20	99.5		
#40	99.1		
#60	98.1		
#100	95.8		
#200	89.0		
0.0588 mm.	86.5		
0.0428 mm.	82.5		
0.0313 mm.	77.6		
0.0212 mm.	66.4		
0.0140 mm.	39.1		
0.0104 mm.	26.3		
0.0075 mm.	19.2		
0.0038 mm.	9.1		
0.0016 mm.	3.3		

* (no specification provided)

Material Description

Dark Gray Fly Ash

Atterberg Limits (ASTM D 4318)

PL= NP

LL= NP

PI= NP

Classification

USCS (D 2487)= ML

AASHTO (M 145)= A-4(0)

Coefficients

D₉₀= 0.0830

D₈₅= 0.0517

D₆₀= 0.0190

D₅₀= 0.0165

D₃₀= 0.0116

D₁₅= 0.0059

D₁₀= 0.0041

C_u= 4.61

C_c= 1.72

Remarks

Specific gravity: 2.174

Date Received: 4-2-10

Date Tested: 4-8-10

Tested By: MC

Checked By: _____

Title: _____

Source of Sample: Boring No.: APB-3
Sample Number: 2

Depth: 9.5'-11.0'

Date Sampled:


**MACTEC ENGINEERING.
AND CONSULTING, INC.**

Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.4	3.0	26.8	35.0	34.8	

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3/8"	100.0		
#4	99.6		
#10	96.6		
#20	85.8		
#40	69.8		
#60	56.7		
#100	45.3		
#200	34.8		

* (no specification provided)

Material Description	
Light Brown Medium to Fine SAND with Silt	
Atterberg Limits (ASTM D 4318)	
PL= 31	LL= 54 PI= 23
Classification	
USCS (D 2487)= SM	AASHTO (M 145)= A-2-7(3)
Coefficients	
D ₉₀ = 1.0875	D ₈₅ = 0.8158
D ₅₀ = 0.1879	D ₃₀ =
D ₁₀ =	C _u =
D ₆₀ = 0.2865	D ₁₅ =
	C _c =
Remarks	
Date Received: 4-2-10	Date Tested: 4-8-10
Tested By: MC	
Checked By: _____	
Title: _____	

Source of Sample: Boring No.: APB-3
Sample Number: 3

Depth: 14.5'-16.0'

Date Sampled:

**MACTEC ENGINEERING.
AND CONSULTING, INC.**


Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report

PERCENT FINER



GRAIN SIZE - mm.

% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	6.2	3.6	17.1	33.4	39.7	

Test Results (ASTM C 136 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3"	100.0		
2"	100.0		
1.5"	100.0		
1"	100.0		
3/4"	100.0		
1/2"	96.3		
3/8"	94.4		
#4	93.8		
#10	90.2		
#20	85.4		
#40	73.1		
#60	60.8		
#100	50.2		
#200	39.7		

* (no specification provided)

Material Description

Light Brown Medium to Fine SAND with Clay

Atterberg Limits (ASTM D 4318)

PL= 21 LL= 45 PI= 24

Classification

USCS (D 2487)= SC AASHTO (M 145)= A-7-6(5)

Coefficients

D₉₀= 1.9069 D₈₅= 0.8241 D₆₀= 0.2415
D₅₀= 0.1485 D₃₀= C_u= D₁₅=
D₁₀= C_c=

Remarks

Date Received: 4-2-10

Date Tested: 4-8-10

Tested By: MC

Checked By:

Title:

Source of Sample: Boring No.: APB-3
Sample Number: 6

Depth: 29.5'-31.0'

Date Sampled:


**MACTEC ENGINEERING.
AND CONSULTING, INC.**

Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.0	0.0	12.4	60.4	27.2	

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3"	100.0		
2"	100.0		
1.5"	100.0		
1"	100.0		
3/4"	100.0		
1/2"	100.0		
3/8"	100.0		
#4	100.0		
#10	100.0		
#20	98.8		
#40	87.6		
#60	67.3		
#100	46.3		
#200	27.2		

* (no specification provided)

Material Description Tan Medium to Fine SAND with Silt		
Atterberg Limits (ASTM D 4318) PL= LL= PI=		
Classification USCS (D 2487)= SM AASHTO (M 145)=		
Coefficients D ₉₀ = 0.4642 D ₈₅ = 0.3913 D ₆₀ = 0.2114 D ₅₀ = 0.1659 D ₃₀ = 0.0844 D ₁₅ = D ₁₀ = C _u = C _c =		
Remarks		
Date Received: 4-2-10		Date Tested: 4-8-10
Tested By: MC		
Checked By:		
Title:		

Source of Sample: Boring No.: APB-3
Sample Number: 8

Depth: 39.5'-41.0'

Date Sampled:

**MACTEC ENGINEERING.
AND CONSULTING, INC.**

Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.2	0.2	0.5	10.1	76.4	12.6

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3/8"	100.0		
#4	99.8		
#10	99.6		
#20	99.5		
#40	99.1		
#60	98.1		
#100	95.8		
#200	89.0		
0.0588 mm.	86.5		
0.0428 mm.	82.5		
0.0313 mm.	77.6		
0.0212 mm.	66.4		
0.0140 mm.	39.1		
0.0104 mm.	26.3		
0.0075 mm.	19.2		
0.0038 mm.	9.1		
0.0016 mm.	3.3		

* (no specification provided)

Material Description	
Dark Gray Fly Ash	
Atterberg Limits (ASTM D 4318)	
PL= NP	LL= NP PI= NP
Classification	
USCS (D 2487)= ML	AASHTO (M 145)= A-4(0)
Coefficients	
D ₉₀ = 0.0830	D ₈₅ = 0.0517 D ₆₀ = 0.0190
D ₅₀ = 0.0165	D ₃₀ = 0.0116 D ₁₅ = 0.0059
D ₁₀ = 0.0041	C _u = 4.61 C _c = 1.72
Remarks	
Specific gravity: 2.174	
Date Received: 4-2-10	Date Tested: 4-8-10
Tested By: MC	
Checked By: _____	
Title: _____	

Source of Sample: Boring No.: APB-3
Sample Number: 2

Depth: 9.5'-11.0'

Date Sampled:



**MACTEC ENGINEERING.
AND CONSULTING, INC.**

Client: Southern Company
Project: Plant Yates Ash Pond



Project No: 6189109008

Jax FL.

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	⊙	△	□	
Sample No.	IS-1	IS-1	IS-1	
Test No.	10101.1	10101.2	10101.3	
Depth	24.5-26.5ft	24.5-26.5ft	24.5-26.5ft	
Initial	Diameter, in	2.87	2.866	2.879
	Height, in	5.967	5.962	5.962
	Water Content, %	17.6	15.8	21.3
	Dry Density, pcf	110.4	115.	104.7
	Saturation, %	94.3	96.2	97.9
	Void Ratio	0.492	0.433	0.575
Before Shear	Water Content, %	18.3	16.3	19.1
	Dry Density, pcf	111.2	115.1	109.6
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.483	0.432	0.504
	Back Press., psi	99.99	120.	130.
Ver. Eff. Cons. Stress, psi		7.998	13.01	18.01
Shear Strength, psi		4.708	7.161	9.281
Strain at Failure, %		1.22	1.07	1.41
Strain Rate, %/min		0.05	0.05	0.05
B-Value		0.96	0.97	0.88
Measured Specific Gravity		2.64	2.64	2.64
Liquid Limit		43	43	43
Plastic Limit		21	21	21

	Project: Plant Yates Ash Pond	
	Location: APB-1	
	Project No.: 6189109008	
	Boring No.: APB-1	
	Sample Type: Undisturbed	
	Description: Brown Clayey Sand	
Remarks: ASTM D4767-04. Strain at failure based on peak excess pore pressure.		


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
⊙	IS-1	10101.1	24.5-26.5ft	JW	4/2/10			10101.1a_2580.dat
△	IS-1	10101.2	24.5-26.5ft	JW	4/2/10			10101.2a_2547.dat
□	IS-1	10101.3	24.5-26.5ft	JW	4/2/10			10101.3a_2546.dat

			
	Project: Plant Yates Ash Pond	Location: APB-1	Project No.: 6189109008
	Boring No.: APB-1	Sample Type: Undisturbed	
	Description: Brown Clayey Sand		
	Remarks: ASTM D4767-04. Strain at failure based on peak excess pore pressure.		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	○	△	□	
Sample No.	IS-1	IS-1	IS-1	
Test No.	10101.1	10101.2	10101.3	
Depth	24.5-26.5ft	24.5-26.5ft	24.5-26.5ft	
Initial	Diameter, in	2.87	2.866	2.879
	Height, in	5.967	5.962	5.962
	Water Content, %	17.6	15.8	21.3
	Dry Density, pcf	110.4	115.	104.7
	Saturation, %	94.3	96.2	97.9
	Void Ratio	0.492	0.433	0.575
Before Shear	Water Content, %	18.3	16.3	19.1
	Dry Density, pcf	111.2	115.1	109.6
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.483	0.432	0.504
	Back Press., psi	99.99	120.	130.
Ver. Eff. Cons. Stress, psi		7.998	13.01	18.01
Shear Strength, psi		4.708	7.161	9.281
Strain at Failure, %		1.22	1.07	1.41
Strain Rate, %/min		0.05	0.05	0.05
B-Value		0.96	0.97	0.88
Measured Specific Gravity		2.64	2.64	2.64
Liquid Limit		43	43	43
Plastic Limit		21	21	21

MACTEC	Project: Plant Yates Ash Pond	
	Location: APB-1	
	Project No.: 6189109008	
	Boring No.: APB-1	
	Sample Type: Undisturbed	
	Description: Brown Clayey Sand	
Remarks: ASTM D4767-04. Strain at failure based on peak excess pore pressure.		


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
○	IS-1	10101.1	24.5-26.5ft	JW	4/2/10			10101.1a_2580.dat
△	IS-1	10101.2	24.5-26.5ft	JW	4/2/10			10101.2a_2547.dat
□	IS-1	10101.3	24.5-26.5ft	JW	4/2/10			10101.3a_2546.dat

			
	Project: Plant Yates Ash Pond	Location: APB-1	Project No.: 6189109008
	Boring No.: APB-1	Sample Type: Undisturbed	
	Description: Brown Clayey Sand		
	Remarks: ASTM D4767-04. Strain at failure based on peak excess pore pressure.		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	⊙	△	□	
Sample No.	IS-1	IS-1	IS-1	
Test No.	10101.1	10101.2	10101.3	
Depth	24.5-26.5ft	24.5-26.5ft	24.5-26.5ft	
Initial	Diameter, in	2.87	2.866	2.879
	Height, in	5.967	5.962	5.962
	Water Content, %	17.6	15.8	21.3
	Dry Density, pcf	110.4	115.	104.7
	Saturation, %	94.3	96.2	97.9
	Void Ratio	0.492	0.433	0.575
Before Shear	Water Content, %	18.3	16.3	19.1
	Dry Density, pcf	111.2	115.1	109.6
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.483	0.432	0.504
	Back Press., psi	99.99	120.	130.
Ver. Eff. Cons. Stress, psi		7.998	13.01	18.01
Shear Strength, psi		16.26	19.66	16.45
Strain at Failure, %		16.8	16.5	16.2
Strain Rate, %/min		0.05	0.05	0.05
B-Value		0.96	0.97	0.88
Measured Specific Gravity		2.64	2.64	2.64
Liquid Limit		43	43	43
Plastic Limit		21	21	21

	Project: Plant Yates Ash Pond	
	Location: APB-1	
	Project No.: 6189109008	
	Boring No.: APB-1	
	Sample Type: Undisturbed	
	Description: Brown Clayey Sand	
Remarks: ASTM D4767-04.		


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
○	IS-1	10101.1	24.5-26.5ft	JW	4/2/10			10101.1a_2580.dat
△	IS-1	10101.2	24.5-26.5ft	JW	4/2/10			10101.2a_2547.dat
□	IS-1	10101.3	24.5-26.5ft	JW	4/2/10			10101.3a_2546.dat

			
	Project: Plant Yates Ash Pond	Location: APB-1	Project No.: 6189109008
	Boring No.: APB-1	Sample Type: Undisturbed	
	Description: Brown Clayey Sand		
	Remarks: ASTM D4767-04.		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	⊙	△	□	
Sample No.	IS-1	IS-1	IS-1	
Test No.	10101.1	10101.2	10101.3	
Depth	24.5-26.5ft	24.5-26.5ft	24.5-26.5ft	
Initial	Diameter, in	2.87	2.866	2.879
	Height, in	5.967	5.962	5.962
	Water Content, %	17.6	15.8	21.3
	Dry Density, pcf	110.4	115.	104.7
	Saturation, %	94.3	96.2	97.9
	Void Ratio	0.492	0.433	0.575
Before Shear	Water Content, %	18.3	16.3	19.1
	Dry Density, pcf	111.2	115.1	109.6
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.483	0.432	0.504
	Back Press., psi	99.99	120.	130.
Ver. Eff. Cons. Stress, psi		7.998	13.01	18.01
Shear Strength, psi		16.26	19.66	16.45
Strain at Failure, %		16.8	16.5	16.2
Strain Rate, %/min		0.05	0.05	0.05
B-Value		0.96	0.97	0.88
Measured Specific Gravity		2.64	2.64	2.64
Liquid Limit		43	43	43
Plastic Limit		21	21	21

	Project: Plant Yates Ash Pond	
	Location: APB-1	
	Project No.: 6189109008	
	Boring No.: APB-1	
	Sample Type: Undisturbed	
	Description: Brown Clayey Sand	
Remarks: ASTM D4767-04		


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
○	IS-1	10101.1	24.5-26.5ft	JW	4/2/10			10101.1a_2580.dat
△	IS-1	10101.2	24.5-26.5ft	JW	4/2/10			10101.2a_2547.dat
□	IS-1	10101.3	24.5-26.5ft	JW	4/2/10			10101.3a_2546.dat

			
	Project: Plant Yates Ash Pond	Location: APB-1	Project No.: 6189109008
	Boring No.: APB-1	Sample Type: Undisturbed	
	Description: Brown Clayey Sand		
	Remarks: ASTM D4767-04		




CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767




Symbol	⊙	△	□	
Sample No.	IS-1	IS-1	IS-1	
Test No.	10101.1	10101.2	10101.3	
Depth	24.5-26.5ft	24.5-26.5ft	24.5-26.5ft	
Initial	Diameter, in	2.87	2.866	2.879
	Height, in	5.967	5.962	5.962
	Water Content, %	17.6	15.8	21.3
	Dry Density, pcf	110.4	115.	104.7
	Saturation, %	94.3	96.2	97.9
	Void Ratio	0.492	0.433	0.575
Before Shear	Water Content, %	18.3	16.3	19.1
	Dry Density, pcf	111.2	115.1	109.6
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.483	0.432	0.504
	Back Press., psi	99.99	120.	130.
Ver. Eff. Cons. Stress, psi		7.998	13.01	18.01
Shear Strength, psi		16.26	19.66	16.45
Strain at Failure, %		16.8	16.5	16.2
Strain Rate, %/min		0.05	0.05	0.05
B-Value		0.96	0.97	0.88
Measured Specific Gravity		2.64	2.64	2.64
Liquid Limit		43	43	43
Plastic Limit		21	21	21

	Project: Plant Yates Ash Pond	
	Location: APB-1	
	Project No.: 6189109008	
	Boring No.: APB-1	
	Sample Type: Undisturbed	
	Description: Brown Clayey Sand	
Remarks: ASTM D4767-04		



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
○	IS-1	10101.1	24.5-26.5ft	JW	4/2/10			10101.1a_2580.dat
△	IS-1	10101.2	24.5-26.5ft	JW	4/2/10			10101.2a_2547.dat
□	IS-1	10101.3	24.5-26.5ft	JW	4/2/10			10101.3a_2546.dat

			
	Project: Plant Yates Ash Pond	Location: APB-1	Project No.: 6189109008
	Boring No.: APB-1	Sample Type: Undisturbed	
	Description: Brown Clayey Sand		
	Remarks: ASTM D4767-04		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	⊙	Δ		
Sample No.	IS-1	IS-1		
Test No.	10102.2	10102.3		
Depth	7.9-9.5 ft	7.5-9.5 ft		
Initial	Diameter, in	2.846	2.866	
	Height, in	5.995	5.934	
	Water Content, %	30.3	33.9	
	Dry Density, pcf	62.58	56.72	
	Saturation, %	55.5	52.1	
Before Shear	Void Ratio	1.21	1.44	
	Water Content, %	49.9	51.7	
	Dry Density, pcf	65.73	64.52	
	Saturation*, %	100.0	100.0	
	Void Ratio	1.11	1.15	
	Back Press., psi	140.	134.	
	Ver. Eff. Cons. Stress, psi	5.014	7.	
	Shear Strength, psi	3.41	1.682	
	Strain at Failure, %	17	1.52	
	Strain Rate, %/min	0.05	0.05	
	B-Value	0.86	0.95	
	Measured Specific Gravity	2.22	2.22	
	Liquid Limit	NP	NP	
	Plastic Limit	NP	NP	

MACTEC	Project: Plant Yates Ash Pond	
	Location: APB-2	
	Project No.: 6189109008	
	Boring No.: APB-2	
	Sample Type: Undisturbed	
	Description: Dark Gray Sandy Silt (Fly Ash)	
	Remarks: ASTM D4767-04	


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
⊙	IS-1	10102.2	7.9-9.5 ft	JW	4/6/10			10102.2_2546.dat
Δ	IS-1	10102.3	7.5-9.5 ft	JW	4/6/10			10102.3_2547.dat

 MACTEC			
	Project: Plant Yates Ash Pond	Location: APB-2	Project No.: 6189109008
	Boring No.: APB-2	Sample Type: Undisturbed	
	Description: Dark Gray Sandy Silt (Fly Ash)		
	Remarks: ASTM D4767-04		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	⊙	Δ		
Sample No.	IS-1	IS-1		
Test No.	10102.2	10102.3		
Depth	7.9-9.5 ft	7.5-9.5 ft		
Initial	Diameter, in	2.846	2.866	
	Height, in	5.995	5.934	
	Water Content, %	30.3	33.9	
	Dry Density, pcf	62.58	56.72	
	Saturation, %	55.5	52.1	
Before Shear	Void Ratio	1.21	1.44	
	Water Content, %	49.9	51.7	
	Dry Density, pcf	65.73	64.52	
	Saturation*, %	100.0	100.0	
	Void Ratio	1.11	1.15	
	Back Press., psi	140.	134.	
	Ver. Eff. Cons. Stress, psi	5.014	7.	
	Shear Strength, psi	3.41	1.682	
	Strain at Failure, %	17	1.52	
	Strain Rate, %/min	0.05	0.05	
	B-Value	0.86	0.95	
	Measured Specific Gravity	2.22	2.22	
	Liquid Limit	NP	NP	
	Plastic Limit	NP	NP	

	Project: Plant Yates Ash Pond	
	Location: APB-2	
	Project No.: 6189109008	
	Boring No.: APB-2	
	Sample Type: Undisturbed	
	Description: Dark Gray Sandy Silt (Fly Ash)	
	Remarks: ASTM D4767-04	


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
○	IS-1	10102.2	7.9-9.5 ft	JW	4/6/10			10102.2_2546.dat
△	IS-1	10102.3	7.5-9.5 ft	JW	4/6/10			10102.3_2547.dat

 MACTEC			
	Project: Plant Yates Ash Pond	Location: APB-2	Project No.: 6189109008
	Boring No.: APB-2	Sample Type: Undisturbed	
	Description: Dark Gray Sandy Silt (Fly Ash)		
	Remarks: ASTM D4767-04		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	⊙	Δ		
Sample No.	IS-1	IS-1		
Test No.	10102.2	10102.3		
Depth	7.9-9.5 ft	7.5-9.5 ft		
Initial	Diameter, in	2.846	2.866	
	Height, in	5.995	5.934	
	Water Content, %	30.3	33.9	
	Dry Density, pcf	62.58	56.72	
	Saturation, %	55.5	52.1	
Before Shear	Void Ratio	1.21	1.44	
	Water Content, %	49.9	51.7	
	Dry Density, pcf	65.73	64.52	
	Saturation*, %	100.0	100.0	
	Void Ratio	1.11	1.15	
	Back Press., psi	140.	134.	
	Ver. Eff. Cons. Stress, psi	5.014	7.	
	Shear Strength, psi	3.41	1.682	
	Strain at Failure, %	17	1.52	
	Strain Rate, %/min	0.05	0.05	
	B-Value	0.86	0.95	
	Measured Specific Gravity	2.22	2.22	
	Liquid Limit	NP	NP	
	Plastic Limit	NP	NP	

	Project: Plant Yates Ash Pond	
	Location: APB-2	
	Project No.: 6189109008	
	Boring No.: APB-2	
	Sample Type: Undisturbed	
	Description: Dark Gray Sandy Silt (Fly Ash)	
Remarks: ASTM D4767-04		


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767





	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
⊙	IS-1	10102.2	7.9-9.5 ft	JW	4/6/10			10102.2_2546.dat
Δ	IS-1	10102.3	7.5-9.5 ft	JW	4/6/10			10102.3_2547.dat

			
	Project: Plant Yates Ash Pond	Location: APB-2	Project No.: 6189109008
	Boring No.: APB-2	Sample Type: Undisturbed	
	Description: Dark Gray Sandy Silt (Fly Ash)		
	Remarks: ASTM D4767-04		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	⊙	△	□	
Sample No.	IS-1	IS-1	IS-1	
Test No.	10103.1	10103.2	10103.3	
Depth	7.5-19.5ft	7.5-19.5ft	7.5-19.5ft	
Initial	Diameter, in	2.875	2.864	2.857
	Height, in	5.958	5.958	5.953
	Water Content, %	20.7	21.8	27.4
	Dry Density, pcf	101.1	103.1	95.56
	Saturation, %	87.9	97.6	100.7
	Void Ratio	0.618	0.586	0.712
Before Shear	Water Content, %	22.4	22.1	27.0
	Dry Density, pcf	103.1	103.6	95.74
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.587	0.579	0.708
	Back Press., psi	140.	116.	108.
Ver. Eff. Cons. Stress, psi		4.996	7.996	12.
Shear Strength, psi		3.423	4.974	6.643
Strain at Failure, %		0.93	1.13	1.87
Strain Rate, %/min		0.05	0.05	0.05
B-Value		0.97	0.96	0.97
Measured Specific Gravity		2.62	2.62	2.62
Liquid Limit		42	42	42
Plastic Limit		25	25	25

	Project: Plant Yates Ash Pond	
	Location: APB-3	
	Project No.: 6189109008	
	Boring No.: APB-3	
	Sample Type: Undisturbed	
	Description: Brown Clayey Sand	
	Remarks: ASTM D4767-04. Strains at failure based on peak excess pore pressure.	


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
○	IS-1	10103.1	17.5-19.5ft	JW	4/8/10			10103.1_2581.dat
△	IS-1	10103.2	17.5-19.5ft	JW	4/8/10			10103.2_2582.dat
□	IS-1	10103.3	17.5-19.5ft	JW	4/8/10			10103.3_2583.dat

 MACTEC			
	Project: Plant Yates Ash Pond	Location: APB-3	Project No.: 6189109008
	Boring No.: APB-3	Sample Type: Undisturbed	
	Description: Brown Clayey Sand		
	Remarks: ASTM D4767-04. Strains at failure based on peak excess pore pressure.		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	⊙	△	□	
Sample No.	IS-1	IS-1	IS-1	
Test No.	10103.1	10103.2	10103.3	
Depth	7.5-19.5ft	7.5-19.5ft	7.5-19.5ft	
Initial	Diameter, in	2.875	2.864	2.857
	Height, in	5.958	5.958	5.953
	Water Content, %	20.7	21.8	27.4
	Dry Density, pcf	101.1	103.1	95.56
	Saturation, %	87.9	97.6	100.7
	Void Ratio	0.618	0.586	0.712
Before Shear	Water Content, %	22.4	22.1	27.0
	Dry Density, pcf	103.1	103.6	95.74
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.587	0.579	0.708
	Back Press., psi	140.	116.	108.
Ver. Eff. Cons. Stress, psi		4.996	7.996	12.
Shear Strength, psi		3.423	4.974	6.643
Strain at Failure, %		0.93	1.13	1.87
Strain Rate, %/min		0.05	0.05	0.05
B-Value		0.97	0.96	0.97
Measured Specific Gravity		2.62	2.62	2.62
Liquid Limit		42	42	42
Plastic Limit		25	25	25

MACTEC	Project: Plant Yates Ash Pond	
	Location: APB-3	
	Project No.: 6189109008	
	Boring No.: APB-3	
	Sample Type: Undisturbed	
	Description: Brown Clayey Sand	
Remarks: ASTM D4767-04. Strains at failure based on peak excess pore pressure.		


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
○	IS-1	10103.1	17.5-19.5ft	JW	4/8/10			10103.1_2581.dat
△	IS-1	10103.2	17.5-19.5ft	JW	4/8/10			10103.2_2582.dat
□	IS-1	10103.3	17.5-19.5ft	JW	4/8/10			10103.3_2583.dat

			
	Project: Plant Yates Ash Pond	Location: APB-3	Project No.: 6189109008
	Boring No.: APB-3	Sample Type: Undisturbed	
	Description: Brown Clayey Sand		
	Remarks: ASTM D4767-04. Strains at failure based on peak excess pore pressure.		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	⊙	△	□	
Sample No.	IS-1	IS-1	IS-1	
Test No.	10103.1	10103.2	10103.3	
Depth	17.5-19.5ft	17.5-19.5ft	17.5-19.5ft	
Initial	Diameter, in	2.875	2.864	2.857
	Height, in	5.958	5.958	5.953
	Water Content, %	20.7	21.8	27.4
	Dry Density, pcf	101.1	103.1	95.56
	Saturation, %	87.9	97.6	100.7
Before Shear	Void Ratio	0.618	0.586	0.712
	Water Content, %	22.4	22.1	27.0
	Dry Density, pcf	103.1	103.6	95.74
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.587	0.579	0.708
	Back Press., psi	140.	116.	108.
	Ver. Eff. Cons. Stress, psi	4.996	7.996	12.
	Shear Strength, psi	15.12	12.47	12.76
	Strain at Failure, %	17	17	17
	Strain Rate, %/min	0.05	0.05	0.05
	B-Value	0.97	0.96	0.97
	Measured Specific Gravity	2.62	2.62	2.62
	Liquid Limit	42	42	42
	Plastic Limit	25	25	25

MACTEC	Project: Plant Yates Ash Pond	
	Location: APB-3	
	Project No.: 6189109008	
	Boring No.: APB-3	
	Sample Type: Undisturbed	
	Description: Brown Clayey Sand	
	Remarks: ASTM D4767-04.	


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
○	IS-1	10103.1	17.5-19.5ft	JW	4/8/10			10103.1_2581.dat
△	IS-1	10103.2	17.5-19.5ft	JW	4/8/10			10103.2_2582.dat
□	IS-1	10103.3	17.5-19.5ft	JW	4/8/10			10103.3_2583.dat

 MACTEC			
	Project: Plant Yates Ash Pond	Location: APB-3	Project No.: 6189109008
	Boring No.: APB-3	Sample Type: Undisturbed	
	Description: Brown Clayey Sand		
	Remarks: ASTM D4767-04.		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	⊙	△	□	
Sample No.	IS-1	IS-1	IS-1	
Test No.	10103.1	10103.2	10103.3	
Depth	7.5-19.5ft	7.5-19.5ft	7.5-19.5ft	
Initial	Diameter, in	2.875	2.864	2.857
	Height, in	5.958	5.958	5.953
	Water Content, %	20.7	21.8	27.4
	Dry Density, pcf	101.1	103.1	95.56
	Saturation, %	87.9	97.6	100.7
Before Shear	Void Ratio	0.618	0.586	0.712
	Water Content, %	22.4	22.1	27.0
	Dry Density, pcf	103.1	103.6	95.74
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.587	0.579	0.708
	Back Press., psi	140.	116.	108.
	Ver. Eff. Cons. Stress, psi	4.996	7.996	12.
	Shear Strength, psi	15.12	12.47	12.76
	Strain at Failure, %	17	17	17
	Strain Rate, %/min	0.05	0.05	0.05
	B-Value	0.97	0.96	0.97
	Measured Specific Gravity	2.62	2.62	2.62
	Liquid Limit	42	42	42
	Plastic Limit	25	25	25

	Project: Plant Yates Ash Pond	
	Location: APB-3	
	Project No.: 6189109008	
	Boring No.: APB-3	
	Sample Type: Undisturbed	
	Description: Brown Clayey Sand	
Remarks: ASTM D4767-04		


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
○	IS-1	10103.1	17.5-19.5ft	JW	4/8/10			10103.1_2581.dat
△	IS-1	10103.2	17.5-19.5ft	JW	4/8/10			10103.2_2582.dat
□	IS-1	10103.3	17.5-19.5ft	JW	4/8/10			10103.3_2583.dat

			
	Project: Plant Yates Ash Pond	Location: APB-3	Project No.: 6189109008
	Boring No.: APB-3	Sample Type: Undisturbed	
	Description: Brown Clayey Sand		
	Remarks: ASTM D4767-04		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	⊙	△	□	
Sample No.	IS-1	IS-1	IS-1	
Test No.	10103.1	10103.2	10103.3	
Depth	7.5-19.5ft	7.5-19.5ft	7.5-19.5ft	
Initial	Diameter, in	2.875	2.864	2.857
	Height, in	5.958	5.958	5.953
	Water Content, %	20.7	21.8	27.4
	Dry Density, pcf	101.1	103.1	95.56
	Saturation, %	87.9	97.6	100.7
Before Shear	Void Ratio	0.618	0.586	0.712
	Water Content, %	22.4	22.1	27.0
	Dry Density, pcf	103.1	103.6	95.74
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.587	0.579	0.708
	Back Press., psi	140.	116.	108.
	Ver. Eff. Cons. Stress, psi	4.996	7.996	12.
	Shear Strength, psi	15.12	12.47	12.76
	Strain at Failure, %	17	17	17
	Strain Rate, %/min	0.05	0.05	0.05
	B-Value	0.97	0.96	0.97
	Measured Specific Gravity	2.62	2.62	2.62
	Liquid Limit	42	42	42
	Plastic Limit	25	25	25

MACTEC	Project: Plant Yates Ash Pond	
	Location: APB-3	
	Project No.: 6189109008	
	Boring No.: APB-3	
	Sample Type: Undisturbed	
	Description: Brown Clayey Sand	
Remarks: ASTM D4767-04		


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
○	IS-1	10103.1	17.5-19.5ft	JW	4/8/10			10103.1_2581.dat
△	IS-1	10103.2	17.5-19.5ft	JW	4/8/10			10103.2_2582.dat
□	IS-1	10103.3	17.5-19.5ft	JW	4/8/10			10103.3_2583.dat

			
	Project: Plant Yates Ash Pond	Location: APB-3	Project No.: 6189109008
	Boring No.: APB-3	Sample Type: Undisturbed	
	Description: Brown Clayey Sand		
	Remarks: ASTM D4767-04		

Attachment D – Critical Section Profile Used in Analysis

F


E

D


C

B


A




SECTION A-Ash Pond 1
Vertical Scale: 1" = 20'
Horizontal Scale: 1" = 100'




SECTION B-Ash Pond 2
Vertical Scale: 1" = 20'
Horizontal Scale: 1" = 20'



SECTION C-Ash Pond 3
Vertical Scale: 1" = 20'
Horizontal Scale: 1" = 20'



SECTION D-Ash Pond A
Vertical Scale: 1" = 20'
Horizontal Scale: 1" = 20'



SECTION E-Ash Pond B'
Vertical Scale: 1" = 20'
Horizontal Scale: 1" = 20'

© Copyright 2007, Southern Company Services, Inc. All Rights Reserved. <small>This document contains proprietary, confidential, and/or trade secret information of the subsidiaries of The Southern Company or of third parties. It is intended for use only by employees of, or authorized contractors of, the subsidiaries of the Southern Company. Unauthorized possession, use, distribution, copying, dissemination, or disclosure of any portion hereof is prohibited.</small>				
Southern Company Generation Engineering and Construction Services FOR				
Georgia Power Company				
PLANT YATES ASH POND DIKE CROSS SECTIONS				
SCALE	PRJ. I.D.	DRAWING NUMBER	SHEET	CONT'D
AS SHOWN		ES1836S1B	1B	FINAL