

PERIODIC SAFETY FACTOR ASSESSMENT
391-3-4-.10(4) and 40 C.F.R. PART 257.73
PLANT YATES ASH POND 2 (AP-2)
GEORGIA POWER COMPANY

The Federal CCR Rule, and, for Existing Surface Impoundments where applicable, the Georgia CCR Rule (391-3-4-.10) require the owner or operator of a CCR surface impoundment to conduct initial and periodic safety factor assessments. *See* 40 C.F.R. § 257.73(e); Ga. Comp. R. & Regs. r. 391.3-4-.10(4)(b)¹. The owner or operator must conduct an assessment of the CCR unit and document that the minimum safety factors outlined in § 257.73(e)(1)(i) through (iv) for the critical embankment section are achieved. In addition, the Rules require a subsequent assessment be performed within 5 years of the previous assessment. *See* 40 C.F.R. § 257.73(f)(3); Ga. Comp. R. & Regs. r. 391.3-4-.10(4)(b)¹.

The CCR surface impoundment known as Plant Yates AP-2 is located on Plant Yates property, northwest of Newnan, Georgia. AP-2 is formed by an engineered cross-valley embankment. The critical section of AP-2 was previously determined to be at the midpoint of the cross-valley embankment. Under current conditions, the midpoint of the embankment remains the critical section. The Notification of Intent to Initiate Closure was placed in the Operating Record on 04/17/2019 and closure has been designed to have no negative impacts on the stability of the perimeter embankment. AP-2 is currently undergoing closure-by-removal, and all CCR has been removed from against the embankment and the unit no longer impounds water against the embankment on a regular basis, only containing periodic limited amounts of water after periods of rain. As a result, a long-term maximum storage pool analysis is no longer applicable.

The analyses used to determine the minimum safety factor for the critical section resulted in the following minimum safety factors:


Loading Condition	Minimum Calculated Safety Factor	Minimum Required Safety Factor
Maximum Surcharge Pool (Static)	1.9	1.4
Seismic	1.7	1.0

The embankment of AP-2 is constructed of compacted clayey and silty sands that are not susceptible to liquefaction. Therefore, a minimum liquefaction safety factor determination was not required.

^[1] In a typographical error, 391.3-4.10(4)(b) references the “structural integrity criteria in 40 CFR 247.73,” when the reference to such criteria should be 40 CFR 257.73.

This assessment is supported by appropriate engineering calculations which are attached.

I hereby certify that the safety factor assessment was conducted in accordance with 40 C.F.R. Part 257.73 (e)(1).





Technical and Project Solutions Calculation

Calculation Number:
TV-YT-GPC1142841-001

Project/Plant: Plant Yates	Unit(s): 6-7	Discipline/Area: Env. Solutions
Title/Subject: Periodic Factor of Safety Assessment for CCR Rule		
Purpose/Objective: Determine the Factor of Safety of the Ash Pond 2 Dike		
System or Equipment Tag Numbers: n/a	Originator: Jacob A. Jordan, P.E.	

Contents

Topic	Page	Attachments (Computer Printouts, Tech. Papers, Sketches, Correspondence)	# of Pages
Purpose of Calculation	2	Attachment A - Boring Location Plan	1
Summary of Conclusions	2	Attachment B - Boring and Piezometer Logs	9
Methodology	2	Attachment C - Laboratory Analyses	42
Criteria and Assumptions	2	Attachment D - Critical Section Profile Used in Analysis	1
Loading Conditions	4		
Design Inputs/References	4		
Body of Calculation	5-7		
Total # of pages including cover sheet & attachments:	64		

Revision Record

Rev. No.	Description	Originator Initial / Date	Reviewer Initial / Date	Approver Initial / Date
0	Issued for Information	JAJ/06-18-21	JCP/06-18-21	JCP/06-18-21

Notes:

Purpose of Calculation

The Eugene A. Yates Power Plant (Plant Yates) was once a seven-unit, coal fired, power generation facility. Units 1-5 have been demolished and Units 6 and 7 have been converted to natural gas. Ash Pond 2, constructed 1966 to 1967, was designed to receive and store coal combustion residuals produced during the electric power generating. Plant Yates ceased burning coal in 2015 and thus ceased sluicing ash to Ash Pond 2 at that time.

The purpose of this calculation is to provide an updated slope stability factor of safety assessment of the Plant Yates Ash Pond 2 dam under conditions prescribed by the EPA CCR rule.

Summary of Conclusions

The following table summarizes the factors of safety resulting from the slope stability analyses. The results indicate the safety factors of the Ash Pond 2 dam meet or exceed the minimum criteria set forth in the structural integrity criteria for existing CCR surface impoundments, 40 CFR 257.73.

Factor of Safety Summary Table

Loading Condition	Minimum Calculated Safety Factor	Minimum Required Safety Factor
Maximum Surcharge Pool (Static)	1.9	1.4
Seismic	1.7	1.0

Methodology

The calculation was performed using the following methods and software:

- GeoStudio 2021 R2 version 11.1.1.22085 Copyright 1991-2021, GEO-SLOPE International, Ltd.
- Strata (Version 0.8.0), University of Texas, Austin
- Morgenstern-Price analytical method

Criteria and Assumptions

The slope stability models were run using the following assumptions and design criteria:

- Seismic site response was determined using a one-dimensional equivalent linear site response analysis. The analysis was performed using Strata and utilizing random vibration theory. The input motion consisted of the USGS published 2014 Uniform Hazard Response Spectrum (UHRS) for Site Class B/C at a 2% Probability of Exceedance in 50 years. The UHRS was converted to a Fourier Amplitude Spectrum, and propagated through a representative one-dimensional soil column using linear wave propagation with strain-dependent dynamic soil properties. The input soil properties and layer thickness were

randomized based on defined statistical distributions to perform Monte Carlo simulations for 100 realizations, which were used to generate a median estimate of the surface ground motions.

- The median surface ground motions were then used to calculate a pseudostatic seismic coefficient for utilization in the stability analysis using the approach suggested by Bray and Tavasrou (2009). The procedure calculates the seismic coefficient for an allowable seismic displacement and a probability exceedance of the displacement. For this analysis, an allowable displacement of 0.5 ft, and a probability of exceedance of 16% were conservatively selected, providing a seismic coefficient of 0.038g for use as a horizontal acceleration in the stability analysis.
- The current required minimum criteria (factors of safety) were taken from the Structural Integrity Criteria for existing CCR surface impoundment from 40 CFR 257.73, published April 17, 2015.
- During March 2010, seven borings and five piezometers were performed and installed, respectively, on the crest of the dam, on the middle bench of the dam and on the riverbank.
- The soil properties used for the analysis (unit weight, phi angle, and cohesion) were obtained from triaxial shear testing performed on undisturbed Shelby tube samples of the dam fill and foundation soils obtained during drilling. Soil testing was performed according to applicable ASTM standards
- The COE EM 1110-2-1902, October 2003, allows the use of the phreatic surface established for the maximum storage condition (normal pool) in the analysis for the maximum surcharge loading condition. This is based on the short-term duration of the surcharge loading relative to the permeability of the embankment and the foundation materials.
- The ash pond is no longer designed to store water; therefore the maximum storage condition was not evaluated for this analysis. Stormwater may pool behind the dike during periods of elevated rainfall amounts. The maximum surcharge condition was evaluated using a maximum pool elevation of EL 717.6 ft, based on the design storm.
- The critical section was selected at location having the apparent maximum dam height. The cross-section of the Ash Pond 2 dam was modeled using the following sources:
 - A 2010 level profile survey extending from the pond surface on the upstream face of the dam to the river surface on the downstream face of the dam performed by Southern Company Services (SCS)
 - Historical drawing H-183, showing the profile of the dam raise that created the current configuration of the AP-2 dam, was used to model the upstream face of the dam.
- All CCR has been removed from the area between the AP-2 embankment and the temporary cofferdam constructed at the approximate middle of AP-2. Therefore, there is no CCR included or considered in the analysis.

Input Data

Ash Pond

Two consolidated, undrained triaxial strength tests were performed on Shelby tube samples recovered from borings performed at Ash Pond 2 to provide total and effective shear strength values of embankment and foundation soils. Soil classification testing, unit weight, and moisture content determination were also performed on the samples. The results of the laboratory analysis are included in attachments to this calculation. The following effective stress values were used in the analyses.

Soil Properties Table

Soil Description	Unit Weight, pcf	Effective Stress Parameters	
		Cohesion, psf	Phi Angle, degrees
Dam Fill	125	144	32
Soft ML and MH	118	130	30
Medium Dense Residuum	125	144	35
Soft Clayey Sand	125	15	28

Phreatic Surface

Piezometers were installed at the following locations:

- Dike Crest – one was installed in the dam fill and one was installed in the foundation soils.
- Bench – one was installed in the dam fill and one was installed in the foundation soils.
- Dike Toe – one was installed in the foundation material.

Loading Conditions

The Plant Yates Ash Pond 2 Dike was evaluated for the maximum surcharge and seismic loading conditions.

Design Inputs/References

- SCS Calculation TV-YT-GPC603884-001
- Idriss and Boulanger, *Semi-empirical procedures for evaluating liquefaction potential during earthquakes*, 2004
- Youd and Idriss, *Liquefaction Resistance of Soils: Summary report from the 1996 NCEER and 1998 NCEER/NSF Workshops on evaluation of liquefaction resistance of soils*, 2001

- Bray, J. D. and Travasarou, T., *Pseudostatic Coefficient for Use in Simplified Seismic Slope Stability Evaluation*, Journal of Geotechnical and Environmental Engineering, American Society of Civil Engineers, September 2009
- GPC Drawing H-183, Dike Addition Plan and Profile Sections
- SCS Drawing ES1836S1A - Pond and Cross-section Layouts
- SCS Drawing ES1836S1B – Plant Yates Ash Pond Dike Cross-Sections
- SCS ES1836S2 Piezometer and Boring Layout
- SCS 2010 Boring and Piezometer Logs
- GPC Drawing - Yates Ash Pond No. 2, April 2014 Survey
- 2016 TRC-Yates Closures FINAL AP2 ash
- 2010 Laboratory Analyses

Body of Calculation

Slope/W analysis attached.

PLANT YATES
ASH POND 2
Maximum Surcharge

Materials


Dike Fill (Clayey Sand/Silty Sand)

Medium Dense Residuum

Rock

Soft Clayey Sand

Soft ML and MH



PLANT YATES

ASH POND 2

Seismic
Horizontal Seismic Coefficient.: 0.038

- Materials**
- Dike Fill (Clayey Sand/Silty Sand)
 - Medium Dense Residuuum
 - Rock
 - Soft Clayey Sand
 - Soft ML and MH


Name: Dike Fill (Clayey Sand/Silty Sand)
Unit Weight: 125 pcf
Effective Cohesion: 144 psf
Effective Friction Angle: 32 °
Piezometric Line: 1

Name: Medium Dense Residuuum
Unit Weight: 125 pcf
Effective Cohesion: 144 psf
Effective Friction Angle: 35 °
Piezometric Line: 1

Name: Rock
Piezometric Line: 1

Name: Soft Clayey Sand
Unit Weight: 125 pcf
Effective Cohesion: 15 psf
Effective Friction Angle: 28 °
Piezometric Line: 1



Name: Soft ML and MH
Unit Weight: 118 pcf
Effective Cohesion: 130 psf
Effective Friction Angle: 30 °
Piezometric Line: 1



Attachment A

Boring Location Plan

F
E
D
C
B
A



- LEGEND:**
- BORING
 - PIEZOMETER

Southern Company Services, Inc. ©Copyright 2010, Southern Company Services, Inc. All Rights Reserved. <small>This document contains proprietary, confidential, and/or trade secret information of the subsidiaries of The Southern Company or of third parties. It is intended for use only by employees of, or authorized contractors of, the subsidiaries of The Southern Company. Unauthorized possession, use, distribution, copying, dissemination, or disclosure of any portion hereof is prohibited.</small>				
Southern Company Generation Engineering and Construction Services FOR				
Georgia Power Company				
PLANT YATES PIEZOMETER & BORING LOCATIONS				
SCALE	PROJ. I.D.	DRAWING NUMBER	SHEET	CONT'D
AS SHOWN		ES1836S2	2	FINAL

Attachment B

Boring and Piezometer Logs



LOG OF TEST BORING

BORING AP2-1 deep
PAGE 1 OF 2

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Plant Yates Ash Pond Dike Stability

LOCATION Whitesburg, Ga

DATE STARTED 3/8/2010 **COMPLETED** 3/8/2010 **SURF. ELEV.** 729.4 **COORDINATES:** N 1,259,231.10 E 2,070,344.54

CONTRACTOR SCS Field Services **EQUIPMENT** CME 55 **METHOD** Hollow Stem Auger

DRILLED BY T. Milam **LOGGED BY** R. Mudd **CHECKED BY** **ANGLE** **BEARING**

BORING DEPTH 54.9 ft. **GROUND WATER DEPTH: DURING** **COMP.** **DELAYED** 30.8 ft. after 240 hrs.

NOTES Top of Ash Pond 2, Deep well Well installed. Refer to well data sheet.

DEPTH (ft.)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	SAMPLE TYPE NUMBER	SAMPLE DEPTH (ft.)	BLOW COUNTS (N VALUE)	RECOVERY % (RQD)	COMMENTS
5		Silty Sand (SM) - red and dark brown, dry, fine to medium grain, <i>fill</i> , with medium to large micaceous pebbles in sample		SS -1	4.5-6.0	3-6-6 (12)		
10		- slightly moist, <i>fill</i>		SS -2	9.5-11.0	2-3-5 (8)		(MC = 18.4%; LL=51; PI=10; FC = 29.3%; Gravel = 9.3%)
15				SS -3	14.5-16.0	2-5-4 (9)		
20				SS -4	19.5-21.0	3-5-7 (12)		
25		Clayey Sand (SC) - gray and red, moist, dense, fine to medium grain, Top of sample is gray and red, while bottom is red. Probable fill to residuum transition.	704.9	SS -5	24.5-26.0	4-11-17 (28)		
30		Clayey Sand (SC) - gray, very moist, medium dense, medium grain, <i>residuum</i>	699.9	SS -6	29.5-31.0	4-9-9 (18)		(MC = 16.7%; LL=34; PI=11; FC = 32.9%; Gravel = 2.5%)
35		- micaceous, more clay than above		SS -7	34.5-36.0	6-6-10 (16)		

(Continued Next Page)

GEOTECH ENGINEERING LOGS - ESEE DATABASE GDT - 09/20/10 10:41 - T:\ESEE MAJOR PROJECTS\PROJECTS\YATES 2010\ES1836 EPA ASH POND INSPECTIONS\BORING INFORMATION\YATES ASH POND DIKES.GPJ



LOG OF TEST BORING

BORING AP2-1 deep
PAGE 2 OF 2

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Plant Yates Ash Pond Dike Stability

LOCATION Whitesburg, Ga

DEPTH (ft)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	SAMPLE TYPE NUMBER	SAMPLE DEPTH (ft.)	BLOW COUNTS (N VALUE)	RECOVERY % (RQD)	COMMENTS
40		Silt (ML) - reddish light brown, moist, soft, high plasticity	689.9	SS -8	39.5- 41.0	WH-WH-2 (2)		(MC = 30.7%; LL=45; PI=15; FC = 87.6%)
				UD -1	42.0- 44.0		80	
45				UD -2	44.0- 46.0		100	
50		Elastic Silt (MH) - dark black, wet, soft, medium to high plasticity	679.9	SS -9	49.5- 51.0	WH-WH-2 (2)		(MC = 48.7%; LL=71; PI=24; FC = 79.1%)
55		(GW) Bottom of borehole at 54.9 feet.	674.9 674.5	SS -10	54.5- 54.9	50/5" (100+)		Auger Refusal.
60								
65								
70								
75								
80								
85								

GEOTECH ENGINEERING LOGS - ESEE DATABASE GDT - 09/20/10 10:41 - T:\ESEE MAJOR PROJECTS\PROJECTS\YATES\2010\ES1836 EPA ASH POND INSPECTIONS\BORING INFORMATION\YATES ASH POND DIKES.GPJ



LOG OF TEST BORING

BORING AP2-1 shallow
PAGE 1 OF 1

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Plant Yates Ash Pond Dike Stability
LOCATION Whitesburg, Ga

DATE STARTED 3/9/2010 **COMPLETED** 3/9/2010 **SURF. ELEV.** 729.5 **COORDINATES:** N 1,259,239.85 E 2,070,394.83

CONTRACTOR SCS Field Services **EQUIPMENT** CME 55 **METHOD** Hollow Stem Auger

DRILLED BY T. Milam **LOGGED BY** R. Mudd **CHECKED BY** **ANGLE** **BEARING**

BORING DEPTH 32 ft. **GROUND WATER DEPTH: DURING** **COMP.** **DELAYED** 7 ft. after 216 hrs.

NOTES Top of Ash Pond 2, Shallow Well Well installed. Refer to well data sheet.

DEPTH (ft.)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	SAMPLE TYPE NUMBER	SAMPLE DEPTH (ft.)	BLOW COUNTS (N VALUE)	RECOVERY % (RQD)	COMMENTS
5								
10				UD -1	10.0- 12.0		100	
15								
20				UD -2	20.0- 22.0		100	
25								
30								
35				UD -3	32.0- 34.0		0	UD attempted, material too dense for sampling, crushed Shelby tube.

GEOTECH ENGINEERING LOGS - ESEE DATABASE.GDT - 09/20/10 10:41 - T:\ESEE MAJOR PROJECTS\PROJECTS\YATES 2010\ES1836 EPA ASH POND INSPECTIONS\BORING INFORMATION\YATES ASH POND DIKES.GPJ



LOG OF TEST BORING

BORING AP2-2 deep
PAGE 1 OF 2

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Plant Yates Ash Pond Dike Stability

LOCATION Whitesburg, Ga

DATE STARTED 3/9/2010 **COMPLETED** 3/9/2010 **SURF. ELEV.** 714.4 **COORDINATES:** N 1,259,256.83 E 2,070,344.54

CONTRACTOR SCS Field Services **EQUIPMENT** CME 55 **METHOD** Hollow Stem Auger

DRILLED BY T. Milam **LOGGED BY** R. Mudd **CHECKED BY** **ANGLE** **BEARING**

BORING DEPTH 45.5 ft. **GROUND WATER DEPTH: DURING** **COMP.** **DELAYED** 17.4 ft. after 216 hrs.

NOTES Ash Pond 2 Berm, Deep Well Well installed. Refer to well data sheet.

DEPTH (ft.)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	SAMPLE TYPE NUMBER	SAMPLE DEPTH (ft.)	BLOW COUNTS (N VALUE)	RECOVERY % (RQD)	COMMENTS
5		Silty Sand (SM) - SM: orange, tan, gray, light gray and red, moist, medium to fine grain, <i>fill</i> , some small pebbles in sample, micaceous	706.9	SS -1	4.5-6.0	3-5-12 (17)		(MC = 16.8%; FC = 24.9%; Gravel = 0.1%)
10		- SM: dark brown, moist, medium dense, medium grain, <i>residuum</i> , white quartz angular pebbles in sample		SS -2	9.5-11.0	2-8-10 (18)		Probable fill/residuum interface, cuttings turned from predominately red to predominately light brown. (MC = 16.2%; FC = 20%; Gravel = 2.2%)
15		- SM: greenish gray and white, very moist, medium dense, medium grain, <i>residuum</i> , some micaceous small angular pebbles in sample		SS -3	14.5-16.0	4-10-9 (19)		
20		Fat Clay (CH) - dark brown, very moist, soft, high plasticity, <i>residuum</i> , trace organics, SG = 2.774	694.9	SS -4	19.5-21.0	1-2-1 (3)		(MC = 42.6%; LL=52; PI=26; FC = 93.3%)
25		- CH: orange-red, moist, medium stiff, medium to high plasticity, <i>residuum</i>		UD -1	22.0-24.0		100	Auger cuttings very wet.
30		Elastic Silt (MH) - gray, moist, soft, medium to high plasticity, <i>residuum</i> , alternates stiff and soft layers in spoon	684.9	SS -6	29.5-31.0	WH-1-2 (3)		(MC = 40.5%; LL=53; PI=20; FC = 87.2%)
35		Poorly-graded Sand (SP) - light and medium gray, very wet, loose, coarse grain, <i>residuum</i> , top 6" of sample is possibly gray CH from above	679.9	SS -7	34.5-36.0	4-4-3 (7)		Auger cuttings appear to alternate between thicker, light gray/red-orange clay and dark gray, "oozy" clay.
								difficult drilling for approximately 1

(Continued Next Page)

GEOTECH ENGINEERING LOGS - ESEE DATABASE GDT - 09/20/10 10:41 - T:\ESEE MAJOR PROJECTS\PROJECTS\YATES ASH POND INSPECTIONS\BORING INFORMATION\YATES ASH POND DIKES.GPJ



LOG OF TEST BORING

BORING AP2-2 deep
PAGE 2 OF 2

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Plant Yates Ash Pond Dike Stability

LOCATION Whitesburg, Ga

DEPTH (ft)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	SAMPLE TYPE NUMBER	SAMPLE DEPTH (ft.)	BLOW COUNTS (N VALUE)	RECOVERY % (RQD)	COMMENTS	
40		Silty Sand (SM) - dark brown and orange, moist, dense, fine grain, <i>residuum</i> , saprolite, micaceous	674.9		SS	39.5-	11-18-23		foot, then more "oozy" clay. (MC = 16.1%; FC = 27.3%; Gravel = 1.4%)
			-8		41.0	(41)			
45		Poorly-graded Sand (SP) - black, dark gray and white layers, moist, very dense, fine grain, <i>residuum</i> , weathered in place gneiss	669.9		SS	44.5-	50/5"		Auger Refusal.
			669.0		-9	44.9	(100+)		
Bottom of borehole at 45.5 feet.									
50									
55									
60									
65									
70									
75									
80									
85									

GEOTECH ENGINEERING LOGS - ESEE DATABASE GDT - 09/20/10 10:41 - T:\ESEE MAJOR PROJECTS\PROJECTS\YATES 2010\ES1836 EPA ASH POND INSPECTIONS\BORING INFORMATION\YATES ASH POND DIKES.GPJ



LOG OF TEST BORING

BORING AP2-2 shallow
PAGE 1 OF 1

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Plant Yates Ash Pond Dike Stability

LOCATION Whitesburg, Ga

DATE STARTED 3/15/2010 **COMPLETED** 3/15/2010 **SURF. ELEV.** 715.2 **COORDINATES:** N 1,259,192.20 E 2,070,301.10

CONTRACTOR SCS Field Services **EQUIPMENT** CME 55 **METHOD** Hollow Stem Auger

DRILLED BY T. Milam **LOGGED BY** R. Mudd **CHECKED BY** **ANGLE** **BEARING**

BORING DEPTH 21 ft. **GROUND WATER DEPTH: DURING** **COMP.** **DELAYED** 6.2 ft. after 72 hrs.

NOTES Ash Pond 2 Berm, Shallow Well Well installed. Refer to well data sheet.

DEPTH (ft)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	SAMPLE TYPE NUMBER	SAMPLE DEPTH (ft.)	BLOW COUNTS (N VALUE)	RECOVERY % (RQD)	COMMENTS
5		Silty Sand (SM) - orange, gray and white, slightly moist, medium to fine grain, fill						
				SS -1	4.5-6.0	6-7-8 (15)		
				SS -2	6.5-8.0	4-8-9 (17)		Cuttings changed from light red to medium brown. (MC = 15.4%; FC = 25.6%; Gravel = 1.3%) Very difficult drilling.
10		- dark brown and gray, Less clay, large white quartz in sample		SS -3	9.5-11.0	5-7-9 (16)		
15		- light tan with orange and gray, fine grain, fill, First sample attempt had no recovery, second sample attempt appears "oozy" in spoon, with trace clay, small recovery		SS -4	14.5-16.0	7-10-8 (18)		cuttings turned from medium brown to dark gray.
			697.7					
20		- SP: gray and white, moist, dense, medium grain, residuum, Appears with CLAY (CH), dark brown, high plasticity and moist		SS -5	19.5-21.0	3-7-8 (15)		probable fill/residuum interface, cuttings "oozed" from hole but quickly turned to balled up light brown clay.
		Bottom of borehole at 21.0 feet.						
25								
30								
35								

GEOTECH ENGINEERING LOGS - ESEE DATABASE GDT - 09/20/10 10:41 - T:\ESEE MAJOR PROJECTS\PROJECTS\YATES 2010\ESI836 EPA ASH POND INSPECTIONS\BORING INFORMATION\YATES ASH POND DIKES.GPJ



LOG OF TEST BORING

BORING AP2-3
PAGE 1 OF 1

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Plant Yates Ash Pond Dike Stability

LOCATION Whitesburg, Ga







DATE STARTED 3/11/2010 **COMPLETED** 3/11/2010 **SURF. ELEV.** 698.5 **COORDINATES:** N 1,259,293.75 E 2,070,299.02

CONTRACTOR SCS Field Services **EQUIPMENT** CME 55 **METHOD** Hollow Stem Auger

DRILLED BY T. Milam **LOGGED BY** R. Mudd **CHECKED BY** **ANGLE** **BEARING**

BORING DEPTH 23.9 ft. **GROUND WATER DEPTH: DURING** **COMP.** 3.2 ft. **DELAYED** 5.7 ft. after 168 hrs.

NOTES Toe of Ash Pond 2, next to Chattahoochee River which was flowing 4' below top of boring at time of drilling (elevated due to recent rains) Well ins

DEPTH (ft.)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	SAMPLE TYPE NUMBER	SAMPLE DEPTH (ft.)	BLOW COUNTS (N VALUE)	RECOVERY % (RQD)	COMMENTS
5		Silty Sand (SM) - red						Surface material is very loose sand flood deposits.
		- dark gray, wet, loose, fine grain		SS -1	4.5-6.0	2-3-3 (6)		(MC = 33.5%; PL=NP; FC = 45.5%; Gravel = 5.8%)
10		Silt (ML) - dark brown-red, wet, very loose, medium plasticity, fine grain	690.5	SS -2	9.5-11.0	WH-WH-WH (0)		(MC = 35.6%; LL=35; PI=9; FC = 55%)
15		- dark gray, very wet, very loose, fine grain		ST -1	13.0-15.0		0	UD contained no recovery, sample too loose to stay in tube.
				SS -3	15.0-16.5	WH-WH-WH (0)		(MC = 41%; LL=34; PI=9; FC = 62.8%)
20		Poorly-graded Sand (SP) - dark gray and white, moist, medium dense, medium grain, angular, weathered rock in sample	678.0	SS -4	19.5-21.0	WH-1-13 (14)		
25		Bottom of borehole at 23.9 feet.	674.6					Auger Refusal.
30								
35								

GEOTECH ENGINEERING LOGS - ESEE DATABASE GDT - 09/20/10 10:41 - T:\ESEE MAJOR PROJECTS\PROJECTS\YATES 2010\ESI836 EPA ASH POND INSPECTIONS\BORING INFORMATION\YATES ASH POND DIKES.GPJ



LOG OF TEST BORING

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Plant Yates Ash Pond Dike Stability
LOCATION Whitesburg, Ga

DATE STARTED 8/9/2010 **COMPLETED** 8/9/2010 **SURF. ELEV.** 698.5 **COORDINATES:** N 1,259,225.40 E 2,070,256.89
CONTRACTOR SCS Field Services **EQUIPMENT** CME 55 **METHOD** Casing Advance with removable bit
DRILLED BY T. Milam **LOGGED BY** R. Mudd **CHECKED BY** _____ **ANGLE** _____ **BEARING** _____
BORING DEPTH 23.2 ft. **GROUND WATER DEPTH: DURING** _____ **COMP.** _____ **DELAYED** _____
NOTES AP2-4 and AP2-5 added after inspection for clarification of riverbank material characteristics; drilling method prevented groundwater reading

DEPTH (ft.)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	SAMPLE TYPE NUMBER	SAMPLE DEPTH (ft.)	BLOW COUNTS (N VALUE)	RECOVERY % (RQD)	COMMENTS
5		Clayey Sand (SC) - dark brown, medium dense, fine grain, micaceous	693.5	SS -1	3.5-5.0	7-8-7 (15)		
10		Sandy Lean Clay (CL) - dark brown, soft, low plasticity, with sand, micaceous		SS -2	9.5-11.0	WH-WH-WH (0)		
15		- more sand than above		SS -3	14.5-16.0	WH-WH-WH (0)		
20								
		Clayey Sand (SC) - dark brown and black, medium dense, fine to medium grain, pieces of rock in sample, micaceous	679.0	SS -4	19.5-21.0	WH-8-7 (15)		
		Bottom of borehole at 23.2 feet.	675.3					Refusal.
25								
30								
35								

GEOTECH ENGINEERING LOGS - ESEE DATABASE GDT - 09/20/10 10:41 - T:\ESEE MAJOR PROJECTS\PROJECTS\YATES 2010\ES1836 EPA ASH POND INSPECTIONS\BORING INFORMATION\YATES ASH POND DIKES.GPJ



LOG OF TEST BORING

BORING AP2-5
PAGE 1 OF 1

SOUTHERN COMPANY SERVICES, INC.
EARTH SCIENCE AND ENVIRONMENTAL ENGINEERING

PROJECT Plant Yates Ash Pond Dike Stability

LOCATION Whitesburg, Ga

DATE STARTED 8/9/2010 **COMPLETED** 8/9/2010 **SURF. ELEV.** 698.6 **COORDINATES:** N 1,259,369.42 E 2,070,343.20

CONTRACTOR SCS Field Services **EQUIPMENT** CME 55 **METHOD** Casing Advance with removable bit

DRILLED BY T. Milam **LOGGED BY** R. Mudd **CHECKED BY** **ANGLE** **BEARING**

BORING DEPTH 22.7 ft. **GROUND WATER DEPTH: DURING** **COMP.** **DELAYED**

NOTES AP2-4 and AP2-5 added after inspection for clarification of riverbank material characteristics; drilling method prevented groundwater reading; Hole

DEPTH (ft.)	GRAPHIC LOG	MATERIAL DESCRIPTION	ELEVATION	SAMPLE TYPE NUMBER	SAMPLE DEPTH (ft.)	BLOW COUNTS (N VALUE)	RECOVERY % (RQD)	COMMENTS
5		Clayey Sand (SC) - dark gray, transitioning to red-brown with depth, medium dense, fine grain, micaceous		SS -1	4.5-6.0	8-5-5 (10)		
10		Lean Clay (CL) - dark brown, soft, medium plasticity, a few twigs and pieces of grass in sample, slightly micaceous	689.1	SS -2	9.5- 11.0	WH-WH-WH (0)		
15		Silty Sand (SM) - light gray, loose, fine grain, large piece of wood in sample, micaceous	684.1	SS -3	14.5- 16.0	1-4-4 (8)		
20		- No recovery, some small pieces of wood in spoon		SS -4	19.5- 21.0	2-1-1 (2)		
			675.9					
		Bottom of borehole at 22.7 feet.						Refusal.
25								
30								
35								

GEOTECH ENGINEERING LOGS - ESEE DATABASE GDT - 09/20/10 10:41 - T:\ESEE MAJOR PROJECTS\PROJECTS\YATES 2010\ES1836 EPA ASH POND INSPECTIONS\BORING INFORMATION\YATES ASH POND DIKES.GPJ

Attachment C
Laboratory Analyses


Project: Plant Yates Ash Pond
 Project Number 6189-10-9008
 Date Performed 4/2/2010
 Date Sampled

Moisture Content Calculation: $(\text{WetWt}-\text{DryWt})/(\text{DryWt}-\text{can wt})$

Boring Number	AP1-1	AP1-1	AP1-1	AP2-1	AP2-1	AP2-1	AP2-1	AP2-2 DEEP	AP2-2 DEEP	AP2-2 DEEP
Sample Number	2	4	6	2	6	8	10	1	2	4
Depth	9.5-11	19.5-21	29.5-31	9.5-11	29.5-31	39.5-41	49.5-51	4.5-6	9.5-11	19.5-21
Can Number										
Can Weight	55.76	54.25	50.83	50.42	51.67	55.88	54.96	53.73	53.15	55.21
Wet wt w/ Can	193.21	96.15	192.67	199.71	213.46	187.23	121.91	235.66	166.27	117.54
Dry wt. W/ Can	165.5	87.83	161.26	176.47	190.3	156.36	99.99	209.44	150.5	98.92
Percent Moisture	25.3%	24.8%	28.4%	18.4%	16.7%	30.7%	48.7%	16.8%	16.2%	42.6%

Boring Number	AP2-2 DEEP	AP2-2 DEEP	AP2-2 SHALLOW	AP2-3	AP2-3	AP2-3	APA-1	APA-1	APA-1	APA-1
Sample Number	6	8	2	1	2	3	3	4	5	7
Depth	29.5-31	39.5-41	6.5-8	4.5-6	9.5-11	15-16.5	14.5-16	19.5-21	24.5-26	37.5-39
Can Number										
Can Weight	53.26	49.04	49.97	50.19	49.76	54.75	49.13	49.84	55.54	50.17
Wet wt w/ Can	173.93	251.55	193.23	144.33	169.21	201.5	102.61	197.05	204.24	229.87
Dry wt. W/ Can	139.13	223.41	174.12	120.7	137.87	158.81	88.89	151.98	164.48	191.61
Percent Moisture	40.5%	16.1%	15.4%	33.5%	35.6%	41.0%	34.5%	44.1%	36.5%	27.1%

Grain Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	9.3	6.4	16.4	38.6	29.3	

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3"	100.0		
2"	100.0		
1.5"	100.0		
1"	100.0		
3/4"	100.0		
1/2"	100.0		
3/8"	98.6		
#4	90.7		
#10	84.3		
#20	78.5		
#40	67.9		
#60	56.7		
#100	45.5		
#200	29.3		

* (no specification provided)

Material Description Light Reddish Brown Medium to Fine SAND with Silt		
Atterberg Limits (ASTM D 4318) PL= 41 LL= 51 PI= 10		
Classification USCS (D 2487)= SM AASHTO (M 145)= A-2-5(0)		
Coefficients D ₉₀ = 4.4266 D ₈₅ = 2.2615 D ₆₀ = 0.2906 D ₅₀ = 0.1836 D ₃₀ = 0.0772 D ₁₅ = D ₁₀ = C _u = C _c =		
Remarks		
Date Received: 4-2-10		Date Tested: 4-8-10
Tested By: MC		
Checked By:		
Title:		

Source of Sample: Boring No.: AP2-1
Sample Number: 2

Depth: 9.5'-11.0'

Date Sampled:

**MACTEC ENGINEERING.
AND CONSULTING, INC.**


Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report

PERCENT FINER



GRAIN SIZE - mm.

% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	2.5	1.5	16.2	46.9	32.9	

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3"	100.0		
2"	100.0		
1.5"	100.0		
1"	100.0		
3/4"	100.0		
1/2"	100.0		
3/8"	98.5		
#4	97.5		
#10	96.0		
#20	91.9		
#40	79.8		
#60	63.5		
#100	47.5		
#200	32.9		

* (no specification provided)

Material Description

Light Brown Medium to Fine SAND with Clay

Atterberg Limits (ASTM D 4318)

PL= 23 LL= 34 PI= 11

Classification

USCS (D 2487)= SC AASHTO (M 145)= A-2-6(0)

Coefficients

D₉₀= 0.7201 D₈₅= 0.5321 D₆₀= 0.2253
D₅₀= 0.1640 D₃₀= D₁₅=
D₁₀= C_u= C_c=

Remarks

Date Received: 4-2-10

Date Tested: 4-8-10

Tested By: MC

Checked By:

Title:

Source of Sample: Boring No.: AP2-1
Sample Number: 6

Depth: 29.5'-31.0'

Date Sampled:

**MACTEC ENGINEERING.
AND CONSULTING, INC.**


Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report

PERCENT FINER



GRAIN SIZE - mm.

% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.0	0.0	0.3	12.1	87.6	

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3"	100.0		
2"	100.0		
1.5"	100.0		
1"	100.0		
3/4"	100.0		
1/2"	100.0		
3/8"	100.0		
#4	100.0		
#10	100.0		
#20	99.9		
#40	99.7		
#60	99.3		
#100	98.5		
#200	87.6		

* (no specification provided)

Material Description

Light Brown SILT with Sand

Atterberg Limits (ASTM D 4318)

PL= 30 LL= 45 PI= 15

Classification

USCS (D 2487)= ML AASHTO (M 145)= A-7-5(16)

Coefficients

D₉₀= 0.0848 D₈₅= D₆₀=
D₅₀= D₃₀= D₁₅=
D₁₀= C_u= C_c=

Remarks

Date Received: 4-2-10

Date Tested: 4-8-10

Tested By: MC

Checked By:

Title:

Source of Sample: Boring No.: AP2-1
Sample Number: 8

Depth: 39.5'-41.0'

Date Sampled:


**MACTEC ENGINEERING.
AND CONSULTING, INC.**

Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.0	0.0	1.1	19.8	47.3	31.8

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
#10	100.0		
#20	99.8		
#40	98.9		
#60	96.8		
#100	91.7		
#200	79.1		
0.0521 mm.	73.9		
0.0376 mm.	70.9		
0.0277 mm.	64.7		
0.0185 mm.	54.8		
0.0111 mm.	47.2		
0.0082 mm.	39.5		
0.0059 mm.	34.2		
0.0030 mm.	24.9		
0.0013 mm.	18.1		

* (no specification provided)

Material Description Dark Gray Elastic SILT with Sand		
Atterberg Limits (ASTM D 4318) PL= 47 LL= 71 PI= 24		
Classification USCS (D 2487)= MH AASHTO (M 145)= A-7-5(25)		
Coefficients D ₉₀ = 0.1347 D ₈₅ = 0.1024 D ₆₀ = 0.0231 D ₅₀ = 0.0132 D ₃₀ = 0.0044 D ₁₅ = D ₁₀ = C _u = C _c =		
Remarks Assumed specific gravity: 2.690		
Date Received: 4-2-10		Date Tested: 4-8-10
Tested By: MC		
Checked By:		
Title:		

Source of Sample: Boring No.: AP2-1
Sample Number: 10

Depth: 49.5'-51.0'

Date Sampled:

**MACTEC ENGINEERING.
AND CONSULTING, INC.**


Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report

PERCENT FINER



GRAIN SIZE - mm.

% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.1	0.9	15.4	58.7	24.9	

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3"	100.0		
2"	100.0		
1.5"	100.0		
1"	100.0		
3/4"	100.0		
1/2"	100.0		
3/8"	100.0		
#4	99.9		
#10	99.0		
#20	95.9		
#40	83.6		
#60	63.3		
#100	42.7		
#200	24.9		

* (no specification provided)

Material Description

Light Brown Medium to Fine SAND with Silt

Atterberg Limits (ASTM D 4318)

PL= LL= PI=

Classification

USCS (D 2487)= SM AASHTO (M 145)=

Coefficients

D₉₀= 0.5515 D₈₅= 0.4465 D₆₀= 0.2313
D₅₀= 0.1823 D₃₀= 0.0948 D₁₅=
D₁₀= C_u= C_c=

Remarks

Date Received: 4-2-10

Date Tested: 4-8-10

Tested By: MC

Checked By: _____

Title: _____

Source of Sample: Boring No.: AP2-2
Sample Number: 1

Depth: 4.5'-6.0'

Date Sampled:


**MACTEC ENGINEERING.
AND CONSULTING, INC.**

Client: Southern Company
Project: Plant Yates Ash Pond


Project No: 6189109008

Jax FL.

Grain Size Distribution Report



Grain Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.0	0.0	0.3	6.4	40.9	52.4

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
#10	100.0		
#20	99.8		
#40	99.7		
#60	99.3		
#100	98.1		
#200	93.3		
0.0484 mm.	89.8		
0.0348 mm.	87.3		
0.0250 mm.	84.7		
0.0164 mm.	78.8		
0.0100 mm.	70.2		
0.0073 mm.	61.8		
0.0054 mm.	54.1		
0.0028 mm.	40.5		
0.0012 mm.	29.4		

* (no specification provided)

Material Description Light Brown Fat Clay with Sand		
Atterberg Limits (ASTM D 4318) PL= 26 LL= 52 PI= 26		
Classification USCS (D 2487)= CH AASHTO (M 145)= A-7-6(28)		
Coefficients D ₉₀ = 0.0494 D ₈₅ = 0.0257 D ₆₀ = 0.0069 D ₅₀ = 0.0045 D ₃₀ = 0.0013 D ₁₅ = D ₁₀ = C _u = C _c =		
Remarks Specific gravity: 2.774		
Date Received: 4-2-10		Date Tested: 4-8-10
Tested By: MC		
Checked By:		
Title:		

Source of Sample: Boring No.: AP2-2
Sample Number: 4

Depth: 19.5'-21.0'

Date Sampled:


**MACTEC ENGINEERING.
AND CONSULTING, INC.**

Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.0	0.0	0.2	12.6	87.2	

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3"	100.0		
2"	100.0		
1.5"	100.0		
1"	100.0		
3/4"	100.0		
1/2"	100.0		
3/8"	100.0		
#4	100.0		
#10	100.0		
#20	99.9		
#40	99.8		
#60	99.3		
#100	97.9		
#200	87.2		

* (no specification provided)

Material Description Light Brown Elastic SILT with Sand		
Atterberg Limits (ASTM D 4318) PL= 33 LL= 53 PI= 20		
Classification USCS (D 2487)= MH AASHTO (M 145)= A-7-5(21)		
Coefficients D ₉₀ = 0.0871 D ₈₅ = D ₆₀ = D ₅₀ = D ₃₀ = D ₁₅ = D ₁₀ = C _u = C _c =		
Remarks		
Date Received: 4-2-10		Date Tested: 4-8-10
Tested By: MC		
Checked By:		
Title:		

Source of Sample: Boring No.: AP2-2
Sample Number: 6

Depth: 29.5'-31.0'

Date Sampled:


**MACTEC ENGINEERING.
AND CONSULTING, INC.**

Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	1.4	1.8	9.6	59.9	27.3	

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3"	100.0		
2"	100.0		
1.5"	100.0		
1"	100.0		
3/4"	100.0		
1/2"	100.0		
3/8"	100.0		
#4	98.6		
#10	96.8		
#20	95.3		
#40	87.2		
#60	71.7		
#100	53.0		
#200	27.3		

* (no specification provided)

Material Description Light Brown Medium to Fine SAND with Silt	
Atterberg Limits (ASTM D 4318) PL= _____ LL= _____ PI= _____	Classification USCS (D 2487)= SM AASHTO (M 145)= _____
Coefficients D ₉₀ = 0.4925 D ₈₅ = 0.3870 D ₆₀ = 0.1810 D ₅₀ = 0.1385 D ₃₀ = 0.0807 D ₁₅ = _____ D ₁₀ = _____ C _u = _____ C _c = _____	
Remarks 	
Date Received: 4-2-10 Date Tested: 4-8-10 Tested By: MC Checked By: _____ Title: _____	

Source of Sample: Boring No.: AP2-2
Sample Number: 8

Depth: 39.5'-41.0'

Date Sampled:

**MACTEC ENGINEERING.
AND CONSULTING, INC.**


Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report

PERCENT FINER



GRAIN SIZE - mm.

% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	1.3	1.5	18.3	53.3	25.6	

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3"	100.0		
2"	100.0		
1.5"	100.0		
1"	100.0		
3/4"	100.0		
1/2"	100.0		
3/8"	100.0		
#4	98.7		
#10	97.2		
#20	92.8		
#40	78.9		
#60	59.8		
#100	41.8		
#200	25.6		

* (no specification provided)

Material Description

Light Brown Medium to Fine SAND with Silt

Atterberg Limits (ASTM D 4318)

PL= LL= PI=

Classification

USCS (D 2487)= SM AASHTO (M 145)=

Coefficients

D₉₀= 0.6908 D₈₅= 0.5344 D₆₀= 0.2515
D₅₀= 0.1924 D₃₀= 0.0932 D₁₅=
D₁₀= C_u= C_c=

Remarks

Date Received: 4-2-10

Date Tested: 4-8-10

Tested By: MC

Checked By:

Title:

Source of Sample: Boring No.: AP2-2
Sample Number: 2

Depth: 6.5'-8.0'

Date Sampled:

**MACTEC ENGINEERING.
AND CONSULTING, INC.**


Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report

PERCENT FINER



GRAIN SIZE - mm.

% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	5.8	6.0	12.2	30.5	45.5	

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3"	100.0		
2"	100.0		
1.5"	100.0		
1"	100.0		
3/4"	100.0		
1/2"	100.0		
3/8"	97.4		
#4	94.2		
#10	88.2		
#20	82.1		
#40	76.0		
#60	69.7		
#100	61.6		
#200	45.5		

* (no specification provided)

Material Description

Dark Gray Fly Ash

Atterberg Limits (ASTM D 4318)

PL= NP

LL= NP

PI= NP

Classification

USCS (D 2487)= SM

AASHTO (M 145)= A-4(0)

Coefficients

D₉₀= 2.5327

D₈₅= 1.2784

D₆₀= 0.1386

D₅₀= 0.0899

D₃₀=

D₁₅=

D₁₀=

C_u=

C_c=

Remarks

Date Received: 4-2-10

Date Tested: 4-8-10

Tested By: MC

Checked By:

Title:

Source of Sample: Boring No.: AP2-3
Sample Number: 1

Depth: 4.5'-6.0'

Date Sampled:

**MACTEC ENGINEERING.
AND CONSULTING, INC.**


Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report

PERCENT FINER



GRAIN SIZE - mm.

% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.0	0.0	0.3	44.7	55.0	

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3"	100.0		
2"	100.0		
1.5"	100.0		
1"	100.0		
3/4"	100.0		
1/2"	100.0		
3/8"	100.0		
#4	100.0		
#10	100.0		
#20	99.9		
#40	99.7		
#60	93.7		
#100	71.6		
#200	55.0		

* (no specification provided)

Material Description

Light Brown SILT with Sand

Atterberg Limits (ASTM D 4318)

PL= 26 LL= 35 PI= 9

Classification

USCS (D 2487)= ML AASHTO (M 145)= A-4(3)

Coefficients

D₉₀= 0.2254 D₈₅= 0.2010 D₆₀= 0.1004
D₅₀= D₃₀= D₁₅=
D₁₀= C_u= C_c=

Remarks

Date Received: 4-2-10

Date Tested: 4-8-10

Tested By: MC

Checked By:

Title:

Source of Sample: Boring No.: AP2-3
Sample Number: 2

Depth: 9.5'-11.0'

Date Sampled:

**MACTEC ENGINEERING.
AND CONSULTING, INC.**


Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report

PERCENT FINER



GRAIN SIZE - mm.

% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.0	0.1	0.1	37.0	62.8	

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
3"	100.0		
2"	100.0		
1.5"	100.0		
1"	100.0		
3/4"	100.0		
1/2"	100.0		
3/8"	100.0		
#4	100.0		
#10	99.9		
#20	99.9		
#40	99.8		
#60	97.9		
#100	84.3		
#200	62.8		

* (no specification provided)

Material Description

Light Gray SILT with Fine Sand

Atterberg Limits (ASTM D 4318)

PL= 25 LL= 34 PI= 9

Classification

USCS (D 2487)= ML AASHTO (M 145)= A-4(4)

Coefficients

D₉₀= 0.1796 D₈₅= 0.1532 D₆₀=
D₅₀= D₃₀= D₁₅=
D₁₀= C_u= C_c=

Remarks

Date Received: 4-2-10

Date Tested: 4-8-10

Tested By: MC

Checked By:

Title:

Source of Sample: Boring No.: AP2-3
Sample Number: 3

Depth: 15.0'-16.5'

Date Sampled:


**MACTEC ENGINEERING.
AND CONSULTING, INC.**

Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report



GRAIN SIZE - mm.

% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.0	0.0	1.1	19.8	47.3	31.8

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
#10	100.0		
#20	99.8		
#40	98.9		
#60	96.8		
#100	91.7		
#200	79.1		
0.0521 mm.	73.9		
0.0376 mm.	70.9		
0.0277 mm.	64.7		
0.0185 mm.	54.8		
0.0111 mm.	47.2		
0.0082 mm.	39.5		
0.0059 mm.	34.2		
0.0030 mm.	24.9		
0.0013 mm.	18.1		

* (no specification provided)

Material Description

Dark Gray Elastic SILT with Sand

Atterberg Limits (ASTM D 4318)

PL= 47 LL= 71 PI= 24

Classification

USCS (D 2487)= MH AASHTO (M 145)= A-7-5(25)

Coefficients

D₉₀= 0.1347 D₈₅= 0.1024 D₆₀= 0.0231
D₅₀= 0.0132 D₃₀= 0.0044 D₁₅=
D₁₀= C_u= C_c=

Remarks

Assumed specific gravity: 2.690

Date Received: 4-2-10

Date Tested: 4-8-10

Tested By: MC

Checked By:

Title:

Source of Sample: Boring No.: AP2-1
Sample Number: 10

Depth: 49.5'-51.0'

Date Sampled:


**MACTEC ENGINEERING.
AND CONSULTING, INC.**

Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

Grain Size Distribution Report



% +3"	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0.0	0.0	0.0	0.0	0.3	6.4	40.9	52.4

Test Results (ASTM D 422 & ASTM D 1140)			
Opening Size	Percent Finer	Spec.* (Percent)	Pass? (X=Fail)
#10	100.0		
#20	99.8		
#40	99.7		
#60	99.3		
#100	98.1		
#200	93.3		
0.0484 mm.	89.8		
0.0348 mm.	87.3		
0.0250 mm.	84.7		
0.0164 mm.	78.8		
0.0100 mm.	70.2		
0.0073 mm.	61.8		
0.0054 mm.	54.1		
0.0028 mm.	40.5		
0.0012 mm.	29.4		

* (no specification provided)

Material Description	
Light Brown Fat Clay with Sand	
Atterberg Limits (ASTM D 4318)	
PL= 26	LL= 52 PI= 26
Classification	
USCS (D 2487)= CH	AASHTO (M 145)= A-7-6(28)
Coefficients	
D ₉₀ = 0.0494	D ₈₅ = 0.0257 D ₆₀ = 0.0069
D ₅₀ = 0.0045	D ₃₀ = 0.0013 D ₁₅ =
D ₁₀ =	C _u = C _c =
Remarks	
Date Received: 4-2-10	Date Tested: 4-8-10
Tested By: MC	
Checked By: _____	
Title: _____	

Source of Sample: Boring No.: AP2-2
Sample Number: 4

Depth: 19.5'-21.0'

Date Sampled:



**MACTEC ENGINEERING.
AND CONSULTING, INC.**

Client: Southern Company
Project: Plant Yates Ash Pond

Project No: 6189109008

Jax FL.

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	⊙	△	□	
Sample No.	IS-1	IS-1	IS-1	
Test No.	10099.1	10099.2	10099.3	
Depth	10-12 ft	10-12 ft	10-12 ft	
Initial	Diameter, in	2.878	2.873	2.856
	Height, in	5.977	5.574	5.572
	Water Content, %	20.1	17.4	19.4
	Dry Density, pcf	103.3	106.2	105.9
	Saturation, %	85.1	79.2	87.4
Before Shear	Void Ratio	0.643	0.599	0.603
	Water Content, %	23.2	21.1	21.9
	Dry Density, pcf	104.	107.9	106.4
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.632	0.574	0.596
	Back Press., psi	120.	134.	134.
	Ver. Eff. Cons. Stress, psi	4.001	5.997	8.009
	Shear Strength, psi	2.584	3.912	5.121
	Strain at Failure, %	1.03	2.05	1.43
	Strain Rate, %/min	0.05	0.05	0.05
	B-Value	0.96	0.96	0.95
	Measured Specific Gravity	2.72	2.72	2.72
	Liquid Limit	NP	NP	NP
	Plastic Limit	NP	NP	NP

MACTEC	Project: Plant Yates Ash Pond	
	Location: AP2-1	
	Project No.: 6189109008	
	Boring No.: AP2-1	
	Sample Type: Undisturbed	
	Description: Brown Silty Sand with Mica	
	Remarks: ASTM D4767-04 Strains at failure based on peak excess pore pressure.	


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
○	IS-1	10099.1	10-12 ft	JW	3/26/10			10099.1_2547.dat
△	IS-1	10099.2	10-12 ft	JW	3/26/10			10099.2_2580.dat
□	IS-1	10099.3	10-12 ft	JW	3/26/10			10099.3_2546.dat

			
	Project: Plant Yates Ash Pond	Location: AP2-1	Project No.: 6189109008
	Boring No.: AP2-1	Sample Type: Undisturbed	
	Description: Brown Silty Sand with Mica		
	Remarks: ASTM D4767-04 Strains at failure based on peak excess pore pressure.		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	⊙	△	□	
Sample No.	IS-1	IS-1	IS-1	
Test No.	10099.1	10099.2	10099.3	
Depth	10-12 ft	10-12 ft	10-12 ft	
Initial	Diameter, in	2.878	2.873	2.856
	Height, in	5.977	5.574	5.572
	Water Content, %	20.1	17.4	19.4
	Dry Density, pcf	103.3	106.2	105.9
	Saturation, %	85.1	79.2	87.4
	Void Ratio	0.643	0.599	0.603
Before Shear	Water Content, %	23.2	21.1	21.9
	Dry Density, pcf	104.	107.9	106.4
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.632	0.574	0.596
	Back Press., psi	120.	134.	134.
Ver. Eff. Cons. Stress, psi		4.001	5.997	8.009
Shear Strength, psi		2.584	3.912	5.121
Strain at Failure, %		1.03	2.05	1.43
Strain Rate, %/min		0.05	0.05	0.05
B-Value		0.96	0.96	0.95
Measured Specific Gravity		2.72	2.72	2.72
Liquid Limit		NP	NP	NP
Plastic Limit		NP	NP	NP

MACTEC	Project: Plant Yates Ash Pond	
	Location: AP2-1	
	Project No.: 6189109008	
	Boring No.: AP2-1	
	Sample Type: Undisturbed	
	Description: Brown Silty Sand with Mica	
	Remarks: ASTM D4767-04 Strains at failure based on peak excess pore pressure.	


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
○	IS-1	10099.1	10-12 ft	JW	3/26/10			10099.1_2547.dat
△	IS-1	10099.2	10-12 ft	JW	3/26/10			10099.2_2580.dat
□	IS-1	10099.3	10-12 ft	JW	3/26/10			10099.3_2546.dat

			
	Project: Plant Yates Ash Pond	Location: AP2-1	Project No.: 6189109008
	Boring No.: AP2-1	Sample Type: Undisturbed	
	Description: Brown Silty Sand with Mica		
	Remarks: ASTM D4767-04 Strains at failure based on peak excess pore pressure.		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	○	△	□	
Sample No.	IS-1	IS-1	IS-1	
Test No.	10099.1	10099.2	10099.3	
Depth	10-12 ft	10-12 ft	10-12 ft	
Initial	Diameter, in	2.878	2.873	2.856
	Height, in	5.977	5.574	5.572
	Water Content, %	20.1	17.4	19.4
	Dry Density, pcf	103.3	106.2	105.9
	Saturation, %	85.1	79.2	87.4
	Void Ratio	0.643	0.599	0.603
Before Shear	Water Content, %	23.2	21.1	21.9
	Dry Density, pcf	104.	107.9	106.4
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.632	0.574	0.596
	Back Press., psi	120.	134.	134.
Ver. Eff. Cons. Stress, psi		4.001	5.997	8.009
Shear Strength, psi		14.74	14.5	21.53
Strain at Failure, %		17	16.8	17
Strain Rate, %/min		0.05	0.05	0.05
B-Value		0.96	0.96	0.95
Measured Specific Gravity		2.72	2.72	2.72
Liquid Limit		NP	NP	NP
Plastic Limit		NP	NP	NP

	Project: Plant Yates Ash Pond	
	Location: AP2-1	
	Project No.: 6189109008	
	Boring No.: AP2-1	
	Sample Type: Undisturbed	
	Description: Brown Silty Sand with Mica	
Remarks: ASTM D4767-04		


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767





	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
○	IS-1	10099.1	10-12 ft	JW	3/26/10			10099.1_2547.dat
△	IS-1	10099.2	10-12 ft	JW	3/26/10			10099.2_2580.dat
□	IS-1	10099.3	10-12 ft	JW	3/26/10			10099.3_2546.dat

			
	Project: Plant Yates Ash Pond	Location: AP2-1	Project No.: 6189109008
	Boring No.: AP2-1	Sample Type: Undisturbed	
	Description: Brown Silty Sand with Mica		
	Remarks: ASTM D4767-04		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	○	△	□	
Sample No.	IS-1	IS-1	IS-1	
Test No.	10099.1	10099.2	10099.3	
Depth	10-12 ft	10-12 ft	10-12 ft	
Initial	Diameter, in	2.878	2.873	2.856
	Height, in	5.977	5.574	5.572
	Water Content, %	20.1	17.4	19.4
	Dry Density, pcf	103.3	106.2	105.9
	Saturation, %	85.1	79.2	87.4
	Void Ratio	0.643	0.599	0.603
Before Shear	Water Content, %	23.2	21.1	21.9
	Dry Density, pcf	104.	107.9	106.4
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.632	0.574	0.596
	Back Press., psi	120.	134.	134.
Ver. Eff. Cons. Stress, psi		4.001	5.997	8.009
Shear Strength, psi		7.937	10.88	13.05
Strain at Failure, %		4.52	7.24	5.94
Strain Rate, %/min		0.05	0.05	0.05
B-Value		0.96	0.96	0.95
Measured Specific Gravity		2.72	2.72	2.72
Liquid Limit		NP	NP	NP
Plastic Limit		NP	NP	NP

	Project: Plant Yates Ash Pond	
	Location: AP2-1	
	Project No.: 6189109008	
	Boring No.: AP2-1	
	Sample Type: Undisturbed	
	Description: Brown Silty Sand with Mica	
	Remarks: ASTM D4767-04 Strains at failure based on A=0.	


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
○	IS-1	10099.1	10-12 ft	JW	3/26/10			10099.1_2547.dat
△	IS-1	10099.2	10-12 ft	JW	3/26/10			10099.2_2580.dat
□	IS-1	10099.3	10-12 ft	JW	3/26/10			10099.3_2546.dat

			
	Project: Plant Yates Ash Pond	Location: AP2-1	Project No.: 6189109008
	Boring No.: AP2-1	Sample Type: Undisturbed	
	Description: Brown Silty Sand with Mica		
	Remarks: ASTM D4767-04 Strains at failure based on A=0.		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	○	△	□	
Sample No.	IS-1	IS-1	IS-1	
Test No.	10099.1	10099.2	10099.3	
Depth	10-12 ft	10-12 ft	10-12 ft	
Initial	Diameter, in	2.878	2.873	2.856
	Height, in	5.977	5.574	5.572
	Water Content, %	20.1	17.4	19.4
	Dry Density, pcf	103.3	106.2	105.9
	Saturation, %	85.1	79.2	87.4
	Void Ratio	0.643	0.599	0.603
Before Shear	Water Content, %	23.2	21.1	21.9
	Dry Density, pcf	104.	107.9	106.4
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.632	0.574	0.596
	Back Press., psi	120.	134.	134.
Ver. Eff. Cons. Stress, psi		4.001	5.997	8.009
Shear Strength, psi		14.74	14.5	21.53
Strain at Failure, %		17	16.8	17
Strain Rate, %/min		0.05	0.05	0.05
B-Value		0.96	0.96	0.95
Measured Specific Gravity		2.72	2.72	2.72
Liquid Limit		NP	NP	NP
Plastic Limit		NP	NP	NP

	Project: Plant Yates Ash Pond				
	Location: AP2-1				
	Project No.: 6189109008				
	Boring No.: AP2-1				
	Sample Type: Undisturbed				
	Description: Brown Silty Sand with Mica				
Remarks: ASTM D4767-04					


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
○	IS-1	10099.1	10-12 ft	JW	3/26/10			10099.1_2547.dat
△	IS-1	10099.2	10-12 ft	JW	3/26/10			10099.2_2580.dat
□	IS-1	10099.3	10-12 ft	JW	3/26/10			10099.3_2546.dat

 MACTEC			
	Project: Plant Yates Ash Pond	Location: AP2-1	Project No.: 6189109008
	Boring No.: AP2-1	Sample Type: Undisturbed	
	Description: Brown Silty Sand with Mica		
	Remarks: ASTM D4767-04		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	⊙	△	□	
Sample No.	IS-1	IS-1	IS-1	
Test No.	10099.1	10099.2	10099.3	
Depth	10-12 ft	10-12 ft	10-12 ft	
Initial	Diameter, in	2.878	2.873	2.856
	Height, in	5.977	5.574	5.572
	Water Content, %	20.1	17.4	19.4
	Dry Density, pcf	103.3	106.2	105.9
	Saturation, %	85.1	79.2	87.4
	Void Ratio	0.643	0.599	0.603
Before Shear	Water Content, %	23.2	21.1	21.9
	Dry Density, pcf	104.	107.9	106.4
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.632	0.574	0.596
	Back Press., psi	120.	134.	134.
Ver. Eff. Cons. Stress, psi		4.001	5.997	8.009
Shear Strength, psi		14.74	14.5	21.53
Strain at Failure, %		17	16.8	17
Strain Rate, %/min		0.05	0.05	0.05
B-Value		0.96	0.96	0.95
Measured Specific Gravity		2.72	2.72	2.72
Liquid Limit		NP	NP	NP
Plastic Limit		NP	NP	NP

MACTEC	Project: Plant Yates Ash Pond				
	Location: AP2-1				
	Project No.: 6189109008				
	Boring No.: AP2-1				
	Sample Type: Undisturbed				
	Description: Brown Silty Sand with Mica				
	Remarks: ASTM D4767-04				


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
○	IS-1	10099.1	10-12 ft	JW	3/26/10			10099.1_2547.dat
△	IS-1	10099.2	10-12 ft	JW	3/26/10			10099.2_2580.dat
□	IS-1	10099.3	10-12 ft	JW	3/26/10			10099.3_2546.dat

 MACTEC			
	Project: Plant Yates Ash Pond	Location: AP2-1	Project No.: 6189109008
	Boring No.: AP2-1	Sample Type: Undisturbed	
	Description: Brown Silty Sand with Mica		
	Remarks: ASTM D4767-04		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	⊙	△	□	
Sample No.	IS-2	IS-2	IS-2	
Test No.	10100.1	10100.2	10100.3	
Depth	44-46 ft	44-46 ft	44-46 ft	
Initial	Diameter, in	2.867	2.863	2.867
	Height, in	5.926	5.959	5.606
	Water Content, %	34.9	30.8	29.2
	Dry Density, pcf	88.11	93.09	95.02
	Saturation, %	103.6	103.2	102.3
Before Shear	Void Ratio	0.906	0.804	0.767
	Water Content, %	31.6	27.8	24.6
	Dry Density, pcf	90.82	96.09	101.1
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.849	0.748	0.661
	Back Press., psi	30.	93.98	104.
	Ver. Eff. Cons. Stress, psi	9.991	20.02	40.02
	Shear Strength, psi	5.018	8.891	17.93
	Strain at Failure, %	3.91	2.95	2.89
	Strain Rate, %/min	0.02	0.02	0.02
	B-Value	1.01	0.96	0.93
	Measured Specific Gravity	2.69	2.69	2.69
	Liquid Limit	38	38	38
	Plastic Limit	25	25	25

	Project: Plant Yates Ash Pond	
	Location: AP2-1	
	Project No.: 6189109008	
	Boring No.: AP2-1	
	Sample Type: Undisturbed	
	Description: Brown Silt with Sand	
	Remarks: ASTM D4767-04 Strains at failure based on peak excess pore pressure.	


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767




	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
○	IS-2	10100.1	44-46 ft	JW	3/30/10			10100.1_2547.dat
△	IS-2	10100.2	44-46 ft	JW	3/30/10			10100.2a_2580.dat
□	IS-2	10100.3	44-46 ft	JW	3/30/10			10100.3_2546.dat

			
	Project: Plant Yates Ash Pond	Location: AP2-1	Project No.: 6189109008
	Boring No.: AP2-1	Sample Type: Undisturbed	
	Description: Brown Silt with Sand		
	Remarks: ASTM D4767-04 Strains at failure based on peak excess pore pressure.		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	⊙	△	□	
Sample No.	IS-2	IS-2	IS-2	
Test No.	10100.1	10100.2	10100.3	
Depth	44-46 ft	44-46 ft	44-46 ft	
Initial	Diameter, in	2.867	2.863	2.867
	Height, in	5.926	5.959	5.606
	Water Content, %	34.9	30.8	29.2
	Dry Density, pcf	88.11	93.09	95.02
	Saturation, %	103.6	103.2	102.3
Before Shear	Void Ratio	0.906	0.804	0.767
	Water Content, %	31.6	27.8	24.6
	Dry Density, pcf	90.82	96.09	101.1
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.849	0.748	0.661
	Back Press., psi	30.	93.98	104.
	Ver. Eff. Cons. Stress, psi	9.991	20.02	40.02
	Shear Strength, psi	5.018	8.891	17.93
	Strain at Failure, %	3.91	2.95	2.89
	Strain Rate, %/min	0.02	0.02	0.02
	B-Value	1.01	0.96	0.93
	Measured Specific Gravity	2.69	2.69	2.69
	Liquid Limit	38	38	38
	Plastic Limit	25	25	25

MACTEC	Project: Plant Yates Ash Pond	
	Location: AP2-1	
	Project No.: 6189109008	
	Boring No.: AP2-1	
	Sample Type: Undisturbed	
	Description: Brown Silt with Sand	
Remarks: ASTM D4767-04 Strains at failure based on peak excess pore pressure.		


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
⊖	IS-2	10100.1	44-46 ft	JW	3/30/10			10100.1_2547.dat
Δ	IS-2	10100.2	44-46 ft	JW	3/30/10			10100.2a_2580.dat
□	IS-2	10100.3	44-46 ft	JW	3/30/10			10100.3_2546.dat

			
	Project: Plant Yates Ash Pond	Location: AP2-1	Project No.: 6189109008
	Boring No.: AP2-1	Sample Type: Undisturbed	
	Description: Brown Silt with Sand		
	Remarks: ASTM D4767-04 Strains at failure based on peak excess pore pressure.		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	⊙	△	□	
Sample No.	IS-2	IS-2	IS-2	
Test No.	10100.1	10100.2	10100.3	
Depth	44-46 ft	44-46 ft	44-46 ft	
Initial	Diameter, in	2.867	2.863	2.867
	Height, in	5.926	5.959	5.606
	Water Content, %	34.9	30.8	29.2
	Dry Density, pcf	88.11	93.09	95.02
	Saturation, %	103.6	103.2	102.3
Before Shear	Void Ratio	0.906	0.804	0.767
	Water Content, %	31.6	27.8	24.6
	Dry Density, pcf	90.82	96.09	101.1
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.849	0.748	0.661
	Back Press., psi	30.	93.98	104.
	Ver. Eff. Cons. Stress, psi	9.991	20.02	40.02
	Shear Strength, psi	8.634	14.94	29.46
	Strain at Failure, %	17	15.7	17
	Strain Rate, %/min	0.02	0.02	0.02
	B-Value	1.01	0.96	0.93
	Measured Specific Gravity	2.69	2.69	2.69
	Liquid Limit	38	38	38
	Plastic Limit	25	25	25

MACTEC	Project: Plant Yates Ash Pond	
	Location: AP2-1	
	Project No.: 6189109008	
	Boring No.: AP2-1	
	Sample Type: Undisturbed	
	Description: Brown Silt with Sand	
	Remarks: ASTM D4767-04	


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
○	IS-2	10100.1	44-46 ft	JW	3/30/10			10100.1_2547.dat
△	IS-2	10100.2	44-46 ft	JW	3/30/10			10100.2a_2580.dat
□	IS-2	10100.3	44-46 ft	JW	3/30/10			10100.3_2546.dat

			
	Project: Plant Yates Ash Pond	Location: AP2-1	Project No.: 6189109008
	Boring No.: AP2-1	Sample Type: Undisturbed	
	Description: Brown Silt with Sand		
	Remarks: ASTM D4767-04		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	○	△	□	
Sample No.	IS-2	IS-2	IS-2	
Test No.	10100.1	10100.2	10100.3	
Depth	44-46 ft	44-46 ft	44-46 ft	
Initial	Diameter, in	2.867	2.863	2.867
	Height, in	5.926	5.959	5.606
	Water Content, %	34.9	30.8	29.2
	Dry Density, pcf	88.11	93.09	95.02
	Saturation, %	103.6	103.2	102.3
Before Shear	Void Ratio	0.906	0.804	0.767
	Water Content, %	31.6	27.8	24.6
	Dry Density, pcf	90.82	96.09	101.1
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.849	0.748	0.661
	Back Press., psi	30.	93.98	104.
	Ver. Eff. Cons. Stress, psi	9.991	20.02	40.02
	Shear Strength, psi	5.488	10.66	21.05
	Strain at Failure, %	5	5	5
	Strain Rate, %/min	0.02	0.02	0.02
	B-Value	1.01	0.96	0.93
	Measured Specific Gravity	2.69	2.69	2.69
	Liquid Limit	38	38	38
	Plastic Limit	25	25	25

MACTEC	Project: Plant Yates Ash Pond	
	Location: AP2-1	
	Project No.: 6189109008	
	Boring No.: AP2-1	
	Sample Type: Undisturbed	
	Description: Brown Silt with Sand	
	Remarks: ASTM D4767-04	


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
○	IS-2	10100.1	44-46 ft	JW	3/30/10			10100.1_2547.dat
△	IS-2	10100.2	44-46 ft	JW	3/30/10			10100.2a_2580.dat
□	IS-2	10100.3	44-46 ft	JW	3/30/10			10100.3_2546.dat

			
	Project: Plant Yates Ash Pond	Location: AP2-1	Project No.: 6189109008
	Boring No.: AP2-1	Sample Type: Undisturbed	
	Description: Brown Silt with Sand		
	Remarks: ASTM D4767-04		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	⊙	△	□	
Sample No.	IS-2	IS-2	IS-2	
Test No.	10100.1	10100.2	10100.3	
Depth	44-46 ft	44-46 ft	44-46 ft	
Initial	Diameter, in	2.867	2.863	2.867
	Height, in	5.926	5.959	5.606
	Water Content, %	34.9	30.8	29.2
	Dry Density, pcf	88.11	93.09	95.02
	Saturation, %	103.6	103.2	102.3
	Void Ratio	0.906	0.804	0.767
Before Shear	Water Content, %	31.6	27.8	24.6
	Dry Density, pcf	90.82	96.09	101.1
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.849	0.748	0.661
	Back Press., psi	30.	93.98	104.
Ver. Eff. Cons. Stress, psi		9.991	20.02	40.02
Shear Strength, psi		5.488	10.66	21.05
Strain at Failure, %		5	5	5
Strain Rate, %/min		0.02	0.02	0.02
B-Value		1.01	0.96	0.93
Measured Specific Gravity		2.69	2.69	2.69
Liquid Limit		38	38	38
Plastic Limit		25	25	25

MACTEC	Project: Plant Yates Ash Pond	
	Location: AP2-1	
	Project No.: 6189109008	
	Boring No.: AP2-1	
	Sample Type: Undisturbed	
	Description: Brown Silt with Sand	
Remarks: ASTM D4767-04		


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
○	IS-2	10100.1	44-46 ft	JW	3/30/10			10100.1_2547.dat
△	IS-2	10100.2	44-46 ft	JW	3/30/10			10100.2a_2580.dat
□	IS-2	10100.3	44-46 ft	JW	3/30/10			10100.3_2546.dat

			
	Project: Plant Yates Ash Pond	Location: AP2-1	Project No.: 6189109008
	Boring No.: AP2-1	Sample Type: Undisturbed	
	Description: Brown Silt with Sand		
	Remarks: ASTM D4767-04		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	○	△	□	
Sample No.	IS-2	IS-2	IS-2	
Test No.	10100.1	10100.2	10100.3	
Depth	44-46 ft	44-46 ft	44-46 ft	
Initial	Diameter, in	2.867	2.863	2.867
	Height, in	5.926	5.959	5.606
	Water Content, %	34.9	30.8	29.2
	Dry Density, pcf	88.11	93.09	95.02
	Saturation, %	103.6	103.2	102.3
	Void Ratio	0.906	0.804	0.767
Before Shear	Water Content, %	31.6	27.8	24.6
	Dry Density, pcf	90.82	96.09	101.1
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.849	0.748	0.661
	Back Press., psi	30.	93.98	104.
Ver. Eff. Cons. Stress, psi		9.991	20.02	40.02
Shear Strength, psi		8.634	14.94	29.46
Strain at Failure, %		17	15.7	17
Strain Rate, %/min		0.02	0.02	0.02
B-Value		1.01	0.96	0.93
Measured Specific Gravity		2.69	2.69	2.69
Liquid Limit		38	38	38
Plastic Limit		25	25	25

	Project: Plant Yates Ash Pond	
	Location: AP2-1	
	Project No.: 6189109008	
	Boring No.: AP2-1	
	Sample Type: Undisturbed	
	Description: Brown Silt with Sand	
Remarks: ASTM D4767-04		


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.



CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
○	IS-2	10100.1	44-46 ft	JW	3/30/10			10100.1_2547.dat
△	IS-2	10100.2	44-46 ft	JW	3/30/10			10100.2a_2580.dat
□	IS-2	10100.3	44-46 ft	JW	3/30/10			10100.3_2546.dat

			
	Project: Plant Yates Ash Pond	Location: AP2-1	Project No.: 6189109008
	Boring No.: AP2-1	Sample Type: Undisturbed	
	Description: Brown Silt with Sand		
	Remarks: ASTM D4767-04		

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767






Symbol	⊙	△	□	
Sample No.	IS-2	IS-2	IS-2	
Test No.	10100.1	10100.2	10100.3	
Depth	44-46 ft	44-46 ft	44-46 ft	
Initial	Diameter, in	2.867	2.863	2.867
	Height, in	5.926	5.959	5.606
	Water Content, %	34.9	30.8	29.2
	Dry Density, pcf	88.11	93.09	95.02
	Saturation, %	103.6	103.2	102.3
	Void Ratio	0.906	0.804	0.767
Before Shear	Water Content, %	31.6	27.8	24.6
	Dry Density, pcf	90.82	96.09	101.1
	Saturation*, %	100.0	100.0	100.0
	Void Ratio	0.849	0.748	0.661
	Back Press., psi	30.	93.98	104.
Ver. Eff. Cons. Stress, psi		9.991	20.02	40.02
Shear Strength, psi		8.634	14.94	29.46
Strain at Failure, %		17	15.7	17
Strain Rate, %/min		0.02	0.02	0.02
B-Value		1.01	0.96	0.93
Measured Specific Gravity		2.69	2.69	2.69
Liquid Limit		38	38	38
Plastic Limit		25	25	25

MACTEC	Project: Plant Yates Ash Pond	
	Location: AP2-1	
	Project No.: 6189109008	
	Boring No.: AP2-1	
	Sample Type: Undisturbed	
	Description: Brown Silt with Sand	
Remarks: ASTM D4767-04		


Phase calculations based on start and end of test.

* Saturation is set to 100% for phase calculations.

CONSOLIDATED UNDRAINED TRIAXIAL TEST by ASTM D4767



	Sample No.	Test No.	Depth	Tested By	Test Date	Checked By	Check Date	Test File
○	IS-2	10100.1	44-46 ft	JW	3/30/10			10100.1_2547.dat
△	IS-2	10100.2	44-46 ft	JW	3/30/10			10100.2a_2580.dat
□	IS-2	10100.3	44-46 ft	JW	3/30/10			10100.3_2546.dat

			
	Project: Plant Yates Ash Pond	Location: AP2-1	Project No.: 6189109008
	Boring No.: AP2-1	Sample Type: Undisturbed	
	Description: Brown Silt with Sand		
	Remarks: ASTM D4767-04		

Attachment D
Critical Section Profile

F






E

D

C

B

A



© Copyright 2007, Southern Company Services, Inc. All Rights Reserved. <small>This document contains proprietary, confidential, and/or trade secret information of the subsidiaries of The Southern Company or of third parties. It is intended for use only by employees of, or authorized contractors of, the subsidiaries of the Southern Company. Unauthorized possession, use, distribution, copying, dissemination, or disclosure of any portion hereof is prohibited.</small>				
Southern Company Generation Engineering and Construction Services FOR				
Georgia Power Company				
PLANT YATES ASH POND DIKE CROSS SECTIONS				
SCALE	PRJ. I.D.	DRAWING NUMBER	SHEET	CONT'D
AS SHOWN		ES1836S1B	1B	FINAL