

§ 257.100(f)(3)(iv) as set forth by §257.83(b)	REPORT OF ANNUAL INSPECTION OF CCR SURFACE IMPOUNDMENT		
	FACILITY NAME: Plant Mitchell Surface Impoundment AP-1, Permit 047-024D(CCR)		
	OWNER/OPERATOR OF FACILITY: Georgia Power Company		
	INSPECTION DATE: November 21, 2025		
	INSPECTING ENGINEER: Patrick B. Rhodes, P.E. (Georgia P.E. License #24586)		
(i)	ANY CHANGES IN GEOMETRY OF THE IMPOUNDING STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION?	No	
	(IF YES, DESCRIBE):		
(ii)	LOCATION AND TYPE OF EXISTING INSTRUMENTATION	See Attached Table	
(ii)	MAXIMUM RECORDED READING OF EACH INSTRUMENT SINCE PREVIOUS ANNUAL INSPECTION	See Attached Table	
(iii)	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF THE IMPOUNDED WATER SINCE PREVIOUS ANNUAL INSPECTION ⁽¹⁾		
	MIN. DEPTH: 0 ft	MAX. DEPTH: 8.5 ft	PRESENT DEPTH: Up to 6.5 ft
	MIN. ELEVATION: 175 ft	MAX. ELEVATION: 183.5 ft	PRESENT ELEVATION: Up to 181.5 ft
(iii)	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF CCR SINCE PREVIOUS ANNUAL INSPECTION ⁽²⁾		
	MIN. DEPTH: 0	MAX. DEPTH: 33.5 ft	PRESENT DEPTH: Up to 33.5 ft
	MIN. ELEVATION: 168 ft	MAX. ELEVATION: 214 ft	PRESENT ELEVATION: Up to 214 ft
(iv)	APPROXIMATE STORAGE CAPACITY OF IMPOUNDING STRUCTURE AT TIME OF INSPECTION	1,230,000 yd ³ ⁽³⁾	
(v)	APPROXIMATE VOLUME OF IMPOUNDED WATER AND CCR AT TIME OF INSPECTION	WATER: 16,000 yd ³ ⁽¹⁾	CCR: 709,000 yd ³
(vi)	ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT AND APPURTENANT STRUCTURES?	No	
	(IF YES, DESCRIBE):		
(vii)	ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION SINCE THE PREVIOUS ANNUAL INSPECTION?	No	
	(IF YES, DESCRIBE):		

- (1) AP-1 is under closure construction and has been dewatered. Water present is related to stormwater management during closure. Temporarily detained contact stormwater is collected in the Contact Water Lagoon for treatment and detained non-contact stormwater is pumped to the site stormwater conveyance system.
- (2) Ash is temporarily dry stacked above perimeter embankment elevation and height will change as closure construction progresses.
- (3) Approximate storage capacity of impounding structure is estimated as the total storage volume of the pond up to the dam crest elevation of 192 feet.



**LOCATION, TYPE, & MAXIMUM RECORDED READINGS OF INSTRUMENTATION
PLANT MITCHELL SURFACE IMPOUNDMENT AP-1**

PIEZOMETER NUMBER	LOCATION	MAXIMUM RECORDED READING ⁽¹⁾
P1NB	N 524600.81, E 2306364.64	153
P1SB	N 523068.09, E 2306172.44	151
P1NT	N 524555.95, E 2306389.13	159
P1ST	N 523089.59, E 2306233.02	151

(1) Maximum recorded reading since last annual inspection; rounded to the nearest foot.